

Bid Document

Bid Details	
Bid End Date/Time	24-07-2020 13:00:00
Bid Opening Date/Time	24-07-2020 13:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Gujarat
Department Name	Education Department Gujarat
Organisation Name	Gujarat Technological University Ahmedabad
Office Name	Ahmedabad
Total Quantity	10
Item Category	Hot and Cold Air Conditioners
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

Hot And Cold Air Conditioners (10 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
CAPACITY / GENERIC	Type of Air Conditioner	High wall Split AC (Hot and Cold)	High wall Split AC (Hot and Cold)
	Compressor (Speed Type)	Inverter (Variable Speed)	Inverter (Variable Speed), Non- Inverter (Fixed Speed)
	Air Conditioning Technology	Hot and Cold	*
	Heating Mechanism	Heat Pump	Heat Pump
	Nominal Capacity (TR)	1	1
	Nominal Cooling Capacity (kcal/hr)	3000 for 1.0 TR	3000 for 1.0 TR
	Nominal Heating Capacity	101 to 110% of Cooling Capacity	101 to 110% of Cooling Capacity
	Coil Material (Evaporator)	Copper	Copper
	Coil Material (Condensor)	Copper	Copper
	Fin Material (Evaporator)	Copper	Copper
	Fin Material (Condensor)	Copper	Copper
	Eco-friendly refrigerant	Yes	Yes
	Minimum Set Temperature	16	*
	Maximum Set Temperature	36	*
	BEE Star Rating	5	5
	Remote Control - inclusive in the scope of supply	Yes	*
	Features	Auto restart,Sleep mode,24 hour On-Off Timer,Power Saver,Turbo cool,Self clean,2-way air swing,4-way air	*

		swing,Speed settings,Humidity Control,Active carbon filter,Anti-Bacteria Filter,Cyclotron filter	
	Minimum length of copper pipe and suitable connecting electrical cable for installation and commissioning - inclusive in the scope of supply	3 metre	3 metre
CONFORMITY / CERTIFICATION	Conformity to Indian Standard	Generally conforming to IS 1391 latest	*
DIMENSIONS / WEIGHT	Overall Dimensions of Indoor Unit (WxHxD) - mm x mm x mm	-	*
	Overall Dimensions of Outdoor Unit (WxHxD) - mm x mm x mm	-	*
	Net Weight of Indoor Unit	-	*
	Net Weight of Outdoor Unit	-	*
WARRANTY & INSTALLATION	Warranty on machine	1	1.0
	Warranty on Compressor	10	10.0
	Installation and Commissioning	With Installation and Commissioning	With Installation and Commissioning

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	GTU REGISTRAR PURCHASE	382424,GUJARAT TECHNOLOGICAL UNIVERSITY GIC-AIC SECTION, IIT SHED, GTU CAMPUS, CHANDKHEDA AHMEDABAD - 382424	10	20

Bid Specific Additional Terms and Conditions

1. IMPORTED PRODUCTS: In case of imported products, OEM or Authorized Seller of OEM should have a registered office in India to provide after sales service support in India. The certificate to this effect should be submitted.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---