

### Bid Document

Bid Details	
Bid End Date/Time	18-07-2020 18:00:00
Bid Opening Date/Time	18-07-2020 18:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Railways
Department Name	Na
Organisation Name	N/a
Office Name	Office Of The Principal Chief Material Manager,north Eastern Railway, Gorakhpur
Total Quantity	800
Item Category	XLPE Cables for Working Voltages from 3.3 kV up to and Including 33 kV
Experience Criteria	1 Year (s)
MSE Exemption for Years Of Experience	Yes
Startup Exemption for Years Of Experience	Yes
Document required from seller	Experience Criteria *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Inspection Required	No

### EMD Detail

Required	No
----------	----

### ePBG Detail

Required	No
----------	----

### Splitting

Bid splitting not applied.

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of years as indicated in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

## **XLPE Cables For Working Voltages From 3.3 KV Up To And Including 33 KV ( 800 meter )**

### **Technical Specifications**

[\\* As per GeM Category Specification](#)

<b>Specification</b>	<b>Specification Name</b>	<b>Values</b>	<b>Bid Requirement (Allowed Values)</b>
GENERIC	Crosslinked Polyethylene Insulated Thermoplastics Sheathed Cables, for Working Voltages from 3.3 kV up to and Including 33 kV conforming to	IS:7098-Part 2:2011 latest	*
	BIS Marked	Yes	*
	BIS Marekd if "Yes" BIS License Number (CM/L Number) - Must declare	-	*
	<b>Types of cable</b>	Three-core armoured, screened	Three-core armoured, screened
	<b>Voltage Grade</b>	Earthed systems: 1.9/3.3 kV	Earthed systems: 1.9/3.3 kV
	<b>Armoured cables upto 11 kV Grade specified in this standard are suitable for use in mines (as per Cl. 1.3 , 4.1.1, Cl. 17.5 and Cl. 21.2.1 of IS:7098 (Part 2):2011 (If "Yes" manufacturer shall have valid BIS License for the same )</b>	Yes	Yes
	<b>Low temperature appliction (If "Yes" manufacturer shall</b>	Yes	Yes

	<b>have valid BIS License for the same )</b>		
	<b>Conductor material (as per Cl.4 of IS:7098 (Part 2):2011 latest</b>	Aluminium	Aluminium
	<b>Outer sheath (Type ST2)</b>	PVC	PVC
	<b>"Nominal Area of Conductor (in Sq.mm)</b>	185	185
CONSTRUCTIONAL	Insulation (conforming to the requiremnt as per Table.1 of IS:7098 (Part 2):2011 latest	cross linked polyethylene	*
	<b>Armouring</b>	Galvanized formed wires armoured	Galvanized formed wires armoured
	<b>Cable packing type (Wound on drum) (as per Cl. 22.1 of I:7098 (Part 2):2011 latest</b>	Wooden drum	Wooden drum
	Identification on cable as per Cl. 21 of IS:7098 (Part 2):2011 latest	Yes	*
	Marking on cable (as per Cl. 22.2 of I:7098 (Part 2):2011 latest	Yes	*
CERTIFICATIONS	Availability of Type test report from Central government/NABL/ILAC accridiated laoratory to prove conformity to the specification	Yes	*
	Test report number - Must declare	-	*
	Report date - Must declare	-	*
	Name of lab - Must declare	-	*
	Address of lab - Must declare	-	*
	All the test reports and certificates shall furnish by the supplier to the buyer/consignee on demand	Yes	*

\* Specifications highlighted in bold are the Golden Parameters.

\* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement ( allowed Values) by the Buyer.

## Additional Specification Documents

### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Murli Dhar Pandey	243122,Office of the Deputy Chief Engineer/Construction, Izzatnagar, Bareilly.	800	30

### Bid Specific Additional Terms and Conditions

1. IMPORTED PRODUCTS: In case of imported products, OEM or Authorized Seller of OEM should have a registered office in India to provide after sales service support in India. The certificate to this effect should be submitted.
2. **Nominated Inspection Agency:** On behalf of the Buyer organization, any one of the following Inspection Agency would be conducting inspection of stores before acceptance:  
Pre-dispatch Inspection at Seller Premises (applicable only if pre-dispatch inspection clause has been selected in ATC): RITES  
Post Receipt Inspection at consignee site before acceptance of stores: RITES
3. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria. In case of bunch bids, the OEM of CATEGORY RELATED TO primary product having highest bid value should meet this criterion.
4. Scope of supply (Bid price to include all cost components) : Only supply of Goods

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---