

Bid Document

Bid Details	
Bid End Date/Time	27-07-2020 17:00:00
Bid Opening Date/Time	27-07-2020 17:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Railways
Department Name	Na
Organisation Name	Rail Coach Factory Kapurthala
Office Name	Kapurthala
Total Quantity	2
Item Category	Molded Case Circuit Breakers (MCCB)
Experience Criteria	1 Year (s)
MSE Exemption for Years Of Experience	Yes
Startup Exemption for Years Of Experience	Yes
Document required from seller	Experience Criteria,OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of years as indicated in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

Molded Case Circuit Breakers (MCCB) (2 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Governing Indian Standard specification as per IS/IEC:60947 part-2:2003 latest	YES	*
	ISI marked	NO	NO
	If ISI Marked 'Yes' declare CM/L Number If 'NO' write NA	-	*
	Rated Current (in Ampere)	400A	400A
	No of poles/Protected poles(PP)	3 Pole	3 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range	MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	35 KA	35 KA
	Rated Voltage	240/415 Volt 50 Hz AC	240/415 Volt 50 Hz AC
CERTIFICATIONS	Availability of Type Test Report from Central Govt./NABL/ILAC accredited lab to prove conformity to specification	YES	*
	Test Report Number (Must declare)	-	*
	Test Report Date (Must declare)	-	*
	Name of Lab (Must declare)	-	*
	Address of Test Lab (Must declare)	-	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Sanjeev Kumar Jindal	144602,Cheif Electrical Engineer Office, Administrative Building Rail coach Factory, Kapurthala	2	20

Bid Specific Additional Terms and Conditions

1.IMPORTED PRODUCTS: In case of imported products, OEM or Authorized Seller of OEM should have a registered office in India to provide after sales service support in India. The certificate to this effect should be submitted.

- 2.Scope of supply (Bid price to include all cost components) : Only supply of Goods
- 3.Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---