

### Bid Document

Bid Details	
Bid End Date/Time	25-07-2020 18:00:00
Bid Opening Date/Time	25-07-2020 18:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Gujarat
Department Name	Energy And Petro Chemicals Department Gujarat
Organisation Name	Gujarat Electricity Board (geb) - Gujarat Urja Vikas Nigam Limited (guvnl)
Office Name	Madhya Gujarat Vij Company Limited Baroda Circle
Total Quantity	100
Item Category	Submersible Cable for Submersible Pumps (Insulated or covered cable)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Inspection Required	No

### EMD Detail

Required	No
----------	----

### ePBG Detail

Required	No
----------	----

### Splitting

Bid splitting not applied.

**Submersible Cable For Submersible Pumps (Insulated Or Covered Cable) ( 100 pieces )**

## Technical Specifications

[\\* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	<b>Cable Type</b>	TWO CORE FLAT CABLES WITH PVC INSULATION AND SHEATHED with multistrand flexible Copper Conductor FOR Submersible Pumps (FOR MAXIMUM CONDUCTOR TEMPERATURE 70°C OR 85°C) duly ISI marked to IS:694 latest	TWO CORE FLAT CABLES WITH PVC INSULATION AND SHEATHED with multistrand flexible Copper Conductor FOR Submersible Pumps (FOR MAXIMUM CONDUCTOR TEMPERATURE 70°C OR 85°C) duly ISI marked to IS:694 latest
CONSTRUCTION	<b>Size of Cable (Sqmm)</b>	2.5	2.5
	Number of cores	3	*
	Material of conductor	Copper(EC grade)	*
	Shape of conductor	Stranded	*
	Insulation	Type C — Heat-resistant cables (HR) as per IS 5831 latest	*
	Sheath	"Type ST2 — cables sheathed with 85°C HRPVC compound to IS 5831 latest"	*
	In addition to marking requirements as per relevant specification, sequential marking for length, Size of the cable, Type of the cable shall be embossed on every metre of the cable	YES	*
	standard cable length in a Coil/Reel	100	*
	Part length which can be supplied by seller	250	*
CERTIFICATION	BIS marked	YES	*
	BIS certificate number	-	*
	Availability of Type test report from Central government/NABL/ILAC accredited laboratory to	YES	*

	prove conformity to the specification for minimum and maximum ratings		
	Type Test Certificate No	-	*
	Type Test Certificate date	-	*
	Name of Lab	-	*
	Address of Lab	-	*
	Test Report to be furnished to the buyer on demand	YES	*

\* Specifications highlighted in bold are the Golden Parameters.

\* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement ( allowed Values) by the Buyer.

#### **Additional Specification Documents**

#### **Consignees/Reporting Officer and Quantity**

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Khadilkar Nitinbhai	391740,Deputy Engineer (Store) Madhya Gujarat Vij Company Limited 66 KV SS Compound, Opp. Prakruti Resort, At. & Po :Chhani Ta.: Vadodara. Dist. : Vadodara	100	15

#### **Bid Specific Additional Terms and Conditions**

1. Scope of supply (Bid price to include all cost components) : Only supply of Goods

[This Bid is also governed by the General Terms and Conditions](#)

**---Thank You---**