

Bid Document

Bid Details	
Bid End Date/Time	23-07-2020 18:00:00
Bid Opening Date/Time	23-07-2020 18:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Finance
Department Name	Department Of Revenue
Organisation Name	Central Board Of Excise And Customs (cbec)
Office Name	Chief Controller Government Opium And Alkaloid Factories New Delhi
Total Quantity	17
Item Category	PLASTIC BODY EVAPORATIVE COOLERS- DESERT COOLER
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

PLASTIC BODY EVAPORATIVE COOLERS- DESERT COOLER (17 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
CAPACITY / TYPE	Nominal Air Delivery / Capacity (Cubic meter per hour)	5000	5000
	Maximum Power Consumption at zero static pressure	350 Watts for 5000 nominal capacity	*
	Type of Mounting	Stand Mounted without castor wheels	Stand Mounted without castor wheels
GENERIC	Sump Tank Capacity (minimum)	80 Liters for 4000 nominal capacity	*
	Body Material of the Plastic Body Cooler	as per clause 5.1 of IS 3315 latest	*
	Thickness of Body of the Plastic Body Cooler (mm)	-	*
	Drain Plug material	Plastic / Rubber	*
	Fan Size	450 mm for 5000 nominal capacity;	*
	Blade Material	G.I	*
	Conformity of Fan Motor	ISI marked to IS: 996 latest	*
	Minimum number of steps for fan speed control	3	*
	Power Factor	0.9 or Better	*
	Conformity of Submersible Pump	Generally conforming to IS:11951 latest	*
	Filter Pads	Synthetic Honeycomb pads	Synthetic Honeycomb pads Or higher
	Thickness of Filter Pad	15 mm or above	*
	Support / Guard for Filter Pads	No	*
	Water Level Indicator	No	*
	Location of the Water Collecting Chamber	At the Bottom	*
	Float Valve installation at inlet	No	No
	Minimum length of ISI marked connecting cable with 3-pin	2.5	*

	moulded Plug Top, 5/6 Amps rating		
	Overall Demension (HxDxW) (mm x mm x mm)	-	*
	Weight	-	*
CERTIFICATION	Conformity to Indian Standrad	Generally conforming to IS: 3315 latest	*
	Availability of the Fan Motor test report from Central Gov/ NABL/ ILAC accredited lab	No	No
	Test Report Number	-	*
	Test Report Date	-	*
	Name & Address of the Lab	-	*
	Availability of the test certificate from CIPET for Plastic Body regarding suitability for coolers	Yes	*
	CIPET Test Report Number	-	*
	CIPET Test Report Date	-	*
WARRANTY	WARRANTY	1	1.0

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Pankaj Kumar Srivastav	233001,Govt. Opium and Alkaloid Works Ghazipur	17	30

Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Only supply of Goods

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---