

Dated: 09-07-2020



Bid Document

2.0 20141110111					
Bid Details					
Bid End Date/Time	20-07-2020 13:00:00				
Bid Opening Date/Time	20-07-2020 13:30:00				
Bid Life Cycle (From Publish Date)	90 (Days)				
Bid Offer Validity (From End Date)	30 (Days)				
Ministry/State Name	Haryana				
Department Name	General Administration And Administrative Reforms Department Haryana				
Organisation Name	N/a				
Office Name	Municipal Corporation Gurugram				
Total Quantity	1				
Item Category	diesel generators- DG Sets (PAC Only)				
Bidder Turnover (Last 3 Years)	26 Lakh (s)				
OEM Average Turnover (Last 3 Years)	200 Lakh (s)				
Experience Criteria	1 Year (s)				
MSE Exemption for Years of Experience and Turnover	No				
Startup Exemption for Years of Experience and Turnover	No				
Document required from seller	Experience Criteria, Past Performance, Bidder Turnover, Certificate (Requested in ATC), OEM Authorization Certificate, OEM Annual Turnover *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer				
Past Performance	10 %				
Bid to RA enabled	No				
Inspection Required	No				

EMD Detail

Advisory Bank	AXIS BANK LTD
EMD Percentage(%)	2.00
EMD Amount	107000

ePBG Detail

Advisory Bank	AXIS BANK LTD
ePBG Percentage(%)	2.00
Duration of ePBG required (Months).	1

- (a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.
- (b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

Beneficiary:

Commissioner

EMD/EPBG in Favor of Commissioner Municipal Corporation Gurugram. (Commissioner Municipal Corporation Gurugram)

Splitting

Bid splitting not applied.

- 1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of years as indicated in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the category of primary product having highest value should meet this criterion.
- 2. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
- 3. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 10% of bid quantity, in at least one of the last three years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (proving supply of cumulative order quantity in any one year) to be submitted along with bid in support of quantity supplied in the relevant year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

Diesel Generators- DG Sets (1 pieces) (Under PAC)

Make	sudhirpowerlimited-cummins

Model c500d5p

Technical Specifications

* As per GeM Category Specification

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
OUTPUT CAPACITY RATING/ PHASE	Nominal Rated Capacity (KVA)	500	500, 600, 750 Or higher
	No of Phase	Three Phase	Three Phase
ENGINE	Make of Engine	Cummins	*
	Model Number of Engine	KTAA19-G10	*
	Capacity of Engine (cc)	18600	*
	Engine Power (kWm)	450	*
	ISI Marking to IS :10001 for engine	No	*
	BIS license No, if applicable	00	*
	Type of Engine cooling	Liquid Cooled	Liquid Cooled
	Type of governer	Electronic	Mechanical, Electronic Or higher
	Class of governer	A0	A0, A1 Or higher
	Number of cylinders (nos)	6	*
	No of Strokes (nos)	4	*
	Rated RPM of Engine (RPM)	1500	1500
	Overload capacity for one hour for every 11 hours continuous running at full load (%)	9	*
	Specific Fuel Consumption (gm/kWh)	206.8	*
	Starting voltage (volt)	12	*
ALTERNATOR	AC GENERATOR(ALTER NATOR) Make	Stamford	*
	AC GENERATOR(ALTER NATOR) model Number	500 KVA Frame	*
	Rating of AC Generator (KVA)	500	*
	Power Factor of AC	0.8	*

	generator		
	Efficiency at rated Power factor at 75% of full Load	95.3	*
	Compliance of Alternator to IS:13364(part-1)	Yes	*
	Type of alternator	Brushless	*
	Voltage Regulation Grade	VG 2	*
	Alternator IP Rating	IP 23	*
	Class of Insulation	Н	*
CONTROL PANEL	Control Panel	AMF	AMF
	IP Rating of Control Panel	IP 53	*
ACOUSTIC ENCLOSURE	Sheet Thickness	1.6	1.6, 1.8, 2 Or higher
	Thickness of Foam	95	*
	Density of Foam for sound insulation	95	*
	Noise level at 1 meter (dB)	72.5	*
BATTERY	Battery Type & Specification	Low Maintenance free to IS: 14257 for high cranking performance	*
	Battery capacity (Ah)	100	*
	No of batteries	2	*
TEST REPORTS	Availability of Type test report for Engine from Central govt/NABL/ILAC accredited laboratory	Yes	*
	Test Report number and date(Engine)	ARAI/MOEF; 29/03/14	*
	Name and address of laboratory(Engine)	ARAI PUNE	*
	Availability of Type test report for Alternator from Central government/NABL/ILAC accredited laboratory	Yes	*
	Test Report number and date(Alternator)	N12B092215; 31/05/12	*
	Name and address of laboratory(Alternator)	DGS&D Pune	*
	DG set meet requirements of Enviro nmental(Protection)	Yes	*

		Rules 1986, in respect of noise and emission norms, as described in STC		
WARRAI		Warranty	2	2.0
INSTALLATION & COMMISSIONING	Installation & Commissioning	With Installation	With Installation	
	Agreed to STC of the Product	Yes	*	

^{*} Specifications highlighted in bold are the Golden Parameters.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporti ng Officer	Address	Quantity	Delivery Days
1	Mahender Singh	122001,GTPL Building C1, Infocity, Sector 34 Gurugram	1	30

Special terms and conditions for category diesel generators- DG Sets

1. In addition to General Terms and Conditions of GeM, Special T&C shall be applicable for Diesel Generating Set/DG Set. click here to view the Special terms and conditions.

Bid Specific Additional Terms and Conditions

- 1. **Upload Manufacturer authorization:** Wherever Authorised Distributors are submitting the bid, Manufacturers Authorisation Form (MAF)/Certificate with OEM details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid.
- 2. IMPORTED PRODUCTS: In case of imported products, OEM or Authorized Seller of OEM should have a registered office in India to provide after sales service support in India. The certificate to this effect should be submitted.
- Bidders can also submit the EMD with Payment online through RTGS / internet banking in Beneficiary name Commissioner Municipal Corporation Gurugram Account No. 919010070385214 IFSC Code UTIB0001787 Bank Name Axis Bank Ltd Branch address Laxmi Bazar Gurugram.
 - Bidder to indicate bid number and name of bidding entity in the transaction details field at the time of on-line transfer. Bidder has to upload scanned copy / proof of the Online Payment Transfer along with bid.
- 4. To be eligible for award of contract, Bidder / OEM must possess following Certificates / Test Reports on the date of bid opening (to be uploaded with bid): Yes.

This Bid is also governed by the General Terms and Conditions

---Thank You---

^{*} Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.