

### Bid Document

Bid Details	
Bid End Date/Time	17-07-2020 15:00:00
Bid Opening Date/Time	17-07-2020 15:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Petroleum And Natural Gas
Department Name	Na
Organisation Name	Hindustan Petroleum Corporation Ltd
Office Name	Petroleum House
Total Quantity	6
Item Category	Rubber Gloves for Electrical Purposes
Experience Criteria	1 Year (s)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Experience Criteria *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Inspection Required	No

### EMD Detail

Required	No
----------	----

### ePBG Detail

Required	No
----------	----

### Splitting

Bid splitting not applied.

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of years as indicated in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

## Rubber Gloves For Electrical Purposes ( 6 pairs )

### Technical Specifications

[\\* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Rubber Gloves, Electrical Purposes conforming to	IS:4770:1991 latest	*
	<b>If Product ISI Marked</b>	1	1, 2
	IF ISI marked Yes, BIS License Number	-	*
	<b>Type of Gloves</b>	Type 3 (Guuntlet type) For use at Voltage not exceeding 7500V, AC rms	Type 1 (Wrist type) For use at Voltage not exceeding 650V AC rms, Type 2 (Guuntlet type) For use at Voltage not exceeding 1100V, AC rms, Type 3 (Guuntlet type) For use at Voltage not exceeding 7500V, AC rms, Type 4 (Guuntlet type) For use at Voltage not exceeding 17000V, AC rms
	<b>Size of Gloves (as per Annexure-A of IS:4770:1991 latest)</b>	11	8, 9, 11
	<b>Composition</b>	Synthetic Rubber	Natural Rubber, Synthetic Rubber, Mixture of Natural and Synthetic rubber
	<b>Construction</b>	Latex	Latex, Calendered sheets
	<b>Minimum internal length from the tip of the second finger to the edge of the cuff shall be (in mm)</b>	400 Guuntlet type	280 for wrist type, 400 Guuntlet type

	<b>Colour of Gloves</b>	Blue for Type 2	Black for Type 1, Blue for Type 2, Green for Type 3, Red for Type 4
	The Gloves shall be packed in	With Polyethylene bags and sealed	*
CERTIFICATIONS	Availability of Type test report with drawings from Central government/NABL/ILAC accredited laboratory to prove conformity to the specification	Yes	*
	Test report number	-	*
	Report date	-	*
	Name of lab	-	*
	Address of lab	-	*
	All the test reports and certificates shall furnish by the supplier to the buyer/consignee on demand	Yes	*

\* Specifications highlighted in bold are the Golden Parameters.

\* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement ( allowed Values) by the Buyer.

### Additional Specification Documents

### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Sanjiv Mili	400008,HPCL, Richardson & Cruddas Building, 2nd Floor, J J Road, Byculla, Mumbai - 400008	6	15

### Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Only supply of Goods
2. Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.
3. Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.
4. Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.
5. Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents

sought in the Bid document, ATC and Corrigendum if any.

6. Material Test Certificate Should Be Sent Along with The Supply. The Material Will Be Checked by Buyer's Lab & the Results of the Lab will be the Sole Criteria for Acceptance of the Item.
7. The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

[This Bid is also governed by the General Terms and Conditions](#)

**---Thank You---**