

Bid Document

Bid Details	
Bid End Date/Time	18-07-2020 17:00:00
Bid Opening Date/Time	18-07-2020 17:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Home Affairs
Department Name	Central Armed Police Forces
Organisation Name	Border Security Force (bsf)
Office Name	Shq Bsf Indreshwar Nagar Jammu/western Command
Total Quantity	19
Item Category	LED Luminaire (for Flood Light) (PAC Only)
Experience Criteria	2 Year (s)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Experience Criteria,Past Performance *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Past Performance	50 %
Bid to RA enabled	No
Inspection Required	No
Estimated Bid Value	100000

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of years as indicated in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

2. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 50% of bid quantity, in at least one of the last three years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (proving supply of cumulative order quantity in any one year) to be submitted along with bid in support of quantity supplied in the relevant year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

LED Luminaire (for Flood Light) (19 pieces) (Under PAC)

Make	philips
Model	philipsuniflood2

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
STANDARDS	LED Luminaire conformity to IS:10322/Part 5/Section 5/2012 latest and IS: 16107 (Part 2/Sec 1):2012 latest	Yes	*
	Photo biological safety of LEDs used shall be as per IS:16108/2012 (exempt group)	Yes	*
	Types of LED Luminaire as per the IS: 16107(Part-2/ Sec.-1)/2012	Type B	*
	Types of LED Modules as per the IS: 16103(Part-2)/2012	Type 3	*
	LED Rating/System Wattage/Rated Power	100W	100W
	Luminaire System Efficacy (Lumen/watt)	>= 100 Lm/Watt	*

	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest	IP66	IP66
	Mounting brackets (included)	Adjustable	*
	Warranty for free replacement (in Years)	2	2
ELECTRICAL EFFICIENCY	Input operating Voltage range and frequency	90 to 300 V olts AC at 50 Hz+/-2 Hz	90 to 300 V olts AC at 50 Hz+/-2 Hz
	Automatic Higher Cut off voltage above 300 volt	Yes	*
	Rated voltage	230 V AC 50 Hz	230 V AC 50 Hz
	AC Power Factor at full load	≥ 0.95	*
	Driver Efficiency (in %age)	≥85	*
	Total Harmonics Distortion (in %age)	≤ 10	*
	"The total circuit power shall not be more than 110 percent of the value declared by the manufacturer"	Yes	*
OPTICAL	LED chip Efficacy	≥130 Lm/Watt	*
	Colour temperature (+/-500K)	6000K	6000K
	Working life for LED (Minimum 50,000 burning hours as per LM-80 report)	Yes	Yes
	Colour Rendering Index(CRI)	≥70	*
	Beam Angle	≥120	*
	Optic lense materal (UV stabilised) (Write NA for without optic lense supply)	Poly carbonate lense	*
THERMAL MANAGEMENT	Heat sink should be die-cast aluminium along with sufficient heat sink fins to dissipate heat effectively	Yes	*
	Capacitor shall be rated for a temperature of	Yes	*

	105 deg. celsius or better		
	Junction temperature	< 85 degC	*
	Operating temperature range	-10 deg C to +50 deg C	*
	Operating Humidity Range	10 % to 95% RH	*
PROTECTION	Short circuit Protection	Yes	*
	Over load protecton	Yes	*
	Over Voltage protection	Yes	*
	Reverse polarity	Yes	*
	High voltage test (1.5 KV for one minute between supply terminals and body of the unit)	Yes	*
	Insulation resistance between earth and current carrying part	>100 M ohm	*
	The luminaire shall be protected against surges and transients (Internal)	>/=4KV	*
	The luminaire shall be protected against surges and transients of >/=10KV (External)	Yes	*
CONSTRUCTIONAL	The Luminaires casing/housing (single piece housing) shall be pressure die casted aluminium alloy with higher thermal conductivity	Yes	*
	The luminaire body must be corrosion resistant epoxy powder coated	Yes	*
	All fastners must be of stainless steel	Yes	*
	The entire housing (both LED section and driver section) shall be dust and water proof having IP 66 protection as per IS:10322 (Part 1):1982 latest	Yes	*
	Extruded silicon loop gasket shall be	Yes	*

	provided in the lantern body to ensure a weather proof seal between the UV Glass cover and the metal housing to exclude the entry of the dust, water, insects etc.,		
	Luminaries light transparency should be of Toughened glass	Yes	*
	Toughned transparent glass cover thickness	>/=4 mm	*
	Toughned Glass shall not get discoloured shall not suffer degradation due to heat and ageing within warranty period	Yes	*
	Number of electronic control gear (power supplies)	1 No.	1 No.
	Driver components shall be industrial grade or above	Yes	*
	PCB shall be FR4 grade minimum 0.8 to 1.0 mm thick or more	Yes	*
	The Luminaires works on single phase three wires system (Phase, Neutral and Earth)	Yes	*
	Suitable connector shall be provided for LED connection between driver output and LED	Yes	*
	Length of ISI marked three core wire (shall be provided along with supply of material)	50 cm	*
	Light Source	SMD LED Chip as per LM 80/IS16106	*
MARKING	"Manufactures Name and and brand on the aluminium die cast body	Engraved/Embossed	*
	Manufacturer's name, model number, serial number	Yes	*

	Date of manufacture (month-year), and lot number as identification mark inside each unit and the outside of each packaging box	Yes	*
REPORTS AND CERTIFICATIONS	LED Make	OSRAM / NICHIA/CREE / SAMSUNG / SEOUL / LUMILED / PHILIPS / EDISON / SYSKA / LUMENMAX / EVERLIGHT / BRIDGELUX / NATIONSTAR / REFOND	*
	System must have EMI/EMC compliance as applicable (Test reports shall be furnish on demand by buyer/consignee)	Yes	*
	LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government lab/NABL/ILAC accredited lab. Reports shall be furnish on demany by buyer (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,)	Yes	*
	LM 80 & TM 21 (Part of LM 80) (Ref. IS:16105:2012) Reports and Photo biological report for LED report from Central Government lab /NABL/ILAC accredited lab. Reports shall be furnish on demany by buyer (LM-80 report shall haveand the Pohoto Biological report of the LED Chip being used in the luminaire)	Yes	*
	Availability of test Report from Central Government lab/NABL/ILAC accredited lab to	Yes	*

Indian Standrad IS:10322/part 5/sec-5/2012 and IS 16107 (Part 2/Sec 1) : 2012		
Seller has to furnish Type test report on demand by buyer/consignee	Yes	*
DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
LED Luminaire for Flood Light shall comply with Compulsory Registration(CRS) of BIS for safety as per IS 10322 (Part 5/Section 5): 2012 as applicable on the date	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporti ng Officer	Address	Quantity	Delivery Days
1	Yashul Sharma	181101,shq bsf indreshware nagar	19	30

Bid Specific Additional Terms and Conditions

- 1. Upload Manufacturer authorization:** Wherever Authorised Distributors are submitting the bid, Manufacturers Authorisation Form (MAF)/Certificate with OEM details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid.
- 2. ISO 9001:** The bidder must have ISO 9001 certification.
- 3. Material Test Certificate Should Be Sent Along with The Supply.** The Material Will Be Checked by Buyer's Lab & the Results of the Lab will be the Sole Criteria for Acceptance of the Item.
- 4. Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.**
- 5. To be eligible for award of contract, Bidder / OEM must possess following Certificates / Test Reports on the date of bid opening (to be uploaded with bid):** LM 79/80 reports.
- 6. Successful bidder will have to ensure that adequate number of dedicated technical service personals / engineers are designated / deployed for attending to the Service Request in a time bound manner and for ensuring Timely Servicing / rectification of defects during**

- warranty period, as per Service level agreement indicated in the relevant clause of the bid.
7. Timely Servicing / rectification of defects during warranty period: After having been notified of the defects / service requirement during warranty period, Seller has to complete the required Service / Rectification within 5 days time limit. If the Seller fails to complete service / rectification with defined time limit, a penalty of 0.5% of Unit Price of the product shall be charged as penalty for each week of delay from the seller. Seller can deposit the penalty with the Buyer directly else the Buyer shall have a right to recover all such penalty amount from the Performance Security (PBG). Cumulative Penalty cannot exceed more than 10% of the total contract value after which the Buyer shall have the right to get the service / rectification done from alternate sources at the risk and cost of the Seller besides forfeiture of PBG. Seller shall be liable to re-imburse the cost of such service / rectification to the Buyer.
8. After award of contract – Successful Bidder shall have to get advance sample approved from buyer before bulk manufacturing / starting bulk supplies. Successful Bidder shall submit 02 samples for Buyer's approval, within 5 days of award of contract. Buyer shall, as per contract specifications framework, either approve the advance sample or will provide complete list of modification required in the sample within 5 days of receipt of advance sample. Seller shall be required to ensure supply as per approved sample with modifications as communicated by Buyer. If there is delay from buyer side in approval of advance sample – the delivery period shall be refixed without LD for the period of delay in sample approval. In case, the sample is found to have major deviations / not conforming to the Contract specifications, the buyer at its discretion may call for fresh samples for approval before allowing bulk supplies or may terminate the contract after notifying the deviations to the seller. Unless otherwise provided in the contract, all samples required for test shall be supplied by the contractor free of cost. Where under the contract, the contractor is required to submit an advance sample, any expenses incurred by the contractor on or in connection with the production of stores in bulk, before the sample has been approved unconditionally shall be borne by the Seller and he shall not claim any compensation in the event of such sample being found unacceptable by the Buyer / Consignee.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---