

Bid Document

Bid Details	
Bid End Date/Time	27-07-2020 15:00:00
Bid Opening Date/Time	27-07-2020 15:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	60 (Days)
Ministry/State Name	Ministry Of Shipping
Department Name	Na
Organisation Name	Directorate General Of Lighthouses And Lightships
Office Name	Vishakhapatnam
Total Quantity	12
Item Category	Buy Back - Stationary Value Regulated lead acid batteries (PAC Only)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Certificate (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

Buy Back - Stationary Value Regulated Lead Acid Batteries (12 pieces) (Under PAC)

Make	exide
Model	exidesolatubular6lms150l

Technical Specifications

* As per GeM Category Specification

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
Scope of Buy back	Cells / Battery with buy back means exchange of one new unit with one old unit	Yes	*
Description of New Battery to be supplied by Seller	Stationary Value Regulated lead acid batteries conforming to	IS: 15549/2005 with Amendment 1 and 2 latest	*
	BIS Marked	No	No
	BIS Marked if "YES" declare BIS License Number (CM/L Number) If "NO" write NA	NA	*
	Battery Voltage	12 Volt	12 Volt
	Battery Capacity (in Ah) at 10 H Rate	150 Ah	150 Ah
	Material of Container	Polypropylene Co-polymenr (PPCP)	Polypropylene Co-polymenr (PPCP)
	Material of separators as per Cl. 4.5 of IS:15549:2005 latest	Glass Mat	*
	Battery supply condition	Factory Charged Condition	*
CONSTRUCTIONAL	Material and construction for Containers, Cell Lids, Plates, Electrolyte, Terminal posts, Fasteners, Connectors and Separators as per Cl. 4 of IS:15549:2005 latest	Yes	*
	Marking as per Cl. 8 of IS:15549: 2005 latest	Yes	*
	Application of battery	Float	*
	Number of cells per battery	6 Cells for 12 Volt Battery	6 Cells for 12 Volt Battery
	Method of connections between cells	Burnt	Burnt
	Over all dimension of each battery (Length x Width x Height) in mm - Must declare	500 X 187 X 416 MM	*
	Weight of each battery (in Kg) - Must declare	65	*
	Instructions/Manuals shall be furnished for procedure and monitoring the health of battery during maintenance and preventive measures required	Yes	*
CERTIFICATIONS	Warranty (in Years)	5	5
	Availability of complete and	Yes	*

	satisfactory type test Report from Central Government / NABL/ ILAC accredited laboratory to showing conformity of the Specification		
	Test report Number	47/15/BT/NISE	*
	Report date	01.04.2016	*
	Name of Lab	NISE	*
	Address of Lab	NISE, Gurgaon-122003	*
	All the test reports and certificates shall furnish to the buyer/consignee on demand	Yes	*
Description of Old Battery to be given by Buyer	Old battery shall be of similar volt and Ah (with +/-15% tolerance in Ah) but need not to be of same make / brand	Yes	*
	Old battery may not be in working condition	Yes	*
	The seller will collect the old Cell/Batteries from buyer end / consignee end at its own cost either at the same time of delivery or after delivery of new cells / battery	Yes	*
	Manufacturer / Seller / Supplier should have all valid licenses as applicable and meet all Govt., instructions and guidelines / Gazette notifications update as applicable to dispose of old cells / batteries	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	RATAN SINGH YADAV	535204, Navigational Assistant I, Santapalli Lighthouse, Chintapalli(Post) Via Poosapatirega, Vizianagaram(District)	12	30

Bid Specific Additional Terms and Conditions

- 1.Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---