

Engineer Addendum ? 2025-06-26

Re: F-02 Unit 5A (Joist rot):

- Deferral increases risk of load failure. Recommend immediate structural remediation.
- Waterproofing without fixing structure may mask symptoms but not address safety.