

Dry Riser System

Certificate of Conformity

Certificate Number VFP09129/0809

BUILDING

4 High Court
Leeds

Client – PH Plumbing

Date of Test: 08/09/25

Viva Fire Protection Ltd, confirm having installed, inspected and tested one dry riser system at the above site.

The system was found to conform to the requirements of BS 9990:2015

The dry riser system comprises of 1 inlet valve and 2 outlet valves.

The Viva Fire test comprised of static pressure test with water to 12 bar of the whole system for 15 minutes

Signed on behalf of Viva Fire Protection Ltd

Date 08/09/25



Dale Booth