

Bus #	Voltage		Generation		Load	
	Mag(pu)	Ang(deg)	P (MW)	Q (MVar)	P (MW)	Q (MVar)
1	1.060	0.000*	217.95	-13.65	-	-
2	1.045	-4.605	46.67	39.31	21.70	12.70
3	1.010	-11.941	6.55	22.34	94.20	19.00
4	1.018	-9.879	-	-	47.80	-3.90
5	1.020	-8.406	-	-	7.60	1.60
6	1.070	-13.831	0.00	12.67	11.20	7.50
7	1.062	-12.937	-	-	-	-
8	1.090	-12.937	0.00	17.58	-	-
9	1.056	-14.521	-	-	29.50	16.60
10	1.051	-14.685	-	-	9.00	5.80
11	1.057	-14.389	-	-	3.50	1.80
12	1.055	-14.684	-	-	6.10	1.60
13	1.050	-14.763	-	-	13.50	5.80
14	1.036	-15.626	-	-	14.90	5.00

Total: 271.17 78.26 259.00 73.50

Branch Data								
Brnch #	From Bus	To Bus	From Bus P (MW)	Injection Q (MVar)	To Bus P (MW)	Injection Q (MVar)	Loss (I ² * Z)	
							P (MW)	Q (MVar)
1	1	2	145.46	-17.70	-141.77	23.10	3.687	11.26
2	1	5	72.49	4.05	-69.94	1.16	2.549	10.52
3	2	3	69.58	3.93	-67.48	0.29	2.100	8.85
4	2	4	55.57	-1.48	-53.93	2.85	1.643	4.99
5	2	5	41.59	1.06	-40.69	-1.98	0.907	2.77
6	3	4	-20.17	3.05	20.45	-3.66	0.276	0.71
7	4	5	-58.64	14.80	59.11	-13.31	0.471	1.49
8	4	7	28.18	-9.66	-28.18	11.37	0.000	1.71
9	4	9	16.14	-0.42	-16.14	1.74	0.000	1.31
10	5	6	43.92	12.53	-43.92	-8.14	0.000	4.39
11	6	11	7.25	3.58	-7.19	-3.47	0.054	0.11
12	6	12	7.77	2.51	-7.70	-2.36	0.072	0.15
13	6	13	17.69	7.23	-17.48	-6.81	0.211	0.42
14	7	8	-0.00	-17.12	0.00	17.58	0.000	0.46
15	7	9	28.18	5.75	-28.18	-4.94	0.000	0.81
16	9	10	5.33	4.20	-5.32	-4.16	0.013	0.03
17	9	14	9.49	3.59	-9.37	-3.34	0.117	0.25
18	10	11	-3.68	-1.64	3.69	1.67	0.012	0.03
19	12	13	1.60	0.76	-1.60	-0.75	0.006	0.01
20	13	14	5.58	1.76	-5.53	-1.66	0.053	0.11
Total:							12.173	50.37

>>