



U.S. Test, Co. LLC

Specializing in C-Store Compliance

P.O Box 341313
Austin, TX 78734
1-800-255-2519

512-589-7666 call or text to schedule testing

Kirk (owner): ustestco1@gmail.com
USTESTCO.COM

LOCATION: _____

ADDRESS: _____ DATE: _____

REASON FOR TEST: _____

FAC # _____

2022-2023
FUEL LINE TEST

GAS BRAND _____

TEST REQUESTED BY: _____

Name

Position

SPECIAL INSTRUCTIONS: _____

CONTRACTOR OR COMPANY MAKING TEST

MECHANIC(S) NAME: _____

IS LD TEST REQUIRED?

☐ YES ☐ NO

LEAK DETECTORS

☐ MLLD ☐ ELLD

TYPE OF PUMP

☐ SUCTION ☐ SUB.

OF DISPENSERS

OF LINES

TESTING NOTES:

IDENTIFY EACH LINE AS TESTED	TIME	LOG OF TEST PROCEDURES, AMBIENT TEMPERATURE, WEATHER, ETC.	PRESSURE		VOLUME		REMARKS	
			psi OR kPs		READING			NET CHANGE
			BEFORE	AFTER	BEFORE	AFTER		
	15	BLEEDBACK	50	0				
REG	30	START TESTING	50	50				
	45	CONTINUED	50	50				
	15	BLEEDBACK	50	0				
PREM	30	START TESTING	50	50				
	45	CONTINUED	50	50				
	15	BLEEDBACK	50	0				
DSL	30	START TESTING	50	50				
	45	CONTINUED	50	50				

TEST
RESULTS

Line Identification	Meet Criteria	Net Volume Change Per Hour	Date Tested
REG	PASS		
PREM	PASS		
DSL	PASS		

CONTRACTOR CERTIFICATION

PETRO- TITE SYSTEM