Card-reader door hardware - 24V power supply

Revision 1 - Patient rooms, Level 2

Project	Riverside Medical Center - North Tower Expansion (RMC-04)
Submitted by	Secure Access Hardware Co. - via Vanguard Construction Group
Spec section	08 71 00 Door Hardware; 28 13 00 Access Control
Revision	Rev 1 supersedes Rev 0 (12V supply)
Reason	Electrified mortise locks specified at 24VDC; Rev 0 listed a 12VDC supply.
Action requested	Owner acknowledgement before hardware fabrication release.

REVIEW STAMP

[ ] Reviewed - no exceptions [ ] Make corrections noted [ ] Revise and resubmit

Reviewer: _____ Date: _____

Hardware schedule - patient room doors (excerpt)

Door	Lock	Reader	Supply	Draw (A)
L2-201	ML20900 EL	R10 iCLASS	PS902 24V	0.45
L2-203	ML20900 EL	R10 iCLASS	PS902 24V	0.45
L2-205	ML20900 EL	R10 iCLASS	PS902 24V	0.45
L2-207	ML20900 EL	R10 iCLASS	PS902 24V	0.45
L2-209	ML20900 EL	R10 iCLASS	PS902 24V	0.45
L2-211	ML20900 EL	R10 iCLASS	PS902 24V	0.45
L2-213	ML20900 EL	R10 iCLASS	PS902 24V	0.45
L2-215	ML20900 EL	R10 iCLASS	PS902 24V	0.45

Rough-in: single-gang box at 48" AFF on the latch side, 6" from the frame (revised from 42").

Changed in Rev 1 are the supply and the reader box height; lock hardware is unchanged.

Product data - PS902 power supply

Regulated, filtered 24VDC 2A power supply with fire-alarm interface and battery charging. Supports up to four electrified locks on independent PTC-protected outputs. UL 294 and UL 603 listed. Enclosure 11" x 11" x 4", mounts above the ceiling within 50 ft of the door, served from the nearest life-safety branch circuit.