

EVIDENCE PACKAGE / BUI-1042 / V1

Garage GFCI receptacle below required elevation

Cooper Residence Renovation / CR-2026-017 / Building: Residence / Space: Garage / Wall: East wall / Near: Entry door

PRIORITY	CLASSIFICATION	EVIDENCE	ISSUE STATUS
HIGH	UNAPPROVED DEVIATION	SUFFICIENT	READY FOR REVIEW

Verification finding

OBSERVED	REQUIRED / EXPECTED	DIFFERENCE
GFCI box centerline measures 12 inches above finished floor at the garage east wall.	E1.1 Electrical Note 3 requires garage receptacle centerline at a minimum 18 inches AFF.	Installed centerline is 6 inches below the explicit approved drawing requirement.

Recommended route

FIELD CORRECTION PUNCH	Installed centerline is 6 inches below the explicit approved drawing requirement.
------------------------	---

Evidence register

TYPE	EVIDENCE	LOCATION / CAPTURE
PHOTO	Garage east wall context Open stud wall near the garage entry door; GFCI rough-in visible.	Building: Residence / Space: Garage / Wall: East wall / Near: Entry door 2026-07-12T10:18:00-07:00
MEASUREME NT	GFCI centerline tape measurement Tape shows receptacle centerline at approximately 12 inches AFF.	Building: Residence / Space: Garage / Wall: East wall / Near: Entry door 2026-07-12T10:18:20-07:00
PHOTO	Receptacle rough-in detail Close view of the installed box before wall close-in.	Building: Residence / Space: Garage / Wall: East wall / Near: Entry door 2026-07-12T10:18:38-07:00

Field image review



Garage east wall context



GFCI centerline tape measurement



Receptacle rough-in detail

Source index

Every requirement statement in this package must be checked against the exact document revision below. Superseded or unapproved sources cannot authorize work.

#	DOCUMENT / REVISION	PAGE	CITED REQUIREMENT
1	E1.1 / Rev IFC-1 / APPROVED SHA-256: 50be9d19503471862a14e1383cbb5c4cf04a8cd97c237521cc324221e104bec1	1	Electrical Note 3: Garage receptacle centerline shall be minimum 18 inches above finished floor.

Review control

REPORT ID	VERSION	GENERATED	CONTROL
rpt_demo_bui_1042	1	2026-07-12 17:25 UTC	DRAFT / REVIEW REQUIRED

BUII assembles a traceable review record. It does not make a design decision, authorize a change, determine contractual entitlement, or replace review by the responsible architect, engineer, contractor, or authority having jurisdiction.