

EVIDENCE PACKAGE / BUI-1042 / V1

Garage GFCI receptacle below required elevation

Cooper Residence Renovation / CR-2026-017 / Residence / Garage / East wall / Entry door

PRIORITY	CLASSIFICATION	EVIDENCE	ISSUE STATUS
HIGH	UNAPPROVED DEVIATION	SUFFICIENT	READY FOR REVIEW

Observed condition

GFCI box centerline measures 12 inches above finished floor at the garage east wall.

Required / expected condition

E1.1 Electrical Note 3 requires garage receptacle centerline at a minimum 18 inches AFF.

Verified difference

Installed centerline is 6 inches below the explicit approved drawing requirement.


Recommended route

field_correction_punch


Evidence register

TYPE	EVIDENCE	LOCATION / CAPTURE
PHOTO	Garage east wall context Open stud wall near the garage entry door; GFCI rough-in visible.	Residence / Garage / East wall / Entry door 2026-07-12T10:18:00-07:00
MEASUREMENT	GFCI centerline tape measurement Tape shows receptacle centerline at approximately 12 inches AFF.	Residence / Garage / East wall / Entry door 2026-07-12T10:18:20-07:00
PHOTO	Receptacle rough-in detail Close view of the installed box before wall close-in.	Residence / Garage / East wall / Entry door 2026-07-12T10:18:38-07:00

Field image review



Garage east wall context



GFCI centerline tape measurement



Receptacle rough-in detail

Source index

Every requirement statement in this package must be checked against the exact document revision below. Superseded or unapproved sources cannot authorize work.

#	DOCUMENT / REVISION	PAGE	CITED REQUIREMENT
1	E1.1 / Rev 03 / APPROVED SHA-256: 85dceb1e6df4016fed87d520f d9c22a6049e351927123c6b587d69731 0a77fda	1	Electrical Note 3: Garage receptacle centerline shall be minimum 18 inches above finished floor.

Review control

REPORT ID	VERSION	GENERATED	CONTROL
rpt_demo_bui_1042	1	2026-07-12 17:25 UTC	DRAFT / REVIEW REQUIRED

BUII assembles a traceable review record. It does not make a design decision, authorize a change, determine contractual entitlement, or replace review by the responsible architect, engineer, contractor, or authority having jurisdiction.