

RFI / RFI-018 / V1

Office partition dimension conflict at grid C

Cooper Residence Renovation / CR-2026-017 / Residence / Office / Grid C

BALL IN COURT	DUE DATE	COST IMPACT	SCHEDULE IMPACT
Studio North Architects	2026-07-16	Unknown - layout hold only	Two working days if unanswered after July 16

Existing condition

A1.1 locates the office partition from the exterior face, while Detail 4/A5.2 dimensions the same partition from the structural grid.

Contract-document conflict

The two references produce a 76 mm difference in partition location.

Question

Please confirm the controlling reference for the office partition and provide the approved offset from grid C.

Suggested answer - for review

Use the grid-based dimension shown in the enlarged detail, subject to architect confirmation.

Evidence register

TYPE	EVIDENCE	LOCATION / CAPTURE
-	No evidence linked.	-

Source index

Every requirement statement in this package must be checked against the exact document revision below. Superseded or unapproved sources cannot authorize work.

#	DOCUMENT / REVISION	PAGE	CITED REQUIREMENT
1	A1.1 / Rev 03 / APPROVED SHA-256: 0583ecbdf0ef7cc120778af37f5543c9efc177fa93d0bef67366806b7f8c154a	1	Office partition is dimensioned from the west exterior wall face.

Review control

REPORT ID	VERSION	GENERATED	CONTROL
rpt_demo_rfi018	1	2026-07-12 17:25 UTC	DRAFT / REVIEW REQUIRED

BUILI assembles a traceable review record. It does not make a design decision, authorize a change, determine contractual entitlement, or replace review by the responsible architect, engineer, contractor, or authority having jurisdiction.