Extinguishers: what to add to your model

Read with the existing egress sheets (pages 1-9). New extinguisher layouts are on pages 11-13; services and BMS guidance follows on pages 15-18.

GROUND	FIRST	SECOND	TOTAL
11 units + 11 signs	8 units + 8 signs	8 units + 8 signs	27 units + 27 signs

This is a proposed distribution, not a certified minimum quantity. Normal offices are provisionally treated as light hazard. Plant, archives, records and UPS/battery spaces need separate hazard classification. No site scale, equipment inventory, door survey or verified travel-distance study was supplied.

DESIGN BASIS	APPLICATION TO THIS BUILDING	REFERENCE
Portable extinguishers	Use NFPA 10 for selection, rating, distribution, mounting and maintenance. NFPA 101 supplies the wider life-safety context.	NFPA 10; NFPA 101
Office Class A coverage	For a light-hazard starting check: minimum 2-A; 3,000 ft2 per A unit. A 2-A unit covers up to 6,000 ft2 (about 557 m2), subject to the travel limit.	NFPA 10 (2022), Table 6.2.1.1; source [3]
Travel distance	Class A: no more than 75 ft (22.9 m) along an accessible walking route. Do not use circles through walls, atrium voids or locked doors.	NFPA factsheet [2]
Other fire classes	Class B selection depends on liquids and rating; travel is typically 30 or 50 ft. Class C suitability is needed for energized electrical equipment. Class K cooking-oil coverage is separate.	Sources [2], [4]
Edition and approval	NFPA lists a 2026 edition of NFPA 10. Numeric placement guidance here uses the cited 2022-based material. Confirm the locally adopted edition and changes before specification.	Authority having jurisdiction (AHJ) + fire designer

Why more than an area-only minimum? The two wings, separate service rooms and room-door routes need reachable stations. For context only, the assumed 40 x 24 m rectangle is 960 m2; two 2-A units could satisfy a light-hazard area calculation, but that does not establish coverage or safe access.