Mounting, signs and the 3D handoff

Use the IDs in the drawings, coordinate schedule and digital-twin objects consistently. Dimensions below are relative to each floor, not the whole building.

ITEM	MODEL / INSTALLATION INTENT	STATUS
Extinguisher position	Suggested top height: 1.20 m above finished floor. For gross weight up to 40 lb (18.14 kg), NFPA 10 maximum top height is 5 ft (1.53 m); heavier portable units: 3.5 ft (1.07 m). Bottom clearance at least 4 in. (102 mm).	1.20 m is a modelling choice; check actual unit and accessibility. [2]
Location signs	One sign above each station. Suggested model: 200 x 200 mm red panel with white extinguisher pictogram; center at 2.10 m. Use a two-sided projecting sign for corridor approaches where helpful.	Size and 2.10 m are project choices, not universal NFPA dimensions.
Visibility	Keep extinguisher identification visible. If the unit is obscured, locate a visible sign or directional marker that leads to it. Do not use an EXIT legend for an extinguisher.	Final sign format, language and sightlines require approval. [2]
ABC-O: 19 units	Provisional office selection: listed multipurpose unit with at least 2-A:10-B:C rating. Actual fuel inventory and adopted code may require a higher rating.	Select by labelled rating, not cylinder weight alone.
ABC-S: 7 units	Reserve a listed ABC unit at each plant / archive / records station. Initial modelling allowance: at least 2-A:20-B:C; final rating may be higher.	No diesel, solvent or concentrated-storage hazard is signed off.
CA-E: 1 unit	Server/UPS: reserve a listed clean-agent portable unit with suitable A and C ratings (at least 2-A for the provisional ordinary-combustible area). Check agent, listing and room contents.	Do not substitute a B:C-only CO2 unit for required A coverage. Battery hazards require a separate design.

Pantries: no commercial cooking is shown. FE-xx-05 is outside each pantry. If fryers or grease-producing commercial appliances are introduced, add a Class K unit within 30 ft (9.1 m) of the cooking hazard and review hood/duct suppression; it is not included in the 27-unit count. [4]

Coordinates: (0,0) is the assumed front-left envelope corner; X increases right, Y toward the rear. Use floor-local Z; floor elevations are unknown. Sign IDs SG-G-01, for example, pair with FE-G-01. Check the farthest occupied points through actual doors and aisles; add or move units if the applicable walking limit is exceeded.