

DANIEL JAKOB

OPTIMISING THE HYBRID OPERATION
TEMPERATURE WINDOW OF A HYBRID
HEATING SYSTEM IN THE IRISH CLIMATE

OPTIMISING THE HYBRID OPERATION TEMPERATURE WINDOW OF A HYBRID HEATING SYSTEM IN THE IRISH CLIMATE

A NUMERICAL SIMULATION STUDY OF AN AIR-WATER HEAT PUMP
AND CONVENTIONAL GAS BOILER IN A RESIDENTIAL SETTING

DANIEL JAKOB
(18409686)



Mechanical Engineering Master's (MEng.)
School of Mechanical and Materials Engineering
College of Engineering & Architecture
University College Dublin

21st March 2023 – v0.1

Daniel Jakob: *Optimising the Hybrid Operation Temperature Window of a Hybrid Heating System in the Irish Climate*, A Numerical Simulation Study of an Air-Water Heat Pump and Conventional Gas Boiler in a Residential Setting, © May 2023

SUPERVISOR:

Prof. Donal Finn

COLLABORATOR:

Dr Mohammad Saffari

EXAMINER:

Dr Joe Bloggs

HEAD OF SCHOOL:

Prof. Kenneth Stanton

Mechanical Engineering Master's (MEng.) Thesis 2023:XX
School of Mechanical and Materials Engineering
College of Engineering & Architecture
University College Dublin
Belfield, Dublin 4, Ireland

Typeset in L^AT_EX, with LuaL^AT_EX and the classicthesis v4.6
Printed by XXX, 15th May 2023, Ballsbridge, Dublin 4, Ireland

FONTS:

main text font: TeX Gyre Pagella, math font: TeX Gyre Pagella
Math, monospace font: Bera Mono

SOURCE AVAILABLE AT:

<https://github.com/daniel-jakob/Thesis>.

CONTENTS

I Preamble

1	Introduction	3
1.1	Context	3
1.2	Aim	8
1.3	Motivation	9
1.4	The Problem	9
1.5	Thesis Layout	9
2	Literature Review	11
2.1	Heat Pumps	11
2.1.1	Vapour-Compression Cycle	14
2.1.2	HHS	15
2.1.3	Operating Modes of HHSs	17
2.1.4	Buffer Tank	19
2.1.5	Frosting and Defrosting	20
2.2	HHDs and Design Temperatures	23
2.3	Primary Energy	26
2.4	Electrification of Heating	29
2.5	Controllers and Control Theory	30
2.5.1	PID Controllers	32
2.5.2	Noise and Error	32
2.6	Verification & Validation of Model	33
2.6.1	Verification	35
2.6.2	Validation	35
2.7	Conclusion	37

II Model and Results

3	Methodology	41
3.1	Overview	41

3.2	Experimental Reference Building	41
3.2.1	Experimental Measurements	42
3.3	Building and Heating System Models	42
3.3.1	Verification	42
3.3.2	HHS Model	44
3.4	Sensitivity Analysis	45
3.5	Eco-Economic Assessment	45
3.6	Conclusion	45
4	System Model	47
4.1	Location	47
4.2	Form and Fabric	47
4.2.1	Thermal Properties of Constructions	49
4.3	Schedules, Equipment and Internal Gains	52
4.3.1	Occupancy Gains	53
4.3.2	Lighting	54
4.3.3	Plug Loads and Equipment	54
4.4	Climate	55
4.5	Heating System	55
4.5.1	ASHP	55
4.5.2	Radiators	56
4.5.3	Thermal Storage Tank	57
4.5.4	Boiler	57
4.5.5	Heating System Behaviour	58
4.6	Load Profiles	58
5	Sensitivity Analysis	59
6	Eco-Economic Assessment	61
7	Conclusions	63
	Bibliography	65
iii	Appendix	
A	Appendix Test	79
A.1	Appendix Section Test	79
A.2	Another Appendix Section Test	80

LIST OF FIGURES

Figure 2.1	HHS with an AWHP and condensing gas boiler [12]	17
Figure 2.2	Bivalent-parallel operating scheme [11].	18
Figure 2.3	Bivalent operation modes	18
Figure 2.4	Heating Duration Curve	26
Figure 2.5	PE breakdown by fuel type and sector	28
Figure 3.1	Space heating load for dwelling: experimental vs. simulation	45
Figure 4.1	Dwelling Floor Plan	48
Figure 4.2	3D Model of Reference Building	48
Figure 4.3	Flowchart diagram of HHS behaviour	58

LIST OF TABLES

Table 4.1	Summary of U-Values	49
Table 4.2	Exterior Wall Construction	49
Table 4.3	Exterior Floor Construction	50
Table 4.4	Pitched Roof Construction	50
Table 4.5	Hipped Dormer Roof Construction	50
Table 4.6	External Glazing Construction	51
Table 4.7	External Glazing Construction (Deep Retrofit)	51
Table 4.8	Exterior Floor Construction	51
Table 4.9	Exterior Wall Construction	52

Table 4.10	Occupancy Schedules	53
Table 4.11	Activity Schedule	54
Table 4.12	Lighting, Plug Loads and Equipment Gains Schedules and Load Densities [63]	55
Table A.1	Autem usu id	79

LISTINGS

Listing A.1	A floating example (listings manual)	80
-------------	--------------------------------------	----

ACRONYMS

COP	Coefficient of performance
HHS	Hybrid heating system
ASHP	Air source heat pump
PE	Primary energy
PEF	Primary energy factor
HVAC	Heating, Ventilation & Air Conditioning
PES	Primary energy savings
SPF	Seasonal performance factor
SCOP	Seasonal coefficient of performance
RHI	Renewable Heat Incentive
DHWP	Domestic Hot Water Production
AWHP	Air-Water Heat Pump
HP	Heat Pump
HHPS	Hybrid Heat Pump System

RES	Renewable Energy Share
HDD	Heating degree days
PID	Proportional-integral-derivative
RMSE	Root mean square error
CV(RMSE)	Coefficient of Variation of Root Mean Square Error
NMBE	Normalized mean bias error
SMAPE	Symmetrical mean absolute percentage error
ACPH	Air Changes Per Hour
BEM	Building Energy Model

ABSTRACT

A full factorial parametric study was carried out on a numerical model of hybrid heating system consisting of an air source heat pump and a gas boiler with. This thesis aims to use the Modelica modelling language to determine an optimal bivalent parallel operation temperature window for the hybrid heating system. A two-storey, residential home was modelled, verified and validated against the reference home, and year long simulations were performed to optimise the temperature window along two metrics: reducing CO₂ emissions and reducing annual running costs.

Keywords: Hybrid heat pumps.

DECLARATION

I hereby certify that the submitted work is my own work, was completed while registered as a candidate for the degree stated on the Title Page, and I have not obtained a degree elsewhere on the basis of the research presented in this submitted work.

Belfield, Dublin 4, May 2023

Daniel Jakob

ACKNOWLEDGMENTS

Firstly, I want to express my greatest appreciation to my supervising professor, Prof. Donal Finn, for his invaluable guidance and feedback throughout the research project. His input and encouragement have been essential in shaping the direction of this project.

I also extend my gratitude to the project collaborator, Dr Mohammad Saffari, for his contributions to this work. His expertise in EnergyPlus (and accompanying software) and willingness to share data to carry out the analysis has been instrumental in the success of this project, and I am thankful for his enthusiasm to collaborate and share his knowledge.

I want to thank Dr Alessandro Maccarini for His Modelica/Dymola course in Copenhagen, which provided me with a solid foundation in the subject matter. His dedication to teaching has been inspiring. Thank you to UCD for providing funding to visit Copenhagen, and software licenses. Thank you to Dr Michael Wetter and the Modelica Buildings Library team at Lawrence Berkeley National Laboratory for their work on progressing the building energy simulation field.

I cannot forget to acknowledge the unwavering support and patience of my family and friends, who have been a constant source of encouragement throughout my academic journey. Thank you to Linus Sebastian, Michael Stevens, Derek Muller, Hank Green, and my late grandfather Jürgen Bielstein for being the people for ultimately influenced me to pursue mechanical engineering.

Special thanks to fellow Modelica-enjoyer Matthew Duffy, my sauna-buddy Daniel Joyce and Cormac Moloney for being my debugging rubber duck.

Finally, thank you to my parents for giving me the opportunity to attend university, providing for me and always wanting the best for me. Thank you, I love you.

Dedicated to...

NOMENCLATURE

Physics Constants

c	Speed of light in a vacuum	$299\,792\,458\,\text{m s}^{-1}$
G	Gravitational constant	$6.674\,30\times 10^{-11}\,\text{m}^3\,\text{kg}^{-1}\,\text{s}^{-2}$
h	Planck constant	$6.626\,070\,15\times 10^{-34}\,\text{J Hz}^{-1}$

Subscripts

i	index variable
-----	----------------

Other Symbols

\bar{Y}	average value
\hat{Y}	actual or reference value
N	total number of data points
p	number of adjustable model parameters, for calibration purposes, ASHRAE suggests $p = 1$
Y	simulated or forecast value

Part I

PREAMBLE

INTRODUCTION

1.1 CONTEXT

Largely, throughout the developed world, it is clear that residential energy usage accounts for a large share of total energy use, and of that, space heating and Domestic Hot Water Production (DHWP) account for the majority of final energy use. In the USA, Heating, Ventilation & Air Conditioning (HVAC) energy use is 50% of all building energy use and in China, HVAC energy use is between 50%–70% of building energy use [1]. It is estimated that by 2050, two thirds of all residential buildings will have a form of air conditioning unit, further increasing these percentage shares. Alone in 2021, space cooling demand rose by 6.5% [2]. In Europe in 2022, the residential sector was responsible for 27% of final energy consumption [3]. Domestic water heating and space heating collectively account for close to 80% of a household's energy usage in Europe. [4]. All of this is to say, energy use due to HVAC and DHWP are high and are expected to continue rising.

Climate change has directly affected heating and cooling design. ASHRAE highlight that for 1274 weather stations/observing sites worldwide with sound data between 1974 and 2006, the averaged design conditions (which are explained in Sec. 2.2) over all locations had changed by the following:

- The 99.6% annual dry-bulb temperature increased 1.52 °C
- The 0.4% annual dry-bulb increased 0.79 °C

Of course, it must be noted that air conditioning naturally rose sharply in no small part due to the COVID-19 pandemic and subsequent isolation rules in place in many parts of the world.

As of writing,
continental
Europe is
experiencing “the
most extreme
event ever seen in
European
climatology” with
a mid-winter
heatwave [6]

- Annual dew point increased by 0.55 °C
- Heating-degree days (base 18.3 °C) decreased by 237 °C d
- Cooling degree-days (base 10 °C) increased by 136 °C d

All of these changes the mentioned parameters point towards an increase in global temperatures. The effects of climate change are affecting how building cooling and heating design is carried out, due to the fact that cooling loads are, in general, becoming lower, while heating loads are generally increasing. Milder winters are allowing Heat Pumps (HPs) to be, ever so slightly more efficient throughout a heating season.

The so-called *electrification of heat* has been supported in the EU for some time now due to seeking carbon emissions reductions and also security of supply, which, due to events on-going as of the writing of this thesis, has indeed become more of an issue than previously thought...Electric heating devices such as HPs convert electricity into heat, creating the sought after link between building heating and the electrical grid [7]. However, this link will not come without growing pains, as more buildings rely on the electrical grid to provide electricity for heating, the electrical demand grows. Due to the nature of heating demand and weather/climate which generally affects large areas and subsequently a large number of houses simultaneously, the electrical grid would be of course put under large strain when a particularly cold spell of weather hits an area. These great peaks in energy demand are a problem when it comes to electrical grid deployment, as the real-time balancing of the grid becomes an increasingly difficult job with the large variability of renewable energy production methods such as wind. [8, 9] propose that Hybrid heating systems (HHSs) could alleviate these very high energy demands from heating systems, could they manage to intelligently switch to primarily gas operation during peak energy demand periods.

In Ireland, the housing stock increased by just 0.4% between 2011 to 2016 [10]. Very few new houses are being constructed with the possibility for newer, more efficient space heating and/or hot water production systems and better, holistic insulation. A similar sentiment has been noted in other Western European countries, making this not a localised issue, but rather an international one [11, 12]. Thus, in order to reduce Primary energy (PE) consumption in any meaningful way, retrofits must be carried out on existing buildings. This includes adding insulation to attic spaces and/or walls of the house and the installation of more efficient heating systems. An advantage of HHSs is that existing buildings presumably already have a heat generator, be it a gas boiler or otherwise, which can be easily integrated into a HHS with the addition of a HP. Of course, plumbing works must be carried out and the HP itself has a relatively high barrier to entry in the form of a high upfront cost. Currently the Ireland do not give grants for the installation of HPs as they do not deem them to be a renewable type of heat generator. This is partly true as HPs do use electricity to run, which, as discussed in Sec. 2.3, is generated mostly by non-renewable means in Ireland currently.

The transfer of heat from a low temperature region to high temperature region is not something that would happen through normal thermodynamic means, as heat can be thought of as flowing in the direction of decreasing temperature, when a temperature differential exists, of course. Rather, special devices called refrigerators can be used to achieve this. HPs (for heating purposes) and refrigerators are identical in architecture, differing only in objective. Refrigerators aim to cool an enclosed volume of air, typically a refrigerator or freezer, while a HP aims to heat an enclosed region, namely a residential home, in the case of this project. Refrigerators work utilising the refrigeration cycle, with the vapour-compression refrigeration cycle being the most commonly used cycle for refrigerators, HPs and air condi-

tioners. The reversed Carnot cycle is the most efficient form of a refrigeration cycle, and is only an idealised theoretical model, not practically achievable. HPs and air conditioners are composed of the same mechanical components [14], meaning one single system can be used for the cooling and heating of a home. This is achieved by adding a reversing valve to the hydronic circuit.

The performance of Air source heat pumps (ASHPs), or HPs in general, is very different to that of a traditional gas condensing boiler. The performance of a HP is almost entirely determined by the outdoor temperature and climatic conditions. The performance of a HP is described by the Coefficient of performance (COP) of the unit. This measure varies throughout a heating season, day and even from minute to minute. A HP with a COP of 3 for example, produces three units of heat energy for every unit of electricity supplied. This *extra* energy is being gathered from a renewable energy source — which in the case of Air-Water Heat Pumps (AWHPs) is the external air. The amount of non-renewable energy consumed by HP at any given time depends on the Renewable Energy Share (RES) of the grid. According to Ireland, Ireland's RES for electricity is around 9.3%. This figure is expected to increase in the coming years/decades as more wind turbines are installed, other renewable energy generators are built, the Celtic Interconnector subsea line between Ireland and France, and multiple non-renewable energy plants are decommissioned.

Since the COP of an ASHP varies quite drastically over a heating season, the measure Seasonal coefficient of performance (SCOP) is often used to describe the performance of a HP over a year or a heating season. The SCOP is an important tool for measuring the performance of heat pumps because it provides a standardised way to compare the efficiency of different systems. The measure of SCOP and Seasonal performance factor (SPF) are quite similar in that they are both a ratio of the total electrical energy input to

the total heat energy output of the HP, however, SCOP can also include other parts of the heating system

HPs have over recent years become more popular throughout Europe [15, 16].

There are three main types of HPs for space heating (i.e., not air-conditioning): AWHPs, Ground-Water Heat Pumps and Hydro-Water Heat Pumps [17, 18]. Ground-Water HPs acquire their heat energy by exploiting the heat contained within the Earth's soil. Soil, below a certain depth has a very consistent heat, only fluctuating mildly seasonally. The added benefit of this type is that soil below a certain depth will not freeze, which would cause frosting like in AWHPs. Hydro-Water HPs gain their heat from water sources such as ponds, lakes or well-water. The temperature of water fluctuates far less than the ambient air temperature, meaning they do not extract as much energy as AWHPs on warmer days, however, during warmer days, the heating load of a residential home is much less than the peak load. Conversely, during very cold days, the water remains much warmer than the air, which is very beneficial during those high-load spells. These two types of HPs, due to their heat sources, have their merits, however, it is also due to their heat sources that they are relatively obscure and not commonplace. Installing these types of HPs is costly, complicated, time consuming and require permits to build. Due to these reasons, AWHPs are the most common form of HP sold in Europe [15].

Frosting is detrimental to the performance of HPs [19]. During cold, humid weather, frost builds up on the evaporator coils on the outdoor component of the HP. Frosting dramatically lowers the heat conductivity between the coils and the ambient air, being essentially insulated by the frost. Frosting is a major concern in cool, humid climates, Ireland being one such climate.

A Hybrid Heat Pump System (HHPS) as opposed to monovalent systems, is a configuration of a HP in combination with a conventional gas boiler. During warmer days, the HP has sufficient heating capacity to provide all the energy needed to heat a space, while being very efficient, while on colder days, it may be not economical or ecological to run the HP. During these periods, the majority of the heating load is passed to the gas boiler, which is not affected by the ambient air temperature. A control system can be put in place to intelligently turn on and off the HP and gas boiler to better suit the current weather, for either economical or ecological reasons, or a weighted combination of the two. An alternative-parallel bivalent system is where the predefined external temperatures for turning on/off the HP/boiler are not coincident, as discussed in Subsubsec. 2.1.3.1. This creates a temperature range wherein the HP and boiler are running simultaneously. This is the focus of this thesis: where lies the optimal crossover points for boiler-only operation, bivalent operation and HP-only operation, specifically for the Irish climate. This research has been carried out for other climate types. The Irish climate is unique in that the temperature range (during the heating season) is quite narrow, the humidity is quite high almost all year round (especially on the west coast) and the temperature is quite mild.

1.2 AIM

The aim of this thesis is to first, give an overview of the current state of research regarding HPs and explain their operation including advantages, disadvantages, principle of operation and use cases.

1.3 MOTIVATION

The operation, control and performance of HHSs consisting of AWHPs and traditional gas boilers has been moderately studied in the literature. This type of heating system has been simulated and tested in-situ in countries such as China [20], Japan and Korea [21, 22], North America [23], Germany [11] and other continental European countries [12, 19, 24–26], however, the research regarding efficient control of such a system in the Irish climate, namely a temperate oceanic climate, has not (or at the least only partially) been explored [7]. Ireland has a very changeable and mild climate, but the characteristic of note is its consistently high humidity. Humidity and low temperatures are the bane of HP operation and efficiency.

1.4 THE PROBLEM

1.5 THESIS LAYOUT

Chap. 2 is a literature review of: the operation of HPs (including the different types) and HHSs; overview of PE; the electrification of heating in the EU; controllers and basic control theory; and ending with

LITERATURE REVIEW

2.1 HEAT PUMPS

HPs work by harnessing the energy from low temperature sources such as air, water or the ground. HPs of any kind acquire energy from its surrounding environment in the form of low-temperature heat and *concentrate* it to heat comparatively minute volumes to its surroundings. This is achieved through a vapour compression cycle, explained in Subsec. 2.1.1. Under ideal conditions, AWHPs have extremely high COPs in the 3.5 to 4.5 range. This is of course from their ability to harvest the aerothermal energy from the outside air. The main downfall of AWHPs is that when the external air temperature is low, their COP is reduced significantly. Due to this inherent disadvantage, HPs are essentially unfit to be the sole space heating generator for almost all applications, depending on climates and design points. While HPs have the capacity to perform heating and cooling, this thesis and associated simulations do not consider the cooling of a building or home, and therefore is only concerned with heating and considers only the heating-season time frame of the year. The space-heating radiators found in existing homes are not suitable for cooling [11], the cold water in the radiators does not warm the room effectively and condensation on the radiator surface may become an issue.

Because the efficiency of HPs is so dependent on the constantly varying outside air temperature, the measure of SPF is typically used to characterise them when considering the performance

over a certain heating period and is considered a more comprehensive metric to establish HP efficiency [16, 27]. The SPF represents the ratio of the total useful energy produced by the HP during a heating season, to the seasonal electricity consumption. For example, an SPF of 3 would mean that over a given year, the HP produced 3 units of heating energy for every unit of electrical energy provided [27]. Due to HPs extracting renewable energy from the surrounding air, the SPF is (or should be) always higher than 1, and generally is above 3. EU legislation states that in order to be eligible for the Renewable Heat Incentive (RHI), a HP's SPF must be above 2.5 [28].

HPs come in many different heat capacities, from single kilowatt units to extremely large units which can heat large multi storey office buildings. In residential home contexts, the largest HPs generally available are almost 300 kW, but usually fall in around the 5 kW to 20 kW range. If an ASHP were to be sized so large as to have the capacity to provide the entire heating envelope of a residential home during even the coldest expected temperatures, the ASHP would (aside from being prohibitively expensive), be so oversized that when temperatures are moderate, the HP would produce so much heat as to heat the space so quickly that it would have an extremely short on-off cycle [29]. Since the peak load for heating occurs for a very small number of hours during any given heating period, this would be very detrimental to the unit, specifically the condenser component. The frequent on-off cycling significantly reduces the longevity of the condenser, and would require replacement long before what would be expected [30]. Many manufacturers suggest that the number of on-off cycles should not exceed 6 per hour. To avoid this issue, AWHPs are specifically undersized. Various "design temperatures" can be calculated for a given location. For Dublin, the design temperature which covers 99.0% of the annual heating is -0.7°C . AWHPs are usually sized to meet a design

temperature of 60%–70%, as opposed to more traditional space heaters, as is further explained in [Sec. 2.2](#).

HPs tend to perform better when providing space heating through underfloor heating [27]. This is partly due to underfloor heating being more efficient in general than other, more traditional space heating methods, namely hot-water radiators. Another reason more applicable to HPs is that the (space heating) inlet water temperature for underfloor heating is much lower than radiators. This means the HP does not have to heat the circulating water as hot as it would with radiators. The temperature delta between water temperature inlet to the HP and the outlet is simply lower and therefore less energy has to be produced by the HP in the first place. However, retrofitting houses with underfloor heating is expensive and very intrusive to the building — as obviously (all) floors much be ripped up and coils must be placed and plumbed — which discourages many homeowners from performing this type of retrofit.

HPs for residential use are generally classified into two distinct product types: low-temperature and high-temperature, which refers to the flow temperature of the HP. Low-temperature HPs typically heat water to a maximum temperature of 55 °C

The flow temperature of a HP in a heating system plays a crucial role in the performance and efficiency of the system. It refers to the temperature of the fluid, typically water or refrigerant, as it flows through the HP's evaporator and condenser coils. A lower flow temperature in the evaporator coil allows the heat pump to absorb more heat from the source, increasing the energy provided to the in-pump loop which is passed to the condenser coils and subsequently the heat distribution/buffer tank loop [16]. The flow temperature is affected by the initial temperature of the refrigerant and also how much electrical energy is being provided to the compressor

The flow temperature also affects the overall temperature of the heating system, as it determines the temperature of the water or refrigerant that is circulated through the building's heating system. A higher flow temperature allows the heat pump to provide more heat to the building, making it warmer. However, a higher flow temperature also results in a lower COP (coefficient of performance) of the heat pump, meaning it is less energy efficient.

2.1.1 *Vapour-Compression Cycle*

The vapour-compression cycle is a process used in [HPs](#) and refrigeration systems to transfer heat from a low temperature heat source to a high temperature heat sink [[14](#)]. The cycle begins when a refrigerant, typically in a liquid state, is vaporised in an evaporator. As the refrigerant vaporises, it absorbs heat from the surrounding low temperature heat source, such as the air inside a refrigerator or the ground in a geothermal [HP](#).

Next, the vaporised refrigerant is pressurised and moves through a compressor. As the refrigerant is compressed, its temperature and pressure increase. The hot, high pressure refrigerant vapour is then passed through a condenser, where it releases heat to the surrounding high temperature heat sink, such as the air outside a refrigerator or the air inside a home in a [HP](#).

As the refrigerant gives up heat, it condenses back into a liquid. The liquid refrigerant is then passed through an expansion valve, where its pressure is reduced and it begins to evaporate once again. This reduction in pressure causes the refrigerant to absorb additional heat, which helps to further cool the low temperature heat source.

The refrigerant continues through the cycle, alternating between the evaporator, compressor, and condenser, until the desired

level of heat transfer is achieved. In a [HP](#), the cycle is reversed during the heating mode, transferring heat from the outside air to the inside of a home.

While the vapour-compression cycle is not identical to the Rankine cycle or the Carnot cycle, it shares some similarities and can be thought of as a practical implementation of these theoretical models.

The Rankine cycle is a thermodynamic cycle that describes the operation of a heat engine, such as a steam power plant [14]. The cycle consists of four processes: pressurisation, heating, expansion, and cooling. These processes are similar to those in the vapour-compression cycle, in which a working fluid (such as water or steam) is pressurised and heated, causing it to expand and generate work before being cooled and condensed back into a liquid.

Like the Rankine cycle, the Carnot cycle is a theoretical model of a heat engine that describes the maximum possible efficiency of a heat engine operating between two temperature reservoirs. The Carnot cycle consists of four reversible processes: isothermal expansion, adiabatic expansion, isothermal compression, and adiabatic compression. The efficiency of the Carnot cycle is determined by the temperature difference between the heat source and the heat sink, and it serves as a benchmark for the performance of real heat engines [14].

2.1.2 HHS

A bivalent, hybrid [HP](#) heating system consists of a [HP](#) of some description and an auxiliary or supplemental heating source [31]. The [HP](#) type this thesis focuses on is a [AWHP](#), and the auxiliary heating source is a conventional condensing gas boiler. The overarching idea behind this dual heating source system for a home

is: the (undersized) HP can provide heating to the home using electricity, rather than gas, as its energy input during milder periods of the heating season with minimal usage of the gas boiler, and during the more severe, colder periods of the season, the gas boiler can provide the majority of the heat required to keep the home at a comfortable temperature. AWHP performance is very weather dependent, as explained in Sec. 2.1, and during very cold, humid spells simply cannot provide enough heating capacity to maintain a comfortable temperature inside, unless it is wholly oversized, which has problems associated with it, described Sec. 2.1. Therefore, almost all of the literature agrees that an undersized HP with a “correctly” sized gas boiler is the most efficient system [12, 22–24]. Fig. 2.1 shows a schematic diagram of a HHS comprising of an AWHP, gas boiler, buffer tank, radiators, sensors, and controller. The blue line represents the “cold” water, which has just expelled its heat to the indoor rooms and is circulating back to the HP and gas boiler to be heated up again. This return water is typically in the range of 25 °C to 30 °C by the time it reaches the heating devices. The heating devices heat the water up a temperature in the range of 45 °C to 40 °C, where makes its way back to radiators to once again expel its stored heat to the indoor rooms, which for a comfortable temperature, are in the neighbourhood of 18 °C to 22 °C.

The controller of this system determines how much heat is being added to the circulating water by the two heating devices, the sum and also the share. During milder days, it is understandable that a lower quantity of heat is required to maintain the home at a comfortable temperature, while during colder days, more heating input is required. The AWHP can only run at full tilt, however, ideally, the controller can control the circulating water flowrate in such a way as to *step down* the heat output of the AWHP/gas boiler to create the ideal heat flux from the radiators into the air of the rooms to maintain an optimal indoor temperature.




Figure 2.1: HHS with an AWHP and condensing gas boiler [12]

Heinen, Burke and O'Malley [7] concluded that HHSs that use a combination of electricity and gas as the energy source for the heating system can provide the greatest economic benefits when compared to other types of hybrid heating technologies in a combined power-residential heat system. The investment costs of these systems may vary depending on factors such as the size of the system, the specific technology used, and the cost of electricity and gas in the area. However, overall, a HHS that utilises a combination of electricity and gas as the energy source is likely to have the most favourable cost-benefit ratio.

2.1.3 Operating Modes of HHSs

2.1.3.1 Bivalent-Parallel Operation

In this study, the bivalent-parallel operation paradigm for a HHS is used, which is where a controller determines whether to solely run the HP or conventional gas boiler, or so run them in parallel. Buday [32] explains: at temperatures below a certain threshold (T_{cutoff}), only the boiler is used, see: domain 1 in Fig. 2.2. Between (T_{cutoff}) and a second threshold (T_{biv}), both the boiler and HP are used (domain 2). At temperatures above (T_{biv}), only the HP is used (domain 3). The second threshold (T_{biv}) is the temperature at which the HP can meet the building's heat demand, and (T_{cutoff}) is set to a value such that, when ambient temperatures are above this value, the HP is ecologically and economically

In monovalent systems the entire heat demand, regardless of ambient temperature is supplied with the HP, but there is hardly any reason to operate in this mode and requires an oversized HP.

efficient. The optimisation of the bivalent temperature, T_{biv} , is the crux of this thesis. The cut-off temperature can be calculated using the boiler and HP efficiency and the Primary energy factors (PEFs) of the heat sources.




Figure 2.2: Bivalent-parallel operating scheme [11].

2.1.3.2 Bivalent-Alternative Operation

In bivalent-alternative operation, the controller has two options in contrast to the three outlined in Subsubsec. 2.1.3.1, either solely use the HP or solely use the gas boiler [32]. Below the set bivalent point, the heat demand is entirely provided by the auxiliary heating device, as see in Fig. 2.3. Above the bivalent temperature, the heat demand is entirely provided by the HP. This operation places the T_{biv} and T_{cutoff} coincident [11, 32].




Figure 2.3: Types of bivalent HHS operation modes visualised through heating duration curves [32]. Note: T_{cutoff} is not clearly shown in this figure.

2.1.4 *Buffer Tank*

A buffer tank is a medium- to large-sized water vessel used in hydronic heating systems. It provides a large thermal inertia to the heating system-house system, which many small- to medium-sized houses, especially those with poor insulation, lack. Thermal inertia is a desired property of a building as rapid thermal fluctuations in ambient air are less of a concern when it comes to maintaining a comfortable thermal environment indoors. This effect is noticeable in large office/district buildings with high thermal inertias and plays a significant role in heating-capacity selection [5]. Furthermore, a buffer tank provides a “hydraulic switch” and allows for heat generation and heat distribution to be in separate loops. This opens up the option to have differing flowrates between the heat generation and heat distribution loops.

Buffer tanks have been found, when sized correctly and with an appropriate control strategy, to have a positive influence on the efficiency and performance on HHSs [11, 25]. The controller is able to make use of the HPs “most profitable working conditions” thanks to the presence of the buffer [33]. It has been found that when a buffer tank is present in the HP circuit, SPF increases as the size of the HP decreases [34]. Mugnini, Coccia, Polonara and Arteconi [34] confirmed this for all sizes of HPs simulated, the smallest buffer tank having a capacity of 200 L. Stiebel Eltron GmbH & Co. KG [30] suggest to size the buffer tank so large as to at least be able to defrost the coils.

ASHPs can experience negative effects when operated at partial load, such as on-off cycle deterioration. This is caused by losses in the start-up and standby stages, where there is a delay in heating output and power consumption but no heat produced. To prevent these losses and excessive on-off cycles, a buffer tank can be installed in series with the heat pump, providing the hy-

draulic switch mentioned earlier [35]. In addition to protecting the heat pump from negative effects of partial load operation, the buffer tank also plays a role in maintaining indoor thermal comfort during reverse defrosting, as discussed in Subsec. 2.1.5.

The larger a buffer tank in volume, the larger its energy storage capacity. However, with a larger volume, and naturally larger cylinder and surface area, comes greater heat loss, which seem to correlate almost linearly [11]. This could be justified if other performance factors such as SPF or load factor were positively affected to offset this loss in heat, however this does not seem to be the case according to [25] and [11], which also found only a moderate reduction in on-off cycles with smaller tanks. This is partly to do with the thermal inertia of the building and return temperature controller. Klein, Huchtemann and Müller found that the volume of the buffer tank had very limited effect on the system performance. Dongellini, Naldi and Morini [12] sized their buffer tank just large enough such that the maximum number of on-off cycles was never greater than six per hour, resulting in a buffer tank with a volume of 79 L. This maximum on-off cycle figure was chosen based off their HP manufacturer guidelines. Daiken suggest [33]

2.1.5 *Frosting and Defrosting*

Frosting occurs in ASHPs in colder ambient temperatures resulting in issues for HPs. Frost build up depends on the ambient temperature, temperature of the surface in question and relative humidity. For HPs, a few ranges of temperatures at which frosting occurs has been found in the literature [36] finding a range of -15°C to 6°C at a r.h. of $\approx 90\%$, while [37] found frost formation to begin when the ambient air temperature was below 3.5°C with a r.h. of 88%. Frosting specifically occurs when the surface temperature of the fins on the air-side heat exchanger

component (evaporator) are lower than the dew point of the air. Water droplets start to form and collect on the fins. When the temperature is below freezing or close to it, the water droplets freeze to the fins and build up a frosting. Frost, unlike snow, which both form from the freezing of water droplets, is not loose and must be scraped off or melted off. It will not *fall off* of a surface like snow might. This layer of frost acts as a layer of insulation and restricts the heat exchanger from transferring heat from the ambient air. Since these fins are typically closely packed, if the layering of frost continues and progressively builds up, the airflow around the fins decreases and so does convective heat transfer to the ambient air, further exacerbating the issue of insulation. All of this is to say that when frosting occurs in ASHPs, their performance declines severely. [38] found that the temperature of the air and surface of the fins, humidity, velocity of air are the main factors involved in frost formation.

Many treatments for frosting have been proposed and implemented into products. There is however no golden bullet solution, all of their advantages and disadvantages. Three main solutions are typically used when addressing the issue of frosting in ASHPs.

- Simple on-off defrosting: the HP is simply switched off when too much frost has formed on the outdoor component. The performance has been degraded to such a point that it is now economically advantageous to turn off the HP and wait for the frost to melt away. This however, takes a long time and can negatively affect the thermal comfort of a home if no other heat production is used. The HP does not use any power during this off-cycle of course, retaining the COP of the HP— although, this may affect the overall system performance if a gas boiler needs to be used to provide the entire heating load of the home.
- Reverse cycle defrosting: this method is similar to the first method; the refrigerant is cycled in reverse and hot gas

is forced into the heat exchanger. Recall that HPs and refrigerators differ only in objective. The HP now treats the outdoors as the “cold” sink and begins transferring heat from indoors to outdoors. Intuitively, one can see that this is quite detrimental to the SPF of the HP as the house is being actively cooled by the HP in order to heat up the outdoor coils and fins to melt away the frost, which in turn causes the auxiliary heater to work even harder to maintain a comfortable indoor temperature. The intention in this method is to melt the frost much quicker than the first method, allowing the ASHP to begin warming the home once again much earlier than the simple on-off defrosting method.

- Resistive heating: electric resistive heaters are installed on/in the heat exchanger. This method works very well, quickly melting off frost and is a separate heating element to the HP and therefore does not interrupt the HPs cycles. Resistive heaters are very expensive to run and negatively affect the COP of the HP.

[39] found that the reverse cycling method resulted in a higher average COP than the other two methods, over a series of multiple reverse cycle defrostings. Additionally, [24] found that a buffer tank can ensure thermal comfort during reverse cycle defrosting, due to being able to use the stored energy from the buffer tank to melt the frost on the outdoor coils without actively cooling the indoor space due to the inherent decoupling of the heat production and distribution loops created by the buffer tank. [24] agreed with [40] that the *defrosting efficiency* of the reverse cycling method is around 60%. This is the ratio of energy supplied to the coils to the actual energy transferred to the frost for melting.

2.2 HHDS AND DESIGN TEMPERATURES

Heating degree dayss (HDDs) is a measure of the difference between the outside temperature and the inside temperature. HDDs are usually considered over a period of time, be it a month, heating season or entire year. A *base* temperature is chosen, typically around 12 °C to 21 °C which then determines when it is “cold” outside, or can be thought of as being the temperature above which heating is no longer considered to require heating. This base temperature can be chosen at will, and simply depends on what the person/institution deems to be *warm enough*. This measure can be used to quantitatively compare the heating demand of a given house in different locations/climates. The heating requirement of a specific building is directly proportional to the HDD [41].

To calculate the HDD for a certain day, three equations are used and are displayed from Eq. 2.1. Which equation to use is determined by the interaction between the base temperature and the maximum temperature recorded during that day.

$$\text{Degree days} = \begin{cases} t_{\text{base}} - \frac{1}{2}(t_{\text{max}} + t_{\text{min}}), & \text{if } t_{\text{max}} < t_{\text{base}} \\ \frac{1}{2}(t_{\text{base}} - t_{\text{min}}) - \frac{1}{4}(t_{\text{max}} - t_{\text{base}}), & \text{if } t_{\text{base}} > \frac{1}{2}(t_{\text{max}} + t_{\text{min}}) \\ \frac{1}{4}(t_{\text{base}} - t_{\text{min}}), & \text{if } t_{\text{base}} < \frac{1}{2}(t_{\text{max}} + t_{\text{min}}) \end{cases} \quad (2.1)$$

To calculate the Monthly degree days however, only the first of the three equations in Eq. 2.1 is made use of. This total is found by summing the daily temperatures differences and can be seen in Eq. 2.2.

$$\text{Monthly degree days} = \sum_{\text{month}} \left[t_{\text{base}} - \frac{1}{2}(t_{\text{max}} + t_{\text{min}}) \right] \quad (2.2)$$

Environmental Design: CIBSE Guide A. has chosen a base temperature of 15.5 °C. 2009 *ASHRAE Handbook: Fundamentals* used a base temperature of 18.3 °C and determined an annual HDD of 3135 °C d for Dublin Airport, IE, N53°26' W6°15'. Using the online tool Degree Days.Net [42] with a base temperature of 15.5 °C, a HDD figure of 2072.3 °C d was obtained for the same location.

Design temperatures are a measure how many hours/days a specified condition is exceeded. In the case of a heating design temperature, this would indicate how many days of the year or heating season are spent below a given temperature. 2009 *ASHRAE Handbook: Fundamentals* notes that this measure does not give an indication of the frequency or duration of these events, only a cumulative result is returned. According to 2009 *ASHRAE Handbook: Fundamentals*, the 99.6% design temperature in Dublin Airport is −1.9 °C while the 99.0% design temperature is −0.7 °C. Traditionally, conventional gas boilers or resistive heaters were sized to design temperatures, meaning, for a chosen design temperature percentile (e.g., 99.0%), the heater could heat the building to thermally comfortable levels for 99% of the year, however during the 1% temperature lows, the heater would not be adequate. This calculates to the heater being undersized for ~35 hours of the year.

$$\begin{aligned} 365 \times 24 &= \\ 8860 \text{ h} &\Rightarrow \\ 99.0\text{-ile} &= \\ 8760(100 - \\ 99.0) &= 87.6 \text{ h} \end{aligned}$$

In monovalent systems, the HP is sized in such a way as to be able to provided the entire heating load for a building at design conditions. This results in the HP being positively over-dimensioned for the task [11]. An oversized heating system would be very inefficient due to frequent on-off cycling, which also results in rapid degradation of heating system components. Oversized heating systems also result in potentially uncomfortable indoor temperatures as rooms are unequally heated. Finally, oversized systems have higher maintenance costs and significantly higher initial investment costs.

The concept of a *design-day* can be used to design heating configurations for homes, especially when performing numerical simulations on a model of the system [23]. A design-day file is a special weather file created with design conditions in mind. Based on the design temperature parameter, ASHRAE lays out a procedure to generate a 24-hour weather profile. These profiles represent the 0.4% to 99.6% extremes experienced for a particular location [5]. This weather data is used in simulations to determine the minimum size for a heater required for a house (for these particular percentiles of course).

The “heating duration curve” can be devised for a specific climate and a specific HP where a curve is plotted on a chart with heating load [kW h^{-1}] against number of hours the heating load is equal to or above a selected percentage of design load. For example, as illustrated in Fig. 2.4, the blue line indicates 50% design load, and lands around 1300 hours on the x-axis. This means that for 1300 hours of the year/heating season, the heating load of the building is 50% of the design (or max) load. The balance point marked by the yellow circle is the point at which the HP is not longer able to provide the entire heating load required by the building. To the left of this point, the gas boiler will need to provide the remaining heat capacity to maintain a comfortable indoor temperature. If the AWHP size is increased, this balance point moves to the left, as the HP can provide the entire heating envelope of the building at lower temperatures. Of course, for the sake of the diagram, the curves and lines in this figure are arbitrary (e.g., AWHP performance is not linear with outdoor temperature, and by proxy, heating load), but it illustrates how a HP may be sized to 60% of the design load of a building.

All of this is to say that there are many methods of determining and comparing the heating load of a building for a given climate, with which heating devices may be sized to in order to be able

for the purposes of the simulation(s) concerning this thesis, the 0.4 percentile, and any cooling-nessecary-temperatures for that matter, are not of concern as cooling is out of scope.




Figure 2.4: Heating Duration Curve

to (almost always) have the capacity to heat a building. A [HHS](#) is unique in that it is composed of two heating devices. The boiler, as stated before, is sized to a certain high-percentage design condition. This may be defined by the user/homeowner, convention, or by some set of standards set by a governing body (e.g., ASHRAE), and is typically a value in the region of 95% to 99.7%. On account of this, the [AWHP](#) can be sized smaller than compared to if it were the sole heating device.

2.3 PRIMARY ENERGY

[PE](#) is a term used in the fields of energy statistics and energetics. Sources of [PE](#) are those which have not been interfered with by humans, in other words, are the natural form of energy and are unprocessed. [PE](#) sources include: oil, natural gas, sunlight, wind, etc. [PE](#) stands in contrast to secondary energy, which can be thought of as the carrier of energy, which most commonly

happens to be electricity, but can also be liquid forms of energy (e.g., diesel/petrol,), hydrogen fuel cells or (waste) heat. Following from PE, is PEF which connects PE to final energy, it is a measure of how much energy in total is required to produce a unit of *usable* energy [16]. The PEF is used to evaluate the environmental impact of a system by considering the primary energy consumption, which includes the energy required to produce and distribute the energy source, such as the energy used to extract and transport fossil fuels. For example, a hydroelectric power plant with a PEF of 1, means that the energy used to generate electricity is equal to the energy consumed. On the other hand, a coal-fired power plant with a PEF of 2.5, means that 2.5 units of PE are consumed to generate 1 unit of electricity. Therefore, hydroelectric power plants are considered more environmentally friendly than coal-fired power plants. [43] found that with a suitably high diffusion of RES in an electrical grid, significant Primary energy savings (PES) can be obtained through the use of HPs for space heating and can overall promote energy savings in buildings, in turn reducing CO₂ emissions [16].

Fig. 2.5 is a sankey diagram which breaks down the flow of energy in Ireland in 2020 from PE on the left by fuel type, and final energy on the left, by sector. It also highlights the energy losses associated with energy production and transmission. It requires energy to convert natural gas or oil to electricity, while energy losses corresponding to renewable energy production are dismissed, as the energy source is of course *free*.

PES is difference between the amount of energy consumed by the original device (whatever it may be) and the amount of energy consumed by the new device. In relation to this thesis, it will be taken to be the savings of the new heat generation system compared to the old system (conventional gas boiler as sole heat production). Knowledge of the PEF, PES and the make-up of the fuel types and shares in the PE, i.e., the RES, can indicate how




Figure 2.5: Sankey diagram showing PE by fuel type on left and final energy by sector on right [44].

much CO₂ is consumed at any instance with a heating system [43], and is the foundation of the techno-ecological model of this thesis.

The RES of an electrical grid refers to the proportion of electricity generated from renewable energy sources, such as solar, wind, hydro, geothermal, and biomass, compared to the total electricity generation. It is a measure of how much of the electricity being consumed by a country or region is coming from renewable sources. For example, if an electrical grid generates 50 GW of electricity and 20 GW of it is generated from renewable sources, the RES of that grid is said to be 40%.

The RES is an important metric to measure the progress towards decarbonization and the reduction of greenhouse gas emissions in the energy sector. Governments and international organisations have set targets for the increasing share of renewable energy in the electricity mix as a means of reducing the dependence on fossil fuels and reducing the emissions of greenhouse gases. Knowing the RES of an electrical grid can also help understand the potential for further integration of renewable energy sources and the necessary investments in infrastructure and technology to achieve the goals set by the government or international organizations. In addition, the RES of an electrical grid can also

impact the stability of the grid and the integration costs, it is important for grid operators and policy makers to consider this metric when planning for future energy systems.

2.4 ELECTRIFICATION OF HEATING

The EU has now for a number of years been pushing for the electrification of heating throughout the union. This has been identified as a clear means to achieve decarbonisation goals, as concerns over global warming become greater. As noted in [Sec. 1.1](#), the residential sector contributes 27% of the final energy consumption, while residential domestic water production and space heating contributes to 80% of that. In Ireland, residential heating accounted for 53% of CO₂ emissions from heating. However, across all sectors, heating and cooling are responsible for half of all final energy consumption in the EU [\[45\]](#). Therefore, it is clearly evident that decarbonisation of the heating/cooling sector is vital to a) reaching EU targets of lowering CO₂ emissions and b) improving air quality and the reduction of harmful emissions [\[46\]](#). Although, switching to electrically driven heating systems does not automatically or inherently reduce the carbon emissions, merely, it changes the source of the energy; the electricity must also be decarbonised for this to be the case.

SEAI [\[44\]](#) carried out a comprehensive study on the Irish electrical grid performance as it relates to renewable energy sources and to heating/cooling. According to the report: the share renewable energy to that of the the total energy used in 2020 was 13.5% (having missed the EU target of 16%); the share of renewable energy used specifically in heating/cooling was just 6.3%, its target having been 12%; energy from renewable sources grew by 8.9% over the previous year, and the total installed wind energy capacity grew by 4.1%, from 4130 MW to 4310 MW (in the Republic). Overall, the residential energy CO₂ emission has

Emission intensity is a measure of how much CO₂ is released per unit of energy produced

trending downwards over the past decade and a half, falling by 25% since 2005, and the CO₂ intensity of electricity generation is half of its value in 2005, standing at 300 gCO₂/kWh. These are good signs for the electrification of heating, because in order for the electrification of heating to result in a decarbonising of heating, the electricity production must at least have a lower emission intensity compared to if no electrification process were to take place, but ideally have the prospects of becoming a very low/zero CO₂ intensity matter.

2.5 CONTROLLERS AND CONTROL THEORY

Control theory is concerned with the control of dynamic systems with with a desired goal in mind, which is called the reference. A controller manipulates the inputs to a system, usually denoted u , in such a way as to alter the output variables or states, y , of the system to follow a given reference. Disturbances, d , to a system are expected, yet unforeseen inputs to a system which may significantly alter the outputs state. There are two main types of controller, feed-forward, and feedback controllers [47].

However, they would they no longer qualify as disturbances, and would simply be considered as inputs, but that is by the by.

A feed-forward controller, also known as an open loop controller, controls the system without knowing the current state of the system. This is possible if disturbances are either eliminated, or wholly understood and accounted for. Complete knowledge of the dynamics of the system being controlled would be required and captured by a mathematical model, either by physics and first principles, or by system identification (a model is fitted to data). The dynamics of the system are inverted by the controller and fed to the system as inputs. Any error in the inversion process results in undesired system states.

Feedback controllers, also known as closed loop controllers are a *much* more common form of controller. The current system state is known to the controller, and the reference and current state

information is used to determine the appropriate control inputs. In doing so, a feedback controller inherently changes the dynamics of a system. Feedback controllers usually make systems more stable, however, there is the possibility of making systems less stable and even unstable through controllers Franklin2014. There are many types of feedback controllers, the most common and well understood kind being a linear feedback controller called a Proportional-integral-derivative (PID) controller, or just a PID. Linear controllers assume the general behaviours of the system to be linear. Although, even if the dynamics of system are not, in fact, linear, a PID will still likely be able to control the system appropriately and reach the reference state [48].

In a HHS, controllers are used to manage the operation of the different heating technologies and ensure that they are used in the most efficient and effective way possible [19, 24, 25, 34, 43, 49]. The controllers in a HHS are typically responsible for a number of tasks, including monitoring the temperature inside and outside the building, determining the best heating technology to use based on the current conditions, and controlling the operation of the heating technologies to maintain a comfortable and consistent temperature.

For example, when the outside temperature is cold, the controller may determine that it is most efficient to use the gas furnace to heat the building. When the outside temperature is mild, the controller may determine that it is more efficient to use the HP, which uses less energy than the gas furnace. Very advanced controllers may also use predictive algorithms and weather forecasts to anticipate changes in temperature and adjust the heating system accordingly by storing a lot of heat in the buffer tank during a warm period right before a cold period [49].

2.5.1 *PID Controllers*

PID controllers are a type of feedback control system that are commonly used in a wide variety of systems to maintain a desired output or setpoint. The acronym refers to the three components of the control algorithm used by the controller. **PID** controllers work by continuously calculating an error value that represents the difference between the desired setpoint and the current output of the system. Panda and Sujath [48] explains that this error value is then used to calculate and apply a correction to the system, based on the three components of the **PID** algorithm:

- The proportional component applies a correction proportional to the error value. This allows the controller to quickly respond to large errors and make large corrections.
- The integral component applies a correction based on the accumulated error over time. This helps to eliminate steady-state errors and ensure that the system eventually reaches the desired setpoint.
- The derivative component applies a correction based on the rate of change of the error. This helps to dampen the system's response and prevent overshoot and oscillation.

PID controllers are used in a wide variety of systems, including mechanical systems like motors and actuators, temperature control systems, and chemical process control systems. They are often preferred over other control algorithms because they are relatively simple to implement and can provide stable and accurate control of the system's output.

2.5.2 *Noise and Error*

Noise and error are common sources of problems in control systems. Noise refers to random variations in the system's output

that are not caused by the control signal, while error refers to the difference between the desired setpoint and the actual output of the system. Noise and error can have a number of adverse effects on the performance of a control system, including reduced accuracy and stability, as well as increased oscillation and overshoot. To deal with noise and error in control systems, a number of different approaches can be used. One approach is to use a filter to remove noise from the system's output signal. This can be done using a low-pass filter, which removes high-frequency noise, or a high-pass filter, which removes low-frequency noise. Another approach is to use a model-based control algorithm, which uses a mathematical model of the system to predict the system's output and apply appropriate control signals. This can help to reduce the effects of noise and error by using the model to compensate for them. Furthermore, another approach is to use a robust control algorithm, which is designed to be resistant to the effects of noise and error. Robust control algorithms typically use a combination of feedback and feed-forward control, as well as advanced control techniques like gain scheduling and optimization, to achieve robust performance in the presence of noise and error.

2.6 VERIFICATION & VALIDATION OF MODEL

Verification and validation are two important processes that are used to assess the credibility and reliability of a simulation model. While these terms are often used interchangeably in common parlance, they have distinct meanings and serve different purposes.

Verification is the process of ensuring that a simulation model is implemented correctly and accurately represents the underlying mathematical equations, assumptions, and physical phenomena. Verification ensures that the simulation code is free from coding

errors and that the numerical algorithms are implemented correctly, and confirms whether the model behaves as the modeller expects. This process involves checking the model against analytical solutions or known results and comparing the simulation output with the expected results.

Validation, on the other hand, is the process of determining whether a simulation model accurately represents the real-world system it is intended to simulate. Validation involves comparing the model output to real-world observations and data to assess the model's accuracy in predicting system behaviour. This process also involves assessing the model's sensitivity to input parameters and assumptions. The model's underlying values (e.g., insulation thickness, floor tile conductivity, etc.) are altered and calibrated to fit the real-world data.

Building Energy Models (BEMs) must undergo verification and validation due to various sources of uncertainty arising naturally as a result of converting a real-life problem to a mathematical model to a numerical model. Four sources of uncertainty particular to BEMs are identified by [50, 51] as:

- Specification uncertainty arises from incomplete or inaccurate specifications of the building or systems being modelled.
- Modelling uncertainty results from simplifications and assumptions of complex physical processes.
- Numerical uncertainty is introduced during the discretisation and simulation of the model.
- Scenario uncertainty comes from external conditions imposed on the building, such as outdoor climate conditions and occupant behaviour.

2.6.1 *Verification*

2.6.2 *Validation*

The validation process of a BEM is a crucial step in ensuring that the model accurately predicts the energy performance of the building. Calibrating a building involves adjusting the energy model to better reflect reality [50, 52]. This is done by comparing measured data to simulated data, and performing an uncertainty analysis to determine how well they match. Although real and measured data can be similar, there may still be errors in the simulation [53]. Various factors, such as weather [54] or occupancy, can introduce uncertainty, along with envelope uncertainties. The ‘ASHRAE Guideline 14-2014’ [53] provides a comprehensive framework for validating BEMs. This guideline outlines a step-by-step process for validating the simulation model and includes criteria for evaluating the accuracy of the model. The validation process involves comparing the model results with actual building energy consumption data and performing statistical analysis to determine the level of accuracy. In the validation process used in this thesis, three statistical tools or indices are employed to evaluate the accuracy of the simulation model in this thesis. The first two are suggested by ASHRAE while the last is used as its properties are distinct from the first two and provides a useful measure of absolute error.

Coefficient of Variation of Root Mean Square Error (CV(RMSE)) is a statistical tool used to determine the degree of error between the simulated and actual data and is a commonly used tool in the validation process of BEMs because it takes into account the variability in the actual data. It calculates the Root mean square error (RMSE) as a percentage of the mean of the actual data, which makes it a useful metric for evaluating the model’s accuracy across a range of operating conditions. A lower CV(RMSE)

value indicates that the model is a better predictor of the actual building energy performance. The [CV\(RMSE\)](#) tool is particularly useful when comparing the performance of different models or when assessing the impact of different input parameters on the model's accuracy. Coakley, Raftery and Keane [50] said: "[[CV\(RMSE\)](#)] allows one to determine how well a model fits the data by capturing offsetting errors between measured and simulated data. It does not suffer from the cancellation effect.". The formula for [CV\(RMSE\)](#) is given by [Eq. 2.3](#).

$$\text{CV(RMSE)} = \frac{100}{\bar{Y}} \sqrt{\frac{\sum_{i=1}^N (Y_i - \hat{Y}_i)^2}{N - p}} = \frac{\text{RMSE}}{\bar{Y}} \quad (2.3)$$

Normalized mean bias error ([NMBE](#)) is another statistical tool used in the validation process, measuring the bias of the model. It provides a measure of the difference between the mean of the simulated and actual data as a percentage of the actual data. A zero [NMBE](#) value indicates that the model is unbiased, while a positive or negative [NMBE](#) value indicates overestimation or underestimation, respectively. The [NMBE](#) tool is useful in identifying systematic errors in the model, which can occur due to incorrect model assumptions, data input errors, or other issues. It helps to identify the direction and magnitude of the bias, which is important for developing strategies to improve the model's accuracy. The formula for [NMBE](#) is given by [Eq. 2.4](#).

$$\text{NMBE} = \frac{100}{\bar{Y}} \frac{\sum_{i=1}^N (Y_i - \hat{Y}_i)}{N - p} \quad (2.4)$$

Symmetrical mean absolute percentage error ([SMAPE](#)), first proposed by Makridakis [55] and approved by many [56–58], is a statistical tool that measures the absolute percentage difference between the simulated and actual data. Unlike the previous two tools, [SMAPE](#) is symmetric and thus gives equal weight to

overestimation and underestimation. A lower SMAPE value indicates higher model accuracy. It is an extension of the MAPE method which has the flaw of being asymmetric in its treatment of over- and underprediction of the actual value, overpredictions being penalised harder than underpredictions. There are three common definitions of SMAPE, each with different properties, however, this thesis chooses to use the definition which outputs values as a percentage error between 0% and 100% as this is most easily interpretable and comparable. The formula for SMAPE is given by Eq. 2.5.

$$\text{SMAPE} = \frac{100}{N} \sum_{i=1}^N \frac{|Y_i - \hat{Y}_i|}{|\hat{Y}_i| + |Y_i|} \quad (2.5)$$

‘ASHRAE Guideline 14-2014’ [53] suggest different tolerances for data calibrated by monthly or by hourly data for the CV(RMSE) and NMBE statistical methods. The experimental data was collected by monthly intervals. ASHRAE suggests tolerances of <15% for CV(RMSE) and $\pm 5\%$ for NMBE. A simulation is said have high levels of model prediction performance if absolute percentage error values outputted by SMAPE are less than 20% and great levels if less than 10%.

2.7 CONCLUSION

In this literature review, the fundamental concepts behind the operating principles of HPs was described, the dynamics of HHSs were described, the effects of the different operating modes and physical phenomena were detailed, and Heating-system design was studied. The reasoning behind (future and current) policies pushing for HP adoption were explained along with the basics of control theory were. Finally, the verification and validation of numerical simulation models was discussed along with the statistical models to be used later on in the thesis. The literature

surrounding HHSs and HPs is vast, however, perhaps the most succinct—and perhaps discouraging—statement/expression in the literature is: “numerical findings are generally idiosyncratic to geographical contexts, time horizons as well as assumptions on costs, policies, and technology availability” [59]... Rauschkolb, Modi and Culligan [23] explain how small variations in the price of natural gas can shift fossil fuel-only systems from being the best economic choice to the worst.

Part II

MODEL AND RESULTS

METHODOLOGY

This chapter presents the research methodologies employed in this thesis. [Sec. 3.1](#) gives a general overview of the study, including a flow chart of the main steps. [Sec. 3.2](#) and [Subsec. 3.3.2](#) give an overview of the reference building being modelled and the implemented heating system respectively. [Sec. 3.5](#) gives an introduction to the ecological and economic models used to quantify the different hybrid operation temperature windows along with a brief overview of the market context. Finally [Sec. 3.6](#) provides a conclusion to the methodologies chapter.

3.1 OVERVIEW

3.2 EXPERIMENTAL REFERENCE BUILDING

In September 2014 a Daikin Altherma hybrid [HP](#) system was installed. The dwelling underwent a minimal retrofitting between December 2014 and February 2015. The insulation and air tightness of the building were improved. Low temperature optimised aluminium radiators were fitted which allow for lower temperature supply water to effectively heat a room, ultimately allowing for higher [COPs](#) from the [HP](#). The improved thermal properties of the building resulted in a reduction of 475 watts per month in the heating load of the house. The average energy consumption decreased by 44.5%. All comparisons between the model and the reference house will be carried out post-minimal retrofit as it is generally not recommended to run a [HP](#) in poorly insulated/inefficient homes.

3.2.1 *Experimental Measurements*

Experimental measurements were carried out on the real-life dwelling pre-, during, and post-retrofit. Many data variables were logged, the main ones which this analysis is concerned with being: heating circuit water supply temperature and return temperature in celsius, volumetric flowrate of the heating circuit in cubic metres per hour, electricity power for HP in watts, outdoor temperature in celsius and gas volume in cubic metres. The data was collected on at ten-minute intervals, but reduced to hourly resolution for the purposes of the data analytics. These measurements are used in the verification process in [Subsub-sec. 3.3.2.1](#).

3.3 BUILDING AND HEATING SYSTEM MODELS

3.3.1 *Verification*

For the purposes of model verification, a series of small simulation runs were carried out to test whether the model was behaving as expected. It was noted during the early runs of the simulation, the air in zone3_floor1 was dramatically increasing in temperature during a certain day in early January. It was discovered that this was due to relatively high levels of direct and horizontal solar irradiation entering the room through the large, southerly facing window. The first verification test consists of loosely quantifying the solar irradiation energy gain into the room with the existing window from the model, and comparing this to a simulation run where the window was purposely shrunk to circa one tenth of its original area.

The ubiquitous heat capacity equation was utilised in quantifying the irradiation gain:

$$Q = mc\Delta T \quad (3.1)$$

Where Q is the heat energy in watts, m is the mass of air in the room, c is the specific heat capacity of air ($C_{v_{\text{air}}} = 0.718 \text{ kJ kg}^{-1} \text{ K}^{-1}$) and ΔT is the change in temperature of the air in the room (i.e., difference between temperature at a chosen time in hours leading up to the event, and the peak temperature after the bulk of the simulation day's irradiation). The mass of air in this room was found by taking the volume (31 m^3) and multiplying it by the density of air at a mean temperature ($\sim 1.204 \text{ kg m}^{-3}$). The heat gained by the room with the large window was found to be 420 J while with the small window it was found to be 420 J. This is to be expected as a larger window would justly allow more irradiance to (semi-)directly into the room.

The next test was to check if heat was being conducted through the interior walls of the building. A room was chosen, and its temperature was purposely raised to an unnatural level of 60°C . One would expect that the temperature of the adjacent rooms would increase by means of conduction.¹ The test involved comparing the adjacent room temperatures to the corresponding room temperatures in the case where the chosen room's temperature was not artificially raised. The temperature was found to increase an average of 6°C across the 4 neighbouring rooms.

¹ Door and window openings were not modelled as part of this simulation. The air infiltration rate was increased slightly to compensate for this. However, this also means interzonal airflow was also not modelled.

3.3.2 *HHS Model*

3.3.2.1 *Validation*

The validation of the [BEM](#) was performed by comparing value obtained from the simulation with the experimental data collected from the building described in ???. Two validation steps were carried out for the building. First, from the heating circuit water flowrate and temperature differentials it is possible to determine the nigh-ideal heating load of the building. The simulated heating loads were obtained by running a year long simulation of the [BEM](#) and using an idealised heat source to maintain the temperature of the rooms at 21 °C at all times. Secondly, an energy consumption comparison was carried out, comparing the electricity and gas consumption of the simulation and the experimental values separately.

The validation criteria used to assess the accuracy of the model were based on ‘ASHRAE Guideline 14-2014’ [53], using the three statistical indices explained in [Subsubsec. 3.3.2.1](#), these indicators measure the deviation between simulated and measured values, as well as the direction and magnitude of the bias. A monthly calibration approach was adopted, meaning the [CV\(RMSE\)](#), [NMBE](#) and [SMAPE](#) values were calculated for each month using [Eqs. 2.3](#) to [2.5](#) respectively.

The [CV\(RMSE\)](#) achieved was 9.483%, which is under the ASHRAE suggested 15.0% for monthly data comparisons. The [NMBE](#) was calculated to be 0.02242, well under the suggested 5% threshold, meaning the model did not systematically over- or underpredict the space heating load. The [SMAPE](#) value came to 6.061%, which is under the generally accepted 10% threshold for very good predictions. [Fig. 3.1](#) shows a clustered bar chart comparing the simulation and experimental space heating values for all heating months.




Figure 3.1: Space heating load for dwelling: experimental vs. simulation

3.4 SENSITIVITY ANALYSIS

3.5 ECO-ECONOMIC ASSESSMENT

3.6 CONCLUSION

SYSTEM MODEL

The purpose of models is not to fit the data, but to sharpen the question

— Samuel Karlin

4.1 LOCATION

The reference house that the building model is based off of a hipped dormer, two-storey residential house located in Belturbet, Cavan, a small town close to the Republic of Ireland and Northern Ireland border, about 125 kilometres from Dublin. The reference house lies at an elevation of 80 metres and is Easterly facing. The dwelling is located in a residential estate, and is thus classified as being located in an urban environment.

4.2 FORM AND FABRIC

The reference model has a floor area of 160 square metres, 93 square metres of which are downstairs, i.e., “exterior floor”, a gross roof area of 173 square metres and a total external wall surface area of 139 square metres. There are 21 exterior windows of varying sizes in total and thirteen rooms, seven downstairs and six upstairs. The ceiling height is a uniform 2.5 metres throughout the model. All rooms except for one were considered to be unconditioned, the exception being a very small box room on the ground floor which was interpreted to be a utility room of sorts. The void zones were also unconditioned. The building model geometry and thermal properties were created during

previous works by Keogh, Saffari, De Rosa and Finn. A floor plan schematic can be seen in Fig. 4.1, showing the ground floor and first floor room layouts and windows. A 3D rendered model of the house can be seen in Fig. 4.2. All model data is contained in a .idf file, an input data file interpretable by EnergyPlus. This file contains data about the geometry of the building, envelope construction, thermal and physical properties of the constructions, building and occupancy schedules, internal gains, outside air infiltration to void zones and various other data regarding the simulation process e.g., timestep.




Figure 4.1: Dwelling Floor Plan




Figure 4.2: 3D Model of Reference Building, rendered in SketchUp via the Euclid plugin

Table 4.1: Summary of U-Values

Building Model	U-Value [W/m ² -K]				Infiltration Rate [ACH]
	Exterior Wall	Pitched Roof	Exterior Floor	Exterior Glazing	
Minimal Retrofit	0.31	0.16	0.25	2.15	0.8
Deep Retrofit	0.18	0.16	0.18	1.39	0.5

4.2.1 Thermal Properties of Constructions

4.2.1.1 Minimal Retrofit Model

[Tbl. 4.2](#) details the specifications of the exterior wall construction for the minimal retrofit model, from outside to inside.

Table 4.2: Exterior Wall Construction

Layer	Thickness [m]	Density [kg m ⁻³]	Heat Capacity [J kg ⁻¹ K ⁻¹]	Conductivity [W m ⁻¹ K ⁻¹]
Rainscreen	0.01	7824	500	30
Insulation	0.085	43	1210	0.03
Air Cavity	0.15	—	—	—
Gypsum board	0.019	800	1090	0.16

[Tbl. 4.3](#) details the specifications of the exterior floor construction for the minimal retrofit model, from top to bottom. The exterior floor is the floor which lays on top of the foundations and therefore conducts heat from the inside of the house to the ground. It consists of concrete at the bottom, insulation board, an air cavity and floor tiles on top.

[Tbl. 4.4](#) details the specifications of the pitched roof construction for the minimal retrofit model, from outside to inside. This

Table 4.3: Exterior Floor Construction

Layer	Thickness [m]	Density [kg m ⁻³]	Heat Capacity [J kg ⁻¹ K ⁻¹]	Conductivity [W m ⁻¹ K ⁻¹]
Acoustic Tile	0.0191	368	590	0.06
Air Cavity	0.15	—	—	—
Insulation	0.085	43	1210	0.03
Concrete	0.1016	1280	840	0.53

construction is applied to the bulk of the roof and consists of clay tile, an air cavity, insulation board and then plasterboard. This construction remains the same across the minimal retrofit and deep retrofit models.

Table 4.4: Pitched Roof Construction

Layer	Thickness [m]	Density [kg m ⁻³]	Heat Capacity [J kg ⁻¹ K ⁻¹]	Conductivity [W m ⁻¹ K ⁻¹]
Clay Tile	0.025	1900	800	0.84
Air Cavity	0.15	—	—	—
Insulation	0.162	43	1210	0.03
Gypsum board	0.019	800	1090	0.16

The dormer roof provides no insulation and is only in place to protect the inside spaces from wind and rain. This construction is shared between the minimal retrofit model and the deep retrofit model.

Table 4.5: Hipped Dormer Roof Construction

Layer	Thickness [m]	Density [kg m ⁻³]	Heat Capacity [J kg ⁻¹ K ⁻¹]	Conductivity [W m ⁻¹ K ⁻¹]
Clay Tile	0.025	1900	800	0.84
Air Cavity	0.15	—	—	—
Roofing Felt	0.005	960	837	0.19

Table 4.6: External Glazing Construction

Layer	Thickness [m]	Transmittance [kg m ⁻³]	Conductivity [W m ⁻¹ K ⁻¹]
Inner Pane	0.003	0.783	0.4
Argon Gas	0.20	—	—
Outer Pane	0.003	0.783	0.4

4.2.1.2 Deep Retrofit Model

During the deep retrofit process, the external wall, exposed floor and external glazing constructions are upgraded to conform to the Building Regulations Part L 2022. The infiltration rate was also decreased to 0.5 Air Changes Per Hour (ACPH) due to leakiness being heavily reduced.

Table 4.7: External Glazing Construction (Deep Retrofit)

Layer	Thickness [m]	Transmittance [kg m ⁻³]	Conductivity [W m ⁻¹ K ⁻¹]
Inner Pane	0.003	0.783	0.4
Argon Gas	0.20	—	—
Middle Pane	0.003	0.783	0.4
Argon Gas	0.20	—	—
Outer Pane	0.003	0.783	0.4

Table 4.8: Exterior Floor Construction

Layer	Thickness [m]	Density [kg m ⁻³]	Heat Capacity [J kg ⁻¹ K ⁻¹]	Conductivity [W m ⁻¹ K ⁻¹]
Acoustic Tile	0.0191	368	590	0.06
Air Cavity	0.15	—	—	—
Insulation	0.085	43	1210	0.03
Concrete	0.1016	1280	840	0.53

Table 4.9: Exterior Wall Construction

Layer	Thickness [m]	Density [kg m ⁻³]	Heat Capacity [J kg ⁻¹ K ⁻¹]	Conductivity [W m ⁻¹ K ⁻¹]
Rainscreen	0.01	7824	500	30
Insulation	0.085	43	1210	0.03
Air Cavity	0.15	—	—	—
Gypsum board	0.019	800	1090	0.16

4.3 SCHEDULES, EQUIPMENT AND INTERNAL GAINS

Internal gains in the context of an energy building simulation of a residential home refers to the heat generated within the envelope by people, appliances, and lighting.

People generate heat through their activities and body heat, while appliances generate heat through their operation. Lighting generates heat due to the inefficiencies in converting electricity into light, and light ultimately being converted to heat energy.

In energy building simulation, internal gains are important to consider because they can significantly affect the energy balance of the building. If the internal gains are high, the building may require less heating, which can lead to energy savings. Conversely, if the internal gains are low, the building may require more heating, which can lead to increased energy consumption and costs. [61]

Internal gains are typically modelled as a heat input to the building, which is then factored into the overall energy balance of the building. The magnitude of internal gains is typically calculated based on the number of occupants, the types and number of appliances, and the lighting levels in the building.

4.3.1 Occupancy Gains

The magnitude of these gains depends on factors such as the number of occupants, their activity levels, and the duration of their stay in the building. It was decided that a house of the size of the reference home was sized for a total of four persons.

In order to accurately model occupancy gains in a BEM, it is important to use typical occupancy profiles in conjunction with typical metabolic rates for different tasks. A typical occupancy profile is a representation of the number of occupants in the building over time, while a typical metabolic rate is a measure of the heat generated by a person due to their physical activity. Different tasks require different amounts of energy, and therefore result in different levels of heat generation. For example, a person sitting quietly may have a lower metabolic rate than someone performing strenuous physical activity.

Buttitta and Finn [61] developed a stochastic occupancy model which generates hourly occupancy schedules for up to five different types of occupancy profiles of residential buildings for an entire year, based off of data gathered from London, UK. For this thesis, an occupancy profile was chosen which represented the largest share of the population, and two schedules were drawn, one for the weekdays and one for the weekends. These schedules depict the number of persons occupying the dwelling at each hour of the day, and are detailed in Tbl. 4.10.

Table 4.10: Occupancy Schedules

1	1	1
---	---	---

‘ANSI/ASHRAE Standard 55-2010: Thermal Environmental Conditions for Human Occupancy’ [62] details the metabolic rate of people performing various tasks, given in Met units, as well

as watts per square metre. An activity level schedule was quasi-arbitrarily assembled and is detailed in [Tbl. 4.11](#).

Table 4.11: Activity Schedule

<u>1</u>	<u>1</u>	<u>1</u>
----------	----------	----------

4.3.2 *Lighting*

In the past, internal gains from lighting used to be a significant contributor to the overall heat load of buildings. This was largely due to the widespread use of inefficient incandescent light bulbs, which generated a significant amount of heat as a byproduct of their operation. In fact, it was not uncommon for incandescent bulbs to emit more heat than light, resulting in a significant waste of energy and contributing to higher cooling loads in buildings.

However, with the gradual adoption of more efficient lighting technologies such as LED bulbs, internal gains from lighting have become much less of a concern. LED bulbs are significantly more efficient than incandescent bulbs, converting a higher percentage of their energy input into light rather than heat. This means that they generate far less waste heat, resulting in lower cooling loads and reduced energy consumption. ISO 17772-1:2017 presents lighting schedules and load density profiles for single family residential homes, and are reproduced in [Tbl. 4.12](#).

4.3.3 *Plug Loads and Equipment*

Plug loads in a residential home refer to the energy consumed by appliances and devices that are plugged into electrical outlets, such as televisions, computers, and kitchen appliances. Equipment internal gains in a residential home refer to the heat generated by the operation of various equipment and appliances,

such as refrigerators, ovens, and water heaters. This heat can contribute to the overall heat load of the home, particularly during periods of high use. ISO 17772-1:2017 gives details regarding standards for schedules and load density profiles for equipment gains and plug loads, and is reproduced in [Tbl. 4.12](#).

Table 4.12: Lighting, Plug Loads and Equipment Gains Schedules and Load Densities [\[63\]](#)

2.07	1.92	1
------	------	---

4.4 CLIMATE

4.5 HEATING SYSTEM

4.5.1 ASHP

The [ASHP](#) model was imported from the IDEAS library [\[64\]](#). Performance table data obtained from Daikin for a low-temperature, modulating [AWHP](#) was used in the modelling of the heat pump. By interpolating the data in the table, the model is able to determine the heating power, electricity usage, and [COP](#) based on the condenser outlet temperature and the ambient temperature. The [HP](#) has a nominal heating power of 7177 W at a test condition of 2/35 °C (air/condenser temperature), with a [COP](#) of 3.17 at this condition and a [COP](#) of 2.44 at a test condition of 2/45 °C for full load operation. The heat pump can operate at leaving water temperatures up to 55 °C.

The [COP](#) of the [AWHP](#) model is calculated by the ratio of heat energy transferred to the passing water to the electrical power used. This is given by [Eq. 4.1](#).

$$\text{COP}_{\text{HP}} = \frac{\dot{Q}_{\text{H}}}{\dot{W}_{\text{elec}}} \quad (4.1)$$

The SCOP of the HP is calculated by taking the ratio the total heat energy imparted to the water to the total electrical energy used by the HP over the course of the year and is given by Eq. 4.2

$$\text{SCOP}_{\text{HP}} = \frac{Q_{\text{H, tot}}}{W_{\text{elec, tot}}} \quad (4.2)$$

The model uses modulation to introduce some hysteresis to avoid quick-succession, repeated on-off cycling. The HP turns off when the modulation drops below 20% and turns on when the modulation exceeds 35%. Heat losses to the surroundings are taken into account to produce a dynamic model, al the while maintaining the performance as per Daikin's data [65].

4.5.2 Radiators

The RadiatorEN442 radiator model from the Buildings library [66] was used. Each of the twelve conditioned rooms was assigned a radiator. The nominal heat flow for a radiator in room i was determined by taking the nominal total heat flow of the system, $Q_{\text{flow, nom}}$ and multiplying it by the ratio of the volume of room i , $V_{\text{room, } i}$ to the total conditioned room volume, $V_{\text{rooms, tot}}$. The radiator model uses five discretised elements to perform a discretised element method heat transfer calculation. The model parameters were altered to only produce convective heat transfer to the room i.e., no radiative heat transfer as the EnergyPlus compatible ThermalZone model has no radiative heat input. The heat transfer was modelled with Eq. 4.3

$$Q_c^i = \text{sign}(T^i - T_a)(1 - f_r) \frac{UA}{N} |T^i - T_a|^n \quad (4.3)$$

Where T^i is the water temperature of the element, T_a is the temperature of the air in the room, f_r fraction of the radiation, set to 0 in this model, n is the exponent of heat transfer, set to

1.3, and UA is the UA -value of the radiator which is numerical solved for the given nominal data values.

4.5.3 Thermal Storage Tank

The thermal storage tank `Thermal.Storage` model from the Buildings library [66] was used in the HHS model. The model uses ten stratified layer to model the dynamics of the temperature gradient of the water within the tank. The storage tank was fixed to contain 0.5 m^3 of water, or 500 L, with 10 cm of insulation thickness and a height of 1.7 m. The tank was assumed to be located in the aforementioned unconditioned room, with heat losses occurring from the tank to the room. Two temperature sensors are connected to the tank, one at the bottom of the water volume (volume index 0) one at the top of the water volume (volume index 9).

4.5.4 Boiler

The boiler model `BoilerPolynomial` from the Buildings library was utilised to model the natural gas boiler component of the HHS. A constant efficiency of 90% was used as this best matched the efficiency of the reference house boiler. A nominal mass flowrate of 0.25 kg s^{-1} was inputted, which had been calculated through Eq. 4.4.

$$\dot{m}_{\text{boi, nom}} = \frac{k \dot{Q}_{\text{nom}}}{\Delta T_{\text{boi loop}} c_{\text{water}}} \quad (4.4)$$

The coefficient k is simply a scaling factor that affects the mass-flow rate and downstream variables.

4.5.5 Heating System Behaviour

Fig. 4.3 is an flowchart diagram which depicts (a slightly non-nuanced version) the system behaviour of the HHS implemented in Modelica.




Figure 4.3: Flowchart diagram of HHS behaviour

4.6 LOAD PROFILES

SENSITIVITY ANALYSIS

A sensitivity analysis, also referred to as a parametric study, is a technique utilised in simulation modelling to assess the impact of varying parameters on the outcomes of the model. The process involves iteratively running the simulation multiple times with systematic modifications to input parameters and can enable the identification of critical parameters that exert the most substantial influence on the model outcomes, and also, in particular, identify the optimal pair of values of the parallel operation temperature window.

In this thesis, an exhaustive or full factorial sensitivity analysis has been performed on the bivalent parallel operation temperature window of a [HHPS](#). The analysis evaluates the impact of altering the bivalent temperature and cut-off temperature on the total cost of fuel and electricity for the [HHS](#) over the course of a year in the economic assessment, as well as on the [PE](#) used and CO₂ emissions in the ecological assessment. The approach adopted in this research allows for a comprehensive examination of the system, by identifying the factors that are critical in determining the optimal operation of the system, while also providing insights into potential cost savings and environmental benefits.

Although full factorial designs can be computationally expensive and time-consuming, this approach was chosen as the dimensionality of the parameters space is very low at just two, and the resolution, or number of levels, being simulated for the two parameters is also relatively low. This enables a full factorial

parametric study to be carried out given the complexity of the model and the computational resources available.

ECO-ECONOMIC ASSESSMENT

Wir müssen wissen. Wir werden wissen

— David Hilbert

CONCLUSIONS

BIBLIOGRAPHY

- [1] International Energy Agency. *The Future of Cooling*. <https://www.iea.org/reports/the-future-of-cooling>. 2018. (3).
- [2] International Energy Agency. *Space Cooling*. <https://www.iea.org/reports/space-cooling>. 2022. (3).
- [3] Eurostat. *Final energy consumption in the residential sector by use, EU-27*. 2018. URL: https://ec.europa.eu/eurostat/statistics-explained/index.php?title=File:Final_energy_consumption_in_the_residential_sector_by_use,_EU-27,_2018.png. (3).
- [4] Eurostat. *Energy consumption in households*. 2020. URL: https://ec.europa.eu/eurostat/statistics-explained/index.php?title=Energy_consumption_in_households. (3).
- [5] M.S. Owen, Refrigerating American Society of Heating and Air-Conditioning Engineers. 2009 *ASHRAE Handbook: Fundamentals*. 2009 Ashrae Handbook - Fundamentals. American Society of Heating, Refrigeration and Air-Conditioning Engineers, 2009. ISBN: 978-1-933742-55-7. URL: <https://books.google.ie/books?id=D65XPgAACAAJ>. (3, 19, 24, 25, 35, 37).
- [6] Pakalolo. *Europe's heatwave is "the most extreme event ever seen in European climatology."* Jan. 2023. URL: <https://www.dailykos.com/stories/2023/1/4/2145284/-Europe-s-heatwave-is-the-most-extreme-event-ever-seen-in-European-climatology>. (4).
- [7] Steve Heinen, Daniel Burke and Mark O'Malley. 'Electricity, gas, heat integration via residential hybrid heating technologies – An investment model assessment'. In: *Energy* 109 (15th Aug. 2016), pp. 906–919. ISSN: 0360-5442. DOI: [10.1016/j.energy.2016.04](https://doi.org/10.1016/j.energy.2016.04)

- .126. URL: <https://www.sciencedirect.com/science/article/pii/S0360544216305461>. (4, 9, 17).
- [8] Cyril Vuillecard, Charles Emile Hubert, Régis Contreau, Anthony mazzenga, Pascal Stabat and Jerome Adnot. 'Small scale impact of gas technologies on electric load management – μ CHP & hybrid heat pump'. In: *Energy* 36.5 (1st May 2011), pp. 2912–2923. ISSN: 0360-5442. DOI: [10.1016/j.energy.2011.02.034](https://doi.org/10.1016/j.energy.2011.02.034). URL: <https://www.sciencedirect.com/science/article/pii/S0360544211001125>. (4).
- [9] Georg Thomaßen, Konstantinos Kavvadias and Juan Pablo Jiménez Navarro. 'The decarbonisation of the EU heating sector through electrification: A parametric analysis'. In: *Energy Policy* 148 (1st Jan. 2021), p. 111929. ISSN: 0301-4215. DOI: [10.1016/j.enpol.2020.111929](https://doi.org/10.1016/j.enpol.2020.111929). URL: <https://www.sciencedirect.com/science/article/pii/S0301421520306406>. (4).
- [10] Central Statistics Office. *Housing Stock*. 2020. URL: <https://www.cso.ie/en/releasesandpublications/ep/p-cplhii/cplhii/hs/>. (5).
- [11] K. Klein, K. Huchtemann and D. Müller. 'Numerical study on hybrid heat pump systems in existing buildings'. In: *Energy and Buildings* 69 (1st Feb. 2014), pp. 193–201. ISSN: 0378-7788. DOI: [10.1016/j.enbuild.2013.10.032](https://doi.org/10.1016/j.enbuild.2013.10.032). URL: <https://www.sciencedirect.com/science/article/pii/S0378778813006798>. (5, 9, 11, 18–20, 24).
- [12] Matteo Dongellini, Claudia Naldi and Gian Luca Morini. 'Influence of sizing strategy and control rules on the energy saving potential of heat pump hybrid systems in a residential building'. In: *Energy Conversion and Management* 235 (1st May 2021), p. 114022. ISSN: 0196-8904. DOI: [10.1016/j.enconman.2021.114022](https://doi.org/10.1016/j.enconman.2021.114022). URL: <https://www.sciencedirect.com/science/article/pii/S0196890421001989>. (5, 9, 16, 17, 20).
- [13] Sustainable Energy Authority of Ireland. *SEAI Data and Insights*. 2020. URL: <https://www.seai.ie/data-and-insights/seai-statistics/energy-data/>. (5, 6).

- [14] Yunus A. Çengel, Michael A. Boles and Mehmet Kanoglu. *Thermodynamics: an engineering approach*. English. 9th in SI units. Singapore: McGraw Hill, 2020. ISBN: 9813157879. (6, 14, 15).
- [15] The European Heat Pump Association AISBL (EHPA). *European Heat Pump Market and Statistics Report 2015 - EHPA*. 2015. URL: https://www.ehpa.org/fileadmin/red/07._Market_Data/2014/EHPA_European_Heat_Pump_Market_and_Statistics_Report_2015_-_executive_Summary.pdf. (7).
- [16] Thomas Nowak. *Heat Pumps – Integrating technologies to decarbonize heating and cooling*. EHPA, 2018. URL: https://help.leonardo-energy.org/hc/article_attachments/360010981780/ehpa-white-paper-111018.pdf. (7, 12, 13, 27).
- [17] Abdeen Mustafa Omer. ‘Ground-source heat pumps systems and applications’. English. In: *Renewable & sustainable energy reviews* 12.2 (2008), pp. 344–371. (7).
- [18] Karl Ochsner. *Geothermal heat pumps*. Planning and Installing. London, England: Earthscan, Nov. 2007. (7).
- [19] Costanzo Di Perna, Guglielmo Magri, Giuliano Giuliani and Giorgio Serenelli. ‘Experimental assessment and dynamic analysis of a hybrid generator composed of an air source heat pump coupled with a condensing gas boiler in a residential building’. In: *Applied Thermal Engineering* 76 (5th Feb. 2015), pp. 86–97. ISSN: 1359-4311. DOI: [10.1016/j.applthermaleng.2014.10.007](https://doi.org/10.1016/j.applthermaleng.2014.10.007). URL: <https://www.sciencedirect.com/science/article/pii/S1359431114008783>. (7, 9, 31).
- [20] Gang Li. ‘Parallel loop configuration for hybrid heat pump – gas fired water heater system with smart control strategy’. In: *Applied Thermal Engineering* 138 (25th June 2018), pp. 807–818. ISSN: 1359-4311. DOI: [10.1016/j.applthermaleng.2018.04.087](https://doi.org/10.1016/j.applthermaleng.2018.04.087). URL: <https://www.sciencedirect.com/science/article/pii/S1359431118302886>. (9).
- [21] Ji Young Jang, Heung Hee Bae, Seung Jun Lee and Man Yeong Ha. ‘Continuous heating of an air-source heat pump during defrosting and improvement of energy efficiency’. In: *Applied*

- Energy* 110 (1st Oct. 2013), pp. 9–16. ISSN: 0306-2619. DOI: [10.1016/j.apenergy.2013.04.030](https://doi.org/10.1016/j.apenergy.2013.04.030). URL: <https://www.sciencedirect.com/science/article/pii/S0306261913003255>. (9).
- [22] Hansaem Park, Ki Hwan Nam, Gi Hyun Jang and Min Soo Kim. ‘Performance investigation of heat pump–gas fired water heater hybrid system and its economic feasibility study’. In: *Energy and Buildings* 80 (1st Sept. 2014), pp. 480–489. ISSN: 0378-7788. DOI: [10.1016/j.enbuild.2014.05.052](https://doi.org/10.1016/j.enbuild.2014.05.052). URL: <https://www.sciencedirect.com/science/article/pii/S0378778814004769>. (9, 16).
- [23] Noah Rauschkolb, Vijay Modi and Patricia Culligan. ‘Cost-Optimal Sizing and Operation of a Hybrid Heat Pump System Using Numerical Simulation’. In: *ASHRAE Transactions* 126 (2020). Num Pages: 134–143 Place: Atlanta, United States Publisher: American Society of Heating, Refrigeration and Air Conditioning Engineers, Inc., pp. 134–143. ISSN: 00012505. URL: <https://www.proquest.com/docview/2414052984/abstract/D9A56D8BC8F44C6CPQ/1>. (9, 16, 25, 38).
- [24] G. Bagarella, R. Lazzarin and M. Noro. ‘Annual simulation, energy and economic analysis of hybrid heat pump systems for residential buildings’. In: *Applied Thermal Engineering* 99 (25th Apr. 2016), pp. 485–494. ISSN: 1359-4311. DOI: [10.1016/j.applthermaleng.2016.01.089](https://doi.org/10.1016/j.applthermaleng.2016.01.089). URL: <https://www.sciencedirect.com/science/article/pii/S1359431116300394>. (9, 16, 22, 31).
- [25] Erica Roccatello, this link will open in a new window Link to external site, Alessandro Prada, this link will open in a new window Link to external site, Paolo Baggio, this link will open in a new window Link to external site, Marco Baratieri and this link will open in a new window Link to external site. ‘Analysis of the Influence of Control Strategy and Heating Loads on the Performance of Hybrid Heat Pump Systems for Residential Buildings’. In: *Energies* 15.3 (2022). Num Pages: 732 Place: Basel, Switzerland Publisher: MDPI AG, p. 732. DOI: [10.3390/en15030732](https://doi.org/10.3390/en15030732). URL: <https://www.proquest.com/docview/2627555758/abstract/55D08F93CBA943A6PQ/1>. (9, 19, 20, 31).

- [26] Tara S. Amirkhizi and Ida G. Jensen. 'Cost comparison and optimization of gas electric hybrid heat pumps'. In: *WIREs Energy and Environment* 9.3 (2020). _eprint: <https://onlinelibrary.wiley.com/doi/pdf/10.1002/wene.370>, e370. ISSN: 2041-840X. DOI: [10.1002/wene.370](https://doi.org/10.1002/wene.370). URL: <https://onlinelibrary.wiley.com/doi/abs/10.1002/wene.370>. (9).
- [27] SEAI and Ricardo Energy & Environment. *Heat Pump Implementation Guide*. SEAI, 2020, p. 55. URL: <https://www.seai.ie/publications/Heat-Pump-Implementation-Guide.pdf>. (12, 13).
- [28] Council of European Union. *Commission Decision of 1 March 2013 establishing the guidelines for Member States on calculating renewable energy from heat pumps from different heat pump technologies pursuant to Article 5 of Directive 2009/28/EC of the European Parliament and of the Council*. English. 2013. URL: <https://eur-lex.europa.eu/legal-content/EN/TXT/?uri=CELEX%3A02013D0114-20130306>. (12).
- [29] Elena Bee, Alessandro Prada, Paolo Baggio and Emmanouil Psimopoulos. 'Air-source heat pump and photovoltaic systems for residential heating and cooling: Potential of self-consumption in different European climates'. In: *Building Simulation* 12.3 (1st June 2019), pp. 453–463. ISSN: 1996-8744. DOI: [10.1007/s12273-018-0501-5](https://doi.org/10.1007/s12273-018-0501-5). URL: <https://doi.org/10.1007/s12273-018-0501-5>. (12).
- [30] Juergen Haeger. *Heat Pumps: Engineering and Installation*. Stiebel Eltron GmbH & Co. KG. Holzminden, Germany, 2012, p. 108. (12, 19).
- [31] Corey Blackman, Kyle R. Gluesenkamp, Mini Malhotra and Zhiyao Yang. 'Study of optimal sizing for residential sorption heat pump system'. In: *Applied Thermal Engineering* 150 (5th Mar. 2019), pp. 421–432. ISSN: 1359-4311. DOI: [10.1016/j.applthermaleng.2018.12.151](https://doi.org/10.1016/j.applthermaleng.2018.12.151). URL: <https://www.sciencedirect.com/science/article/pii/S1359431118351007>. (15).
- [32] Tamás Buday. 'Reduction of environmental impacts of heat pump usage with special regard on systems with borehole heat ex-

- changers'. In: *Acta Geographica Debrecina Landscape & Environment* 8 (Dec. 2014), pp. 66–77. (17, 18).
- [33] F. D'Ettorre, M. De Rosa, P. Conti, E. Schito, D. Testi and D. P. Finn. 'Economic assessment of flexibility offered by an optimally controlled hybrid heat pump generator: a case study for residential building'. In: *Energy Procedia*. ATI 2018 - 73rd Conference of the Italian Thermal Machines Engineering Association 148 (1st Aug. 2018), pp. 1222–1229. ISSN: 1876-6102. DOI: [10.1016/j.egypro.2018.08.008](https://doi.org/10.1016/j.egypro.2018.08.008). URL: <https://www.sciencedirect.com/science/article/pii/S1876610218302935>. (19, 20).
- [34] A. Mugnini, G. Coccia, F. Polonara and A. Arteconi. 'Variable-Load Heat Pumps: Impact of the Design and Control Parameters on the Actual Operation Conditions'. In: *TECNICA ITALIANA-Italian Journal of Engineering Science* (2021). DOI: [10.18280/ti-ijes.652-434](https://doi.org/10.18280/ti-ijes.652-434). (19, 31).
- [35] Giacomo Bagarella, Renato M. Lazzarin and Biagio Lamanna. 'Cycling losses in refrigeration equipment: An experimental evaluation'. In: *International Journal of Refrigeration* 36.8 (1st Dec. 2013), pp. 2111–2118. ISSN: 0140-7007. DOI: [10.1016/j.ijrefrig.2013.07.020](https://doi.org/10.1016/j.ijrefrig.2013.07.020). URL: <https://www.sciencedirect.com/science/article/pii/S0140700713001989>. (20).
- [36] Camilla Sandström. *Frosting and Defrosting on Air Source Heat Pump Evaporators*. 2021. URL: <http://urn.kb.se/resolve?urn=urn:nbn:se:kth:diva-299880>. (20).
- [37] Tomas Kropas, Giedrė Streckienė and Juozas Bielskus. 'Experimental Investigation of Frost Formation Influence on an Air Source Heat Pump Evaporator'. In: *Energies* 14.18 (Jan. 2021). Number: 18 Publisher: Multidisciplinary Digital Publishing Institute, p. 5737. ISSN: 1996-1073. DOI: [10.3390/en14185737](https://doi.org/10.3390/en14185737). URL: <https://www.mdpi.com/1996-1073/14/18/5737>. (20).
- [38] Long Zhang, Yiqiang Jiang, Jiankai Dong, Yang Yao and Shiming Deng. 'An experimental study of frost distribution and growth on finned tube heat exchangers used in air source heat pump units'. In: *Applied Thermal Engineering* 132 (5th Mar. 2018), pp. 38–

51. ISSN: 1359-4311. DOI: [10.1016/j.applthermaleng.2017.12.047](https://doi.org/10.1016/j.applthermaleng.2017.12.047). URL: <https://www.sciencedirect.com/science/article/pii/S1359431117360969>. (21).
- [39] Mohammed Amer and Chi-Chuan Wang. 'Review of defrosting methods'. In: *Renewable and Sustainable Energy Reviews* 73 (1st June 2017), pp. 53–74. ISSN: 1364-0321. DOI: [10.1016/j.rser.2017.01.120](https://doi.org/10.1016/j.rser.2017.01.120). URL: <https://www.sciencedirect.com/science/article/pii/S1364032117301302>. (22).
- [40] Jiankai Dong, Shiming Deng, Yiqiang Jiang, Liang Xia and Yang Yao. 'An experimental study on defrosting heat supplies and energy consumptions during a reverse cycle defrost operation for an air source heat pump'. In: *Applied Thermal Engineering* 37 (2012), pp. 380–387. ISSN: 1359-4311. DOI: <https://doi.org/10.1016/j.applthermaleng.2011.11.052>. URL: <https://www.sciencedirect.com/science/article/pii/S1359431111006806>. (22).
- [41] Chartered Institution of Building Services Engineers. *Environmental Design: CIBSE Guide A*. 7th. CIBSE guide. Chartered Institution of Building Services Engineers, 2006. ISBN: 978-1-903287-66-8. URL: <https://books.google.ie/books?id=IxXKAAACAAJ>. (23, 24).
- [42] BizEE Software. *Degree Days*. <https://www.degreedays.net/>. Accessed: 2022-10-25. (24).
- [43] Vincenzo Bianco, Federico Scarpa and Luca A. Tagliafico. 'Estimation of primary energy savings by using heat pumps for heating purposes in the residential sector'. In: *Applied Thermal Engineering* 114 (Mar. 2017), pp. 938–947. ISSN: 13594311. DOI: [10.1016/j.applthermaleng.2016.12.058](https://doi.org/10.1016/j.applthermaleng.2016.12.058). URL: <https://linkinghub.elsevier.com/retrieve/pii/S1359431116340625>. (27, 28, 31).
- [44] SEAI. *Energy in Ireland 2021 Report*. 2021. URL: https://www.seai.ie/publications/Energy-in-Ireland-2021_Final.pdf. (28, 29).

- [45] European Commission. 'An EU Strategy on Heating and Cooling'. In: COM 51 (2016). (29).
- [46] EPRI. 'US national electrification assessment'. In: *Technical Report 3002013582* (2018). (29).
- [47] Gene F Franklin, J David Powell and Abbas Emami-Naeini. *Feedback control of dynamic systems*. 7th ed. Upper Saddle River, NJ: Pearson, Apr. 2014. (30).
- [48] Rames. Panda and V. Sujath. 'Identification and control of multivariable systems – role of relay feedback'. In: *Introduction to PID Controllers - Theory, Tuning and Application to Frontier Areas*. InTech, Feb. 2012. DOI: [10.5772/2422](https://doi.org/10.5772/2422). (31, 32).
- [49] Gulsun Demirezen and Alan S. Fung. 'Feasibility of Cloud Based Smart Dual Fuel Switching System (SDFSS) of Hybrid Residential Space Heating Systems for Simultaneous Reduction of Energy Cost and Greenhouse Gas Emission'. In: *Energy and Buildings* 250 (1st Nov. 2021), p. 111237. ISSN: 0378-7788. DOI: [10.1016/j.enbuild.2021.111237](https://doi.org/10.1016/j.enbuild.2021.111237). URL: <https://www.sciencedirect.com/science/article/pii/S0378778821005211>. (31).
- [50] Daniel Coakley, Paul Raftery and Marcus Keane. 'A review of methods to match building energy simulation models to measured data'. In: *Renewable and Sustainable Energy Reviews* 37 (1st Sept. 2014), pp. 123–141. ISSN: 1364-0321. DOI: [10.1016/j.rser.2014.05.007](https://doi.org/10.1016/j.rser.2014.05.007). URL: <https://www.sciencedirect.com/science/article/pii/S1364032114003232>. (34–36).
- [51] Sten de Wit and Godfried Augenbroe. 'Analysis of uncertainty in building design evaluations and its implications'. In: *Energy and Buildings* 34.9 (2002). A View of Energy and Bilding Performance Simulation at the start of the third millennium, pp. 951–958. ISSN: 0378-7788. DOI: [https://doi.org/10.1016/S0378-7788\(02\)00070-1](https://doi.org/10.1016/S0378-7788(02)00070-1). URL: <https://www.sciencedirect.com/science/article/pii/S0378778802000701>. (34).
- [52] Tahmasebi Farhang and Mahdavi Ardeshir. 'Monitoring-based optimization-assisted calibration of the thermal performance

- model of an office building’. In: International Conference on Architecture and Urban Design. 2012. (35).
- [53] ASHRAE Guideline Project Committee 14. ‘ASHRAE Guideline 14-2014’. In: (2014). ISSN: 1049-894X. URL: https://upgreengrade.ir/admin_panel/assets/images/books/ASHRAE%20Guideline%2014-2014.pdf. (35, 37, 44).
- [54] Eva Lucas Segarra, Hu Du, Germán Ramos Ruiz and Carlos Fernández Bandera. ‘Methodology for the quantification of the impact of weather forecasts in predictive simulation models’. In: *Energies* 12.7 (2019), p. 1309. (35).
- [55] Spyros Makridakis. ‘Accuracy measures: theoretical and practical concerns’. In: *International Journal of Forecasting* 9.4 (1993), pp. 527–529. ISSN: 0169-2070. DOI: [https://doi.org/10.1016/0169-2070\(93\)90079-3](https://doi.org/10.1016/0169-2070(93)90079-3). URL: <https://www.sciencedirect.com/science/article/pii/0169207093900793>. (36).
- [56] Chris Tofallis. ‘A better measure of relative prediction accuracy for model selection and model estimation’. In: *Journal of the Operational Research Society* 66.8 (1st Aug. 2015). Publisher: Taylor & Francis _eprint: <https://doi.org/10.1057/jors.2014.103>, pp. 1352–1362. ISSN: 0160-5682. DOI: [10.1057/jors.2014.103](https://doi.org/10.1057/jors.2014.103). URL: <https://doi.org/10.1057/jors.2014.103>. (36).
- [57] Ferhat Khendek and Reinhard Gotzhein, eds. *System Analysis and Modeling. Languages, Methods, and Tools for Systems Engineering: 10th International Conference, SAM 2018, Copenhagen, Denmark, October 15–16, 2018, Proceedings*. Vol. 11150. Lecture Notes in Computer Science. Cham: Springer International Publishing, 2018. ISBN: 978-3-030-01042-3. DOI: [10.1007/978-3-030-01042-3](https://doi.org/10.1007/978-3-030-01042-3). URL: <http://link.springer.com/10.1007/978-3-030-01042-3>. (36).
- [58] Sungil Kim and Heeyoung Kim. ‘A new metric of absolute percentage error for intermittent demand forecasts’. In: *International Journal of Forecasting* 32 (1st July 2016), pp. 669–679. DOI: [10.1016/j.ijforecast.2015.12.003](https://doi.org/10.1016/j.ijforecast.2015.12.003). (36).

- [59] Andreas Bloess, Wolf-Peter Schill and Alexander Zerrahn. ‘Power-to-heat for renewable energy integration: A review of technologies, modeling approaches, and flexibility potentials’. In: *Applied Energy* 212 (15th Feb. 2018), pp. 1611–1626. ISSN: 0306-2619. DOI: [10.1016/j.apenergy.2017.12.073](https://doi.org/10.1016/j.apenergy.2017.12.073). URL: <https://www.sciencedirect.com/science/article/pii/S0306261917317889>. (38).
- [61] Giuseppina Buttitta and Donal P. Finn. ‘A high-temporal resolution residential building occupancy model to generate high-temporal resolution heating load profiles of occupancy-integrated archetypes’. In: *Energy and Buildings* 206 (1st Jan. 2020), p. 109577. ISSN: 0378-7788. DOI: [10.1016/j.enbuild.2019.109577](https://doi.org/10.1016/j.enbuild.2019.109577). URL: <https://www.sciencedirect.com/science/article/pii/S0378778819322170>. (52, 53).
- [62] ASHRAE. ‘ANSI/ASHRAE Standard 55-2010: Thermal Environmental Conditions for Human Occupancy’. In: (2010), p. 44. ISSN: 1041-2336. (53).
- [63] Technical Committee ISO/TC 163. *Energy performance of buildings — Indoor environmental quality*. Standard. Geneva, CH: International Organization for Standardization, June 2017, p. 60. (54, 55).
- [64] F. Jorissen, G. Reynders, R. Baetens, D. Picard, D. Saelens and L. Helsen. ‘Implementation and verification of the IDEAS building energy simulation library’. In: *Journal of Building Performance Simulation* 11.6 (2nd Nov. 2018). Publisher: Taylor & Francis _eprint: <https://doi.org/10.1080/19401493.2018.1428361>, pp. 669–688. ISSN: 1940-1493. DOI: [10.1080/19401493.2018.1428361](https://doi.org/10.1080/19401493.2018.1428361). URL: <https://doi.org/10.1080/19401493.2018.1428361>. (55).
- [65] Daikin Europe N.V. *Technical Data — ERYQ005-007A, EKHBH007A / EKHBX007A, EKSWW150-300*. Ostend, Belguim, 2006. URL: http://www.pacenr.free.fr/doc/daikin_altherma_bt_tech_spec/TD_ERYQ005-007A_EKHBH-X007A_EN.pdf. (56).
- [66] Michael Wetter, Wangda Zuo, Thierry Noudui and Xiufeng Pang. ‘Modelica Buildings library’. In: *Journal of Building Performance*

ance Simulation 7 (4th July 2014). DOI: [10.1080/19401493.2013.765506](https://doi.org/10.1080/19401493.2013.765506). ([56](#), [57](#)).

Part III

APPENDIX

APPENDIX TEST

Lorem ipsum at nusquam appellantur his, ut eos erant homero concludaturque. Albucius appellantur deterruisset id eam, vivendum partiendo dissentiet ei ius. Vis melius facilisis ea, sea id convenire referrentur, takimata adolescens ex duo. Ei harum argumentum per. Eam vidit exerci appetere ad, ut vel zzril intellegam interpretaris.

More dummy text.

A.1 APPENDIX SECTION TEST

Test: [Tbl. A.1](#) (This reference should have a lowercase, small caps A if the option `floatperchapter` is activated, just as in the table itself → however, this does not work at the moment.)

Table A.1: Autem usu id.

LABITUR BONORUM PRI NO	QUE VISTA	HUMAN
fastidii ea ius	germano	demonstratea
suscipit instructor	titulo	personas
quaestio philosophia	facto	demonstrated

$$V = \frac{4}{3}\pi r^3 \quad (\text{A.1})$$

$$= \eta_{\text{s, turbine}} \quad (\text{A.2})$$

$$\text{ch}(f_! \mathcal{F}^\bullet) \text{td}(Y) = f_*(\text{ch}(\mathcal{F}^\bullet) \text{td}(X)) \quad (\text{A.3})$$

Eq. A.1 Eqs. A.1 to A.3 Eqs. A.1 and A.3

A.2 ANOTHER APPENDIX SECTION TEST

Equidem detraxit cu nam, vix eu delenit periculis. Eos ut vero constituto, no vidit propriae complectitur sea. Diceret nonummy in has, no qui eligendi recteque consetetur. Mel eu dictas suscipiantur, et sed placerat oporteat. At ipsum electram mei, ad aequae atomorum mea. There is also a useless Pascal listing below:

*More dummy
textss.*

List. A.1.

Listing A.1: A floating example (listings manual)

```

1 for i:=maxint downto 0 do
2 begin
3   { do nothing }
4 end;
```

COLOPHON

This document was typeset using the typographical look-and-feel `classicthesis` developed by André Miede and Ivo Pletikosić. The style was inspired by Robert Bringhurst’s seminal book on typography “*The Elements of Typographic Style*”. `classicthesis` is available for both \LaTeX and \LyX :

<https://bitbucket.org/amiede/classicthesis/>

Happy users of `classicthesis` usually send a real postcard to the author, a collection of postcards received so far is featured here:

<http://postcards.miede.de/>

Thank you very much for your feedback and contribution.