



Revisado / Reviewed

Revisado con Comentarios
Reviewed with comments

Rechazado y volver a emitir
Rejected, reissue

Solo Información
Information Only

Fecha / Date
17-02-2020

Firma / Signature
Marcial Mendoza

1.- FOR P&ID LEGENDS AND SYMBOLS SEE DRAWINGS N°4-V2-2000-PR-PID-000001@000009.

2.- * INDICATES THAT IS PROVIDED BY VENDOR OR EQUIPMENT SUPPLIER.

3.- IN EQUIPMENT POWER DESCRIPTION, (E) ESTIMATED, (C) CALCULATED, (V) VENDOR'S CONFIRMED DATA.

4.- FOR FLUIDS CODES DETAILS SEE DRAWING N° 4-V2-2000-PR-PID-000004.

5.- TRIPLE EFFECT.

6.- ELEV. 1687 masl.

7.- END OF LINE

8.- MINIMUM SLOPE REQUIRED.

9.- DELETED.

10.- ELEV. 1686.

11.- CONTAINED AREA. SPILLS DRAIN TO SUMP 2831-SU-256.

12.- TEMPORARY CONE STRAINER.

13.- VALVE MUST BE MANUALLY REGULATED TO PRODUCE AN UPSTREAM PRESSURE OF 200 kPa.

Fluor-Salfa

BHP

MINERA SPENCE S.A.

SCALE

DESIGNED BY:

REVISOR:

ENGINEERING MGR:

DATE

23/03/19

23/03/19

23/03/19

SCALE

DRAWN BY:

DISCIPLINE LEADER:

PROJECT MGR:

DATE

23/03/19

23/03/19

23/03/19

CONTRACT N°:

8500135645

BHP DRAWING N°:

4-V2-2831-PR-PID-000008

REV

3

SGO PROJECT

UTILITIES & ONSITE INFRASTRUCTURE

WATER SUPPLY & DISTRIBUTION

COOLING WATER P&ID

3	13-02-20	ISSUED APPROVED FOR CONSTRUCTION	FC	HA	JB						
2	23-05-19	ISSUED APPROVED FOR CONSTRUCTION	FC	GB	JB						
1	11-12-18	ISSUED APPROVED FOR CONSTRUCTION	GE	GB	JB						
0	20-03-18	ISSUED APPROVED FOR DESIGN	CA	HA	JB						
0A	29-09-17	ISSUED FOR COMPANY APPROVAL	CA	HA	JB						
A	16-08-17	ISSUED FOR INTERNAL REVIEW	CA	HA	JB						
Rev. No.	DATE	REVISION	DIS.	REV.	D.L	BHP					

FRESH WATER DISTRIBUTION - PFD

4-V2-2800-PR-PFD-000001