

Extracts of - KERALA ELECTRICITY SUPPLY CODE (FOURTH AMENDMENT) REGULATIONS, 2008

*(These regulations shall be deemed to have come into force with effect from 1-11-2008.)*

Clause	Present	Amendment																																																			
2(1)(ee)	'Premises' include any land, building or structure;	' 'Premises' include any land, building, structure or part of it , situated in an immovable property , details of which have been specified in the applications or agreements prescribed for grant of electric connection.'																																																			
4(5)	<p>The supply voltage for different connected loads for new connections shall be as follows:</p> <table><tr><th>Supply Voltage</th><th>Maximum Connected Load</th><th>Maximum Contract Demand</th></tr><tr><td>240 V</td><td>5 kW</td><td>-</td></tr><tr><td>415V</td><td>100 kVA</td><td></td></tr><tr><td>11 kV</td><td>-</td><td>3000 kVA</td></tr><tr><td>22 kV/33 kV</td><td>-</td><td>6000 kVA</td></tr><tr><td>66 kV</td><td>-</td><td>8000 kVA</td></tr><tr><td>110 kV</td><td>-</td><td>20000 kVA</td></tr><tr><td>220 kV</td><td>-</td><td>&gt;20000kVA</td></tr></table> <p>Provided that variations may be permitted in respect of Extra High Tension (EHT) consumers with the approval of the Commission.</p>	Supply Voltage	Maximum Connected Load	Maximum Contract Demand	240 V	5 kW	-	415V	100 kVA		11 kV	-	3000 kVA	22 kV/33 kV	-	6000 kVA	66 kV	-	8000 kVA	110 kV	-	20000 kVA	220 kV	-	>20000kVA	<p>(a) The supply voltage for different connected loads for new connections shall be as follows:</p> <table><tr><th>Supply Voltage</th><th>Maximum Connected Load</th><th>Maximum Contract Demand</th></tr><tr><td>240 V</td><td>5 kW</td><td>-</td></tr><tr><td>415V</td><td>100 kVA</td><td></td></tr><tr><td>11 kV</td><td>-</td><td>3000 kVA</td></tr><tr><td>22 kV</td><td>-</td><td>6000 kVA</td></tr><tr><td>33 kV</td><td></td><td>12000 kVA</td></tr><tr><td>66 kV</td><td>-</td><td>20000 kVA</td></tr><tr><td>110 kV</td><td>-</td><td>40000 kVA</td></tr><tr><td>220 kV</td><td>-</td><td>&gt;40000kVA</td></tr></table> <p>(b) For new consumers connected load permitted under LT may be limited to 100kVA. But consumers existing as on the date of implementation of Kerala Electricity Supply Code, 2005 may be permitted to operate in LT up to a load of 150kVA '</p>	Supply Voltage	Maximum Connected Load	Maximum Contract Demand	240 V	5 kW	-	415V	100 kVA		11 kV	-	3000 kVA	22 kV	-	6000 kVA	33 kV		12000 kVA	66 kV	-	20000 kVA	110 kV	-	40000 kVA	220 kV	-	>40000kVA
Supply Voltage	Maximum Connected Load	Maximum Contract Demand																																																			
240 V	5 kW	-																																																			
415V	100 kVA																																																				
11 kV	-	3000 kVA																																																			
22 kV/33 kV	-	6000 kVA																																																			
66 kV	-	8000 kVA																																																			
110 kV	-	20000 kVA																																																			
220 kV	-	>20000kVA																																																			
Supply Voltage	Maximum Connected Load	Maximum Contract Demand																																																			
240 V	5 kW	-																																																			
415V	100 kVA																																																				
11 kV	-	3000 kVA																																																			
22 kV	-	6000 kVA																																																			
33 kV		12000 kVA																																																			
66 kV	-	20000 kVA																																																			
110 kV	-	40000 kVA																																																			
220 kV	-	>40000kVA																																																			
5(4)	<p>The Licensee may require an applicant to remit non-refundable application fee as follows:</p> <table><tr><th>System of supply</th><th>Application fee (Rs.)</th></tr><tr><td>LT supply</td><td>Rs. 25</td></tr><tr><td>HT supply</td><td>Rs. 1000</td></tr><tr><td>EHT supply</td><td>Rs. 5000</td></tr></table> <p>In the case of multistoried buildings having several service connections with more than 100kVA connected load, connections can be extended at Medium Voltage by providing bus ducts of adequate current carrying capacity and complying with Indian Electricity Rules 1956 or new rules framed as per provisions of the Act after installation of a single transformer of adequate capacity by the Licensee. Tariff applicable to such consumers shall be HT Tariff with appropriate modifications regarding Transformer losses, after obtaining approval of Kerala State Electricity Regulatory Commission.</p>	System of supply	Application fee (Rs.)	LT supply	Rs. 25	HT supply	Rs. 1000	EHT supply	Rs. 5000	<p>The Licensee may require an applicant to remit non-refundable application fee as follows:</p> <table><tr><th>System of supply</th><th>Application fee (Rs.)</th></tr><tr><td>LT supply</td><td>Rs. 50</td></tr><tr><td>HT supply</td><td>Rs. 1000</td></tr><tr><td>EHT supply</td><td>Rs. 5000</td></tr></table> <p>Except in the case of Kerala State Electricity Board or its successor body, for multistoried buildings having several service connections with more than 100kVA connected load, connections can be extended at Medium Voltage by providing bus ducts of adequate current carrying capacity and complying with Indian Electricity Rules 1956 or new rules framed as per provisions of the Act after installation of a single transformer of adequate capacity by the Licensee. Tariff applicable to such consumers shall be HT Tariff with appropriate modifications regarding Transformer losses, after obtaining approval of Kerala State Electricity Regulatory Commission.</p>	System of supply	Application fee (Rs.)	LT supply	Rs. 50	HT supply	Rs. 1000	EHT supply	Rs. 5000																																			
System of supply	Application fee (Rs.)																																																				
LT supply	Rs. 25																																																				
HT supply	Rs. 1000																																																				
EHT supply	Rs. 5000																																																				
System of supply	Application fee (Rs.)																																																				
LT supply	Rs. 50																																																				
HT supply	Rs. 1000																																																				
EHT supply	Rs. 5000																																																				

Extracts of - KERALA ELECTRICITY SUPPLY CODE (FOURTH AMENDMENT) REGULATIONS, 2008

(These regulations shall be deemed to have come into force with effect from 1-11-2008.)

(contd.....)

Clause	Present	Amendment
8(5)	Subject to sub-clause 1,2,3 and 4 in case of multistoried buildings having connected load below 50kVA, Licensee shall provide service connection from the LT line. For loads of 50 kVA and above, connection shall be affected only after installation of separate transformer of adequate capacity by the owner/occupier."	Subject to sub-clause 1,2,3 and 4 in case of multistoried buildings having connected load below 50kVA, Licensee shall provide service connection from the LT line. For loads of 50 kVA and above, connection shall be affected only after installation of separate transformer of adequate capacity by the owner/occupier <b>irrespective of the category of consumer."</b>
13(5)	The Licensee shall review the adequacy of security of all consumers in the first quarter of every financial year or when tariff revision is effected based on the average consumption of the preceding financial year and charges and tariffs in force. Based on the review, the Licensee may demand for shortfall <b>or refund the excess security as the case may be, by giving 30 days notice to the consumer.</b>	The Licensee shall review the adequacy of security deposit of all consumers in the first quarter of every financial year or when tariff revision is effected based on the average consumption of preceding financial year and charges and tariff in force. Based on the review, the licensee may demand for the shortfall <b>by giving 30 days notice to the consumer or adjust the excess security amount in the next bill as the case may be.</b>
23	<b>Interest charges for belated payment.-</b> In case of belated payments penal interest <b>at twice the bank rate based on actual number of days of delay from due date may be charged by the Licensee.</b>	<b>Interest Charges for belated payment -</b> In the case of belated payments, penal interest <b>at the rate of 12% per annum based on actual number of days of delay from the due date up to a period of 30 days and thereafter at the rate of 18% per annum for the entire period of default from the due date shall be charged by the Licensee.</b>

Visit <http://jameskutty.info/>