

Daniel's Super Cool and overly long title

Daniel Mortensen, Jacob Gunther

Abstract—TODO: add abstract

Index Terms—TODO: Add Keywords

I. INTRODUCTION

The goal of public transportation is to provide transit services using cost effective and environmentally sound methods. Most public transportation systems include bus fleets where each bus traverses a route and ferries costumers between stops. This business model puts significant miles on the buses and while effective, has several drawbacks including maintenance costs and emissions. To help overcome these challenges, many transit authorities have begun adopting electric buses which, in addition to zero emissions also offer fewer maintenance costs, and access to renewable energy[14].

Electric buses however are not without problems of their own. When an electric bus refuels, it draws power and induces a load on electrical infrastructure known as ‘the grid’. The loads introduced by bus charging are substantial and can significantly increase the grid’s maximum power draw[16][6][3]. The increase in maximum draw can cause additional maintenance and expense for power companies.

To recover these expenses, power companies bill more for high power use. They include charges for the maximum average power, or a ‘demand’ charge. They also designate high use periods as ‘on-peak’ and bill increased rates for energy and power. In the end, high loads are expensive for both power providers and transit authorities and can make large-scale bus charging cost prohibitive.

One approach to managing charge costs, is to plan when and how much power will be drawn. However, developing charge plans is complex and must work around route schedules, account for charge time, ensure sufficient battery charge, and consider differences between operation and offline hours. In short, the solution must consider all aspects of the bus’s day to day activities.

When a bus starts the day, it has a route and schedule assigned which tells the bus operator where to be and when to be there. Throughout the day, the bus returns to the hub to pick up passengers and recharge.

Because the number of fast-chargers is limited, a bus may only charge if a charger is available and must leave on route as scheduled. Furthermore, because batteries may require several hours for a full charge, they may not have time finish. Lower charge rates may also be used for less power draw which further delays charge times.

At the end of operation hours, each bus is stored in the bus depot and connected to a ‘slow’ charger. Slow-charging is preferable when possible because it draws less instantaneous

power and prolongs battery life [9]. Furthermore, charging during off-hours offers each bus the opportunity to charge at any time with no contention for charging resources.

II. LITERATURE REVIEW

We acknowledge the existance of additional contributions, such as minimizing costs for startup infrastructure [17], and preserving battery lifespan [9]. However, as these are not relevent to this work, we consider them outside the scope of this review. We further acknowledge that some works cited herein contain solutions to several of these problems, such as in [20], but for sake of organization, we list them in the most relevent context.

A. Battery Charging

Here we consider solutions to empty batteries and focus our attention on either battery replacement or charging methods. We also refer to charging methods as either static (at rest) or dynamic (in motion).

Because charge times can significantly complicate logistics, [19] and [11] give methods for exchanging spent with charged batteries. The benefits include minimal down time as refueling can occur in a matter of minutes. Unfortunately, batteries can be cumbersome, and their exchange can be difficult. It also requires specialized tools, and could require automation.

Another alternative is to inductively charge buses while they traverse their routes [2], [11], [12], [5]. Unfortunately, this requires significant infrastructure which may not be available and is cost prohibitive for large systems.

Alternative solutions tend towards optimal planning. This allows for buses to charge in the traditional sense, minimizes additional infrastructure, and avoids the complexities of exchanging batteries. These approaches generally fall into one of three categories; reactive, hybrid, and global.

Reactive planning focuses strictly on presential circumstances. Methods of this type are computationally efficient, run in real-time, and are adaptable. These techniques generally stem from control theory and minipulate a current state to minimize cost. One such example includes the work done by [4], who uses comparable methodology to reduce demand on the power grid. This methodology however, does not account for global phenomena that require broader planning schemes and for the most part this class of techniqies remain unused for bus charging.

Another class of algorithms encompasses a limited number of projected events to improve decision making. This allows for a middle ground between simplicity and global planning and has proven useful in previous work [10], [1].

Global planning algorithms assume complete foreknowledge of future events and provide globally optimal plans

[18],[7]. This class of algorithm requires more computation and is less flexible than reactive or hybrid approaches. However, the solutions are globally optimal and derive from insight unavailable to other algorithm classes.

B. Cost Management

The final set of constraints aim to decrease load on the grid. Previous work has shown that the use of electric buses can significantly complicate local power management [3] [6]. Additionally, power demand generally increases the fiscal cost from a billing perspective. [8] has provided methodology for forecasting the load on the grid. These types of models often form the basis for power distribution algorithms. For example, [15] gives an approach to minimize grid demand, but requires foreknowledge of uncontrolled loads. [4] takes a different approach and observes real-time data to control the charge rates of connected buses. [13] also operates in the real-time sense but uses on-board batteries to mitigate the effects of rapid charging.

III. GRAPH INFO

– this line needs to be more descriptive: i.e. Representation of problem with graphs ;subjects need to be nouns ;talk about how graphs relate to the problem at hand, this section talks about graphs because... we use graphs to encode bus availability, and edges to encode different charge rates; ;'this' needs to be more specific; ;the first paragraph is too compressed. Need to explain things more concisely and define terms before I use them; ;potential order for information: - to be done in another section where we describe the problem formulation 1. buses (battery, SOC) and routes 2. station, depot charging, and availability 3. constraints: a. charge time b. schedule, availability c. service (battery cannot reach 0 while on route) 4. costs a. energy b. power c. rates 5. don't refer to Rocky Mountain Power, refer to 'billing utility'. and UTA as the 'transit authority' a. billing utility i. wants to delay infrastructure upgrades ii. this is done by managing peak load b. transit authority i. wants to minimize costs problem formulation (to be included in the introduction): 1. buses, battery SOC, and routes 2. station, depot charges, availability 3. constraints a. charge time b. schedule and availability c. service (battery cannot reach 0 while on route) 4. costs a. uta: minimize fiscal costs associated with energy usage, power consumption, and time of day b. RMP: delay infrastructure upgrades by managing peak load 5. our approach ... a. uses directed graph to encode i. time -left to right layout of graph ii. bus availability - layers of nodes, or sets of nodes iii. charger - bus assignment - edges (binary var. on those edges) iv. charge rate (edges) v. day vs night charging (connecting multiple graphs) vi. energy cost -; edges vii. nodes -; state of charge viii. talk about charge model ix. peak/off-peak/demand

6. move the list of contributions to the end of the literature review section

; This solution uses a graph to formulate constraints and describe bus availability. The graph represents a flow of chargers as they traverse a time-sequence of available buses. By activating graph edges, we imply a certain state associated




Fig. 1: A simple graph with two buses and six time intervals




Fig. 2: Network flow illustrating sources and sinks

with a number of chargers. Edges leading to active layers of the graph indicate that this charger is charging a bus where an active 'rest' layer gives an unused charger. The graph contains $n + 1$ layers, where n is the number of buses in the fleet. There is one layer for each bus as well as a 'rest' layer for non-charging elements.

nodes represent bus availability. A node for bus i at time j indicates bus i 's availability for charging at time j . In Figure 1, for example, both buses one and two are available at times two, three, five, and six, and unavailable otherwise. Note how the zeroth element always has nodes. This is consistent with an ever-present no-charge option.

Edges represent potential actions to be done between time indices and represent one of three actions: mount, charge, or dismount (see figure 4). A mount action signals a bus to connect to a charger. A charge action causes a bus to charge, and a dismount to disconnect. A charge command must always be lead by a mount, and followed by either an additional charge or dismount command.

This type of directed graph can be represented using an incidence matrix, where the i,j th element refers to a connection between node i and edge j . This value is either positive or negative 1. A positive 1 implies an incoming edge whereas negative one indicates an outgoing edge. For example, the graph given in figure 3 would be described as:

$$\begin{bmatrix} -1 & 0 & -1 & 1 & 0 \\ 1 & -1 & 0 & 0 & 0 \\ 0 & 0 & 0 & -1 & -1 \\ 0 & 1 & 1 & 0 & 1 \end{bmatrix} \quad (1)$$




Fig. 3: A generic directed graph consisting of nodes and edges




Fig. 4: Mount, Dismount, and Charge Edges

If we let x be a vector representing the number of chargers occupying any one edge and A be an adjacency matrix, then the total ‘flow’ for each node can be expressed as

$$\text{flow} = Ax. \quad (2)$$

Because chargers are not consumed or produced during the day, the total flow for each node must be zero with the exception of *sources* and *sinks*. Sources are single nodes from which the first edges originate as shown in figure 2, and give a negative flow value equal to the number of chargers. A sink is converse, where the final edges terminate and maintains a corresponding positive flow value.

This relationship can be described in terms of a *flow constraint*:

$$Ax = \begin{bmatrix} 0 \\ \vdots \\ -n\text{Charger} \\ \vdots \\ 0 \\ n\text{Charger} \\ \vdots \\ 0 \end{bmatrix} \quad (3)$$

We also assume that a bus will only charge once before departing for the next route, and that one charger can only service one bus at a time. This constraint is described as a *group constraint*, where groups are collections of nodes for a single bus that describe continuous time at the hub (see




Fig. 5: Example of groups in a network flow graph




Fig. 6: Mount edge example for groups

figure 5) This behavior is described in terms of an inequality constraint

$$Bx \leq \begin{bmatrix} 1 \\ 1 \\ \vdots \\ 1 \end{bmatrix}, \quad (4)$$

where x is a matrix giving the number of chargers traversing an edge, and B describes all mount edges (see figure 4) corresponding to the same group. In B , the i,j th value is one if the j th edge mounts to the i th group. For example, the graph given in figure 6 would have the following group constraints:

$$B = \begin{bmatrix} 0 & 0 & 0 & 0 & 0 & 0 & 1 & 0 & 0 & 1 & 0 & 0 & 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 0 & 1 & 0 & 0 & 1 & 0 \end{bmatrix} \quad (5)$$

IV. MULTI-GRAPH ADDITIONS

An additional contribution this work offers is the expansion to night vs day charging. During the night, there is one charger for each bus; each with a single charge rate. During this time, buses are also available to charge at any time. These differences in operations introduce changes to the original graph formation and warrant a separate graph.

Night graphs consider a situation where both the number of buses reflect the number of chargers and buses are readily available. Note how there are several source and sink nodes in figure 7. When a bus deploys for the day, the available number of charges changes and are reflected in the underlying source and sink constraints.

Changes in the first graph are reflected in the second through use of state of charge variables.




Fig. 7: Night vs Day Graphs




Fig. 8: SOC indicators




Fig. 9: Depiction of which edges increase SOC for the single rate case

V. BATTERY STATE OF CHARGE

The state of charge (SOC) is influenced in three ways; initial conditions, discharge events, and traversing charge nodes (as shown in figure 4). There are SOC variables for each node representing an available bus, where the SOC value for the i th bus at SOC index j is denoted as $d_{i,j}$ as shown in figure 8. Note, there only needs be SOC variables for time indices where buses are available to charge and $d_{i,j}$ does not generally correspond to the charge at *time interval* j . All other timesteps are deterministic and need not be computed.

When charging, the change in SOC associated with the i th bus at the j th charge edge is denoted $g_{i,j}$. Again, note that j is *not* indicative of a time interval, rather it gives the *index* of the *charge edge* in use as shown in figure 9.

An additional contribution this paper gives is the addition of multi-rate charging. This adapts the basic methodology to incorporate additional charge edges and $g_{i,j}$ variables. Under this methodology, the graph given in figure 5 would




Fig. 10: Multi-Rate Charging

be modified to reflect figure 10, where $g_{i,j,k}$ represents the i th bus at charge instance j and charge rate k .

To model the effect of charging on a battery state of charge, we adopt the Constant Current Constant Voltage (CCCV) model as derived in [18] which gives

$$s_{k+1} = \bar{a}_l s_k - \bar{b}_l M \quad (6)$$

Where s_k is the charge of a battery at time k , \bar{a}_l is a charge rate dependent, experimentally determined value, $\bar{b}_l = \bar{a}_l - 1$, and M is the maximum capacity of the battery in kWh.

Recall how g represented the change in state of charge of the battery in kWh. This allows us to express s_{k+1} in terms of

$$s_{k+1} = s_k + g_{\pi_g(m,k,l)} \quad (7)$$

where $\pi_g(m,k,l)$ represents the index of g for bus m at time index k for charge rate l . These two equations imply that

$$\begin{aligned} s_k + g_{\pi_g(m,k,l)} &= \bar{a}_l s_k - \bar{b}_l M \\ \Rightarrow g_{\pi_g(m,k,l)} &= \bar{a}_l s_k - s_k - \bar{b}_l M \\ \Rightarrow g_{\pi_g(m,k,l)} &= s_k(\bar{a}_l - 1) - \bar{b}_l M. \end{aligned} \quad (8)$$

But the state of charges for bus m are given in terms of $d_{i,j}$. If we let $d_{i,j} = \pi_d(i,k,l)$, then the final expression for g becomes

$$g_{\pi_g(m,k,l)} = d_{\pi_d(m,k,l)}(\bar{a}_l - 1) - \bar{b}_l M. \quad (9)$$

Note, 9 is only valid when the bus is charging and must be tempered with additional constraints to account for the non-charging case.

To handle the two cases, we express the cases for charging (equation 9 and non-charging ($g = 0$) as

$$\begin{aligned} g_{\pi_g(m,k,l)} &= d_{\pi_d(m,k,l)}(\bar{a}_l - 1) - \bar{b}_l M \\ g_{\pi_g(m,k,l)} &= 0. \end{aligned} \quad (10)$$

which also implies that

$$\begin{aligned} g_{\pi_g(m,k,l)} &\leq d_{\pi_d(m,k,l)}(\bar{a}_l - 1) - \bar{b}_l M \\ g_{\pi_g(m,k,l)} &\geq d_{\pi_d(m,k,l)}(\bar{a}_l - 1) - \bar{b}_l M \\ g_{\pi_g(m,k,l)} &\leq 0 \\ g_{\pi_g(m,k,l)} &\geq 0. \end{aligned} \quad (11)$$

Next, let $x_{\pi_x(m,k,l)}$ be the index of the edge corresponding to $g_{\pi_g(m,k,l)}$. A switch between the two constraints expressed in equation 11 can be constructed using the *big M* technique. This modifies equation 11 such that

$$\begin{aligned} g_{\pi_g(m,k,l)} &\leq d_{\pi_d(m,k,l)}(\bar{a}_l - 1) - \bar{b}_l M - M(1 - x_{\pi_x(m,k,l)}) \\ g_{\pi_g(m,k,l)} &\geq d_{\pi_d(m,k,l)}(\bar{a}_l - 1) - \bar{b}_l M \\ g_{\pi_g(m,k,l)} &\leq 0 + Mx_{\pi_x(m,k,l)} \\ g_{\pi_g(m,k,l)} &\geq 0. \end{aligned} \quad (12)$$

Note that as expressed, when the charge edge is active (i.e. $x_{\pi_x(m,k,l)} = 1$), then

$$\begin{aligned} g_{\pi_g(m,k,l)} &\leq d_{\pi_d(m,k,l)}(\bar{a}_l - 1) - \bar{b}_l M \\ g_{\pi_g(m,k,l)} &\geq d_{\pi_d(m,k,l)}(\bar{a}_l - 1) - \bar{b}_l M \\ g_{\pi_g(m,k,l)} &\leq M \\ g_{\pi_g(m,k,l)} &\geq 0. \end{aligned} \quad (13)$$

But as g can never exceed the charge capacity of the battery, the bottom two constraints are inactive and g is both less than or greater than equation 9, making it equal. When the edge is inactive, or $x_{\pi_x(m,k,l)} = 0$, equation 12 becomes

$$\begin{aligned} g_{\pi_g(m,k,l)} &\leq d_{\pi_d(m,k,l)}(\bar{a}_l - 1) - \bar{b}_l M - M \\ g_{\pi_g(m,k,l)} &\geq d_{\pi_d(m,k,l)}(\bar{a}_l - 1) - \bar{b}_l M \\ g_{\pi_g(m,k,l)} &\leq 0 \\ g_{\pi_g(m,k,l)} &\geq 0. \end{aligned} \quad (14)$$

where the top two constraints become inactive and g is both less than and greater than 0, making it equal. Hence, these constraints can be expressed in linear form as

$$\begin{aligned} -g_{m,k,l} + d_{m,k,l}(\bar{a}_l - 1) + x_{m,k,l} &\leq M(\bar{b}_l + 1) \\ g_{m,k,l} - d_{m,k,l}(\bar{a}_l - 1) &\leq -\bar{b}_l M \\ g_{m,k,l} - Mx_{m,k,l} &\leq 0 \\ -g_{m,k,l} &\leq 0. \end{aligned} \quad (15)$$

The constraints for state of charge are circumstantially dependent. Each $d_{m,k,l}$ must be defined by a set of constraints which are defined by either initial conditions, previous graphs, route discharge, or $g_{m,k,l}$ variables.

Initial conditions and previous graphs are straight forward. Initial conditions are given as an equality constraint. For example, if d_0 was initialized to 80 kWh, the constraint would be $d_0 = 80$. To initialize to the value of a previous graph, use an equality constraint.

Suppose we modeled early morning and day-time operations and had two corresponding graphs. The final node of graph one would be equivalent to the first node of graph two in the temporal sense and the corresponding $d_{m,l,k}$ values would also be equated as $d_{\text{Graph 1}} - d_{\text{Graph 2}} = 0$.




Fig. 11: δ values for routes

$d_{m,l,k}$ values corresponding to available charge times are expressed as a sum of $g_{m,k,l}$ values given in equation 15 such that

$$d_{m,k+1} = d_{m,k} + \sum_l g_{m,k,l}$$

or as given in linear form,

$$d_{m,k+1} - d_{m,k} - \sum_l g_{m,k,l} = 0. \quad (16)$$

The final case deals with battery discharge over a route. As seen in figure 11, discharge values, also referred to as δ represent the power expenditure over a route. This expenditure is modeled as a withdrawal from the reservoir in a battery and was calibrated from data received from the Utah Transit Authority. In figure 11, the SOC constraints corresponding to δ_1 would be as follow:

$$d_{1,3} = d_{1,2} - \delta_1$$

or in linear form,

$$d_{1,2} - d_{1,3} = \delta_1. \quad (17)$$

VI. FISCAL RATE SCHEDULE

One objective of this work is to minimize the fiscal cost associated with power use and uses the Rocky Mountain Power schedule 8 billing rates. This billing schedule includes an on-peak power charge, facilities charge, and both on and off peak energy charges.

The facilities charge is computed by calculating the average power over a 15 minute period. The facilities charge is based on the maximum average value over the course of the month. This section of the bill charges \$4.81 per kW. The On-Peak Power Charge is similarly calculated but only includes average values from designated on-peak hours. Rocky Mountain Power charges \$15.73 per kW for this value.

the facilities power can be formulated as a linear set of constraints that include power used at each timestep for charging buses and external loads. This can be expressed as

$$c_i = \sum_j g_{i,j} + p_i$$

Where c_i represents the

The energy charges are billed per kWh and charge for each unit of energy used. There are two rates: 5.8282¢ for energy consumed during on-peak hours, and 2.6316¢ for off-peak hours. general introduction with details for demand and consumption charge and how these relate to the end-of-the-month billing.

a. external loads (contribution) b. consumption charge i. total energy in Kwh ii. on-peak vs off-peak iii. constraints for consumption charge c. demand charge i. average power in 15 minute window ii. on-peak vs facilities iii. constraints for on-peak and facilities charges d. total cost breakdown i. Show how Rocky Mountain Power uses these and what the cost weighting is.

VII. BUS FLEET OPERATIONS

Overview of bus operations during the day vs the night a. night environment i. one charger per bus ii. slow chargers iii. single rate chargers iv. buses always available b. day environment i. limited number of chargers ii. fast/variable rates iii. limited charging availability c. multiple graphs to incorporate day vs night charging i. show picture to illustrate this ii. show SOC constraints to implement these relationships

VIII. OBJECTIVE FUNCTION

IX. GUROBI & USAGE

X. RESULTS

XI. FUTURE WORK

REFERENCES

- [1] Avishan Bagherinezhad et al. "Spatio-Temporal Electric Bus Charging Optimization With Transit Network Constraints". In: *IEEE Transactions on Industry Applications* 56.5 (Sept. 2020), pp. 5741–5749. ISSN: 0093-9994, 1939-9367. DOI: 10.1109/TIA.2020.2979132. URL: <https://ieeexplore.ieee.org/document/9028116/> (visited on 11/13/2021).
- [2] Bhagyashree J Balde and Arghya Sardar. "Electric Road system With Dynamic Wireless charging of Electric buses". In: *2019 IEEE Transportation Electrification Conference (ITEC-India)*. 2019 IEEE Transportation Electrification Conference (ITEC-India). Bengaluru, India: IEEE, Dec. 2019, pp. 1–4. ISBN: 978-1-72813-169-6. DOI: 10.1109/ITEC-India48457.2019.ITECINDIA2019-251. URL: <https://ieeexplore.ieee.org/document/9080859/> (visited on 11/18/2021).
- [3] T. Boonraksa et al. "Impact of Electric Bus Charging on the Power Distribution System a Case Study IEEE 33 Bus Test System". In: *2019 IEEE PES GTD Grand International Conference and Exposition Asia (GTD Asia)*. 2019 IEEE PES GTD Grand International Conference and Exposition Asia (GTD Asia). Bangkok, Thailand: IEEE, Mar. 2019, pp. 819–823. ISBN: 978-1-5386-7434-5. DOI: 10.1109/GTDAsia.2019.8716023. URL: <https://ieeexplore.ieee.org/document/8716023/> (visited on 11/13/2021).
- [4] Qifu Cheng et al. "A smart charging algorithm-based fast charging station with energy storage system-free". In: *CSEE Journal of Power and Energy Systems* (2020). ISSN: 20960042, 20960042. DOI: 10.17775/CSEJJPES.2020.00350. URL: <https://ieeexplore.ieee.org/stamp/stamp.jsp?tp=&arnumber=9171658> (visited on 11/19/2021).
- [5] Blint Csonka. "Optimization of Static and Dynamic Charging Infrastructure for Electric Buses". In: *Energies* 14.12 (June 13, 2021), p. 3516. ISSN: 1996-1073. DOI: 10.3390/en14123516. URL: <https://www.mdpi.com/1996-1073/14/12/3516> (visited on 11/13/2021).
- [6] Sanchari Deb, Karuna Kalita, and Pinakeshwar Mahanta. "Impact of electric vehicle charging stations on reliability of distribution network". In: *2017 International Conference on Technological Advancements in Power and Energy (TAP Energy)*. 2017 International Conference on Technological Advancements in Power and Energy (TAP Energy). Kollam: IEEE, Dec. 2017, pp. 1–6. ISBN: 978-1-5386-4021-0. DOI: 10.1109/TAPENERGY.2017.8397272. URL: <https://ieeexplore.ieee.org/document/8397272/> (visited on 11/16/2021).
- [7] Nader A. El-Taweel and Hany E. Z. Farag. "Incorporation of Battery Electric Buses in the Operation of Intercity Bus Services". In: *2019 IEEE Transportation Electrification Conference and Expo (ITEC)*. 2019 IEEE Transportation Electrification Conference and Expo (ITEC). Detroit, MI, USA: IEEE, June 2019, pp. 1–6. ISBN: 978-1-5386-9310-0. DOI: 10.1109/ITEC.2019.

8790598. URL: <https://ieeexplore.ieee.org/document/8790598/> (visited on 11/19/2021).
- [8] Qiang Gao et al. "Charging Load Forecasting of Electric Vehicle Based on Monte Carlo and Deep Learning". In: *2019 IEEE Sustainable Power and Energy Conference (iSPEC)*. 2019 IEEE Sustainable Power and Energy Conference (iSPEC). Beijing, China: IEEE, Nov. 2019, pp. 1309–1314. ISBN: 978-1-72814-930-1. DOI: 10.1109/iSPEC48194.2019.8975364. URL: <https://ieeexplore.ieee.org/document/8975364/> (visited on 11/19/2021).
- [9] Adnane Houbbadi et al. "Optimal Charging Strategy to Minimize Electricity Cost and Prolong Battery Life of Electric Bus Fleet". In: *2019 IEEE Vehicle Power and Propulsion Conference (VPPC)*. 2019 IEEE Vehicle Power and Propulsion Conference (VPPC). Hanoi, Vietnam: IEEE, Oct. 2019, pp. 1–6. ISBN: 978-1-72811-249-7. DOI: 10.1109/VPPC46532.2019.8952493. URL: <https://ieeexplore.ieee.org/document/8952493/> (visited on 11/13/2021).
- [10] Amra Jahic, Mina Eskander, and Detlef Schulz. "Pre-emptive vs. non-preemptive charging schedule for large-scale electric bus depots". In: *2019 IEEE PES Innovative Smart Grid Technologies Europe (ISGT-Europe)*. 2019 IEEE PES Innovative Smart Grid Technologies Europe (ISGT-Europe). Bucharest, Romania: IEEE, Sept. 2019, pp. 1–5. ISBN: 978-1-5386-8218-0. DOI: 10.1109/ISGTEurope.2019.8905633. URL: <https://ieeexplore.ieee.org/document/8905633/> (visited on 11/16/2021).
- [11] Shubham Jain et al. "Battery Swapping Technology". In: *2020 5th IEEE International Conference on Recent Advances and Innovations in Engineering (ICRAIE)*. 2020 5th IEEE International Conference on Recent Advances and Innovations in Engineering (ICRAIE). Jaipur, India: IEEE, Dec. 1, 2020, pp. 1–4. ISBN: 978-1-72818-867-6. DOI: 10.1109/ICRAIE51050.2020.9358366. URL: <https://ieeexplore.ieee.org/document/9358366/> (visited on 11/18/2021).
- [12] Seog Y. Jeong et al. "Automatic Current Control by Self-Inductance Variation for Dynamic Wireless EV Charging". In: *2018 IEEE PELS Workshop on Emerging Technologies: Wireless Power Transfer (Wow)*. 2018 IEEE PELS Workshop on Emerging Technologies: Wireless Power Transfer (WoW). Montral, QC, Canada: IEEE, June 2018, pp. 1–5. ISBN: 978-1-5386-2465-4. DOI: 10.1109/WoW.2018.8450926. URL: <https://ieeexplore.ieee.org/document/8450926/> (visited on 11/18/2021).
- [13] Inaki Ojer et al. "Development of energy management strategies for the sizing of a fast charging station for electric buses". In: *2020 IEEE International Conference on Environment and Electrical Engineering and 2020 IEEE Industrial and Commercial Power Systems Europe (EEEIC / I&CPS Europe)*. 2020 IEEE International Conference on Environment and Electrical Engineering and 2020 IEEE Industrial and Commercial Power Systems Europe (EEEIC / I&CPS Europe). Madrid, Spain: IEEE, June 2020, pp. 1–6. ISBN: 978-1-72817-455-6. DOI: 10.1109/EEEIC/ICPSEurope49358.2020.9160716. URL: <https://ieeexplore.ieee.org/document/9160716/> (visited on 11/16/2021).
- [14] Kavuri Poornesh, Kuzhivila Pannickottu Nivya, and K. Sireesha. "A Comparative study on Electric Vehicle and Internal Combustion Engine Vehicles". In: *2020 International Conference on Smart Electronics and Communication (ICOSEC)*. 2020 International Conference on Smart Electronics and Communication (ICOSEC). Trichy, India: IEEE, Sept. 2020, pp. 1179–1183. ISBN: 978-1-72815-461-9. DOI: 10.1109/ICOSEC49089.2020.9215386. URL: <https://ieeexplore.ieee.org/document/9215386/> (visited on 11/13/2021).
- [15] Nan Qin et al. "Numerical analysis of electric bus fast charging strategies for demand charge reduction". In: *Transportation Research Part A: Policy and Practice* 94 (Dec. 2016), pp. 386–396. ISSN: 09658564. DOI: 10.1016/j.tra.2016.09.014. URL: <https://linkinghub.elsevier.com/retrieve/pii/S096585641630444X> (visited on 11/13/2021).
- [16] Daniel Stahleder et al. "Impact Assessment of High Power Electric Bus Charging on Urban Distribution Grids". In: *IECON 2019 - 45th Annual Conference of the IEEE Industrial Electronics Society*. IECON 2019 - 45th Annual Conference of the IEEE Industrial Electronics Society. Lisbon, Portugal: IEEE, Oct. 2019, pp. 4304–4309. ISBN: 978-1-72814-878-6. DOI: 10.1109/IECON.2019.8927526. URL: <https://ieeexplore.ieee.org/document/8927526/> (visited on 11/16/2021).
- [17] Ran Wei et al. "Optimizing the spatio-temporal deployment of battery electric bus system". In: *Journal of Transport Geography* 68 (Apr. 2018), pp. 160–168. ISSN: 09666923. DOI: 10.1016/j.jtrangeo.2018.03.013. URL: <https://linkinghub.elsevier.com/retrieve/pii/S0966692317306294> (visited on 11/13/2021).
- [18] Justin Whitaker et al. "A Network Flow Approach to Battery Electric Bus Scheduling". In: (2021), p. 10.
- [19] Xian Zhang and Guibin Wang. "Optimal dispatch of electric vehicle batteries between battery swapping stations and charging stations". In: *2016 IEEE Power and Energy Society General Meeting (PESGM)*. 2016 IEEE Power and Energy Society General Meeting (PESGM). Boston, MA, USA: IEEE, July 2016, pp. 1–5. ISBN: 978-1-5090-4168-8. DOI: 10.1109/PESGM.2016.7741893. URL: <http://ieeexplore.ieee.org/document/7741893/> (visited on 11/18/2021).
- [20] Dan Zhou et al. "Optimization Method of Fast Charging Buses Charging Strategy for Complex Operating Environment". In: *2018 2nd IEEE Conference on Energy Internet and Energy System Integration (EI2)*. 2018 2nd IEEE Conference on Energy Internet and Energy System Integration (EI2). Beijing: IEEE, Oct. 2018, pp. 1–6. ISBN: 978-1-5386-8549-5. DOI: 10.1109/EI2.2018.8582378. URL: <https://ieeexplore.ieee.org/document/8582378/> (visited on 11/13/2021).