

Information Panel Displays for Virgo Operations

Authors: D. Sentenac, A. Pasqualetti, L. Francescon

This document describes the wall-mounted information panels and the rack-mounted touchscreens deployed across the Virgo site to give operators, shift personnel and visiting staff a real-time view of the detector environment (O₂, vacuum, lasers, particle counters). It does not define any safety procedure: it explains what each panel shows, where it is installed and how to read its indicators, so that the information presented on screen is unambiguous to every user.

Information panels are large wall-mounted **read-only** displays that expose the current state of the Virgo detector to operators and visiting staff. Two panel families are in use:

- a **global Control Room panel**, and
- the **local building panels** (Central Building, West End, North End, and a dedicated panel for the 1500W clean room).

A separate, smaller family of **touchscreen** displays is mounted in each fixed particle-counting rack and is used to adjust counter settings locally. (see Section 7.2).

Each variant exposes the slice of information relevant to its physical location.

1. Global Control Room panel

Location: a single instance, installed in the Virgo Control Room.

Scope: the entire site (Central Building, North End, West End) in a single view. From left to right the layout is:

Pane	Content
O ₂ Sensors	CB / NE / WE controllers, building alarms, and per-zone %O ₂ readings
Laser Beams – CB	Optical path through the interferometer (WEST – BS – SR – DET – IB – MC – PR – WI – NI – NORTH – SQZ, with the SDT2, SQB1/SQB2, SPRB, FCIN/FCEND sub-elements) plus the CO ₂ NI/WI sources, the SQZ Yag and SQZ Green sources, the main Yag and main Green sources
Vacuum Monitoring	Pressure gauges and valve states along the main tubes
Particle Monitoring – CB and Mobile	Six size buckets (0.3 / 0.5 / 1 / 2.5 / 5 / 10 µm) for every fixed and mobile particle counter
Laser Beams – NE / WE	Each end terminal, its near-tower sources (Source Green and Source PCAL per end, SNEB / SWEB indicators) and the tube toward the Central Building

Pane	Content
Legend	Icon meanings (see Section 6)

Because the Control Room panel is the only one that combines all three buildings side-by-side, it is the reference display for any cross-building decision (starting/stopping a laser source, opening/closing a sector valve, etc.).




Figure 1 — Global Control Room panel: O₂ sensors for CB/NE/WE, Laser Beams CB diagram, Vacuum Monitoring, and the NE / WE end-building sub-diagrams.

Note: the same view rendered on the global Control Room panel is also accessible directly at <http://olserver134.virgo.infn.it:8081/controlroom/>, from any device.

2. Central Building local panels

Location: several panels are disseminated through the Central Building:

- one at the **CB entrance**,
- one in the **clean-room area** (Clean SAS),
- one in the **Clean room in the baseroom**, below the tower entrance level,
- one in the **Preparation and Washing Room** at the basement level.

Scope: everything that is useful to someone physically working in CB without having to call the Control Room. The layout reuses the same widgets as the Control Room panel but trims it to the local context:

- O₂ sensors **status and location in the Central Building**;
- Laser Beams **activity status in the Central Building**;
- Vacuum Monitoring is shown **globally**;
- Particle Monitoring shows the **eight CB clean-room counters** (Injection Lab, Baseroom Clean Room, Detection Lab, Main Hall, Mirror Clean Room, Payload Clean Room, SAS Clean Room, SAS Detection Lab) plus the three Mobile counters.

These panels make it possible, for example, to verify a vacuum alarm at the entrance of CB before entering, to read the O₂ level of a specific zone before opening a chamber, or to check the particle levels before / after entering any clean room.




Figure 2 — Central Building local panel: CB-only O₂ sensors and Laser Beams diagram, Vacuum Monitoring for the CB tubes, the eight CB fixed particle counters, the three Mobile particle counters, and the icon legend.

3. End-building local panels

Location: one panel per end, each placed in the **entrance SAS** of the building (West End and North End).

Scope: identical role to the CB panels but restricted to the local end:

- the WE panel shows WE O₂ sensors, the WE laser-beam diagram (WE Source Green, WE Source PCAL, SWEB, tube toward CB), the WE particle counters in the WE clean rooms, and the WE side of the vacuum tube;
- the NE panel is the symmetric for the North End (NE Source Green, NE Source PCAL, SNEB, NE clean rooms, NE tube).

They are the first display a person sees when entering the building, and therefore carry the safety-critical O₂ alarm summary, and include the Detector Monitoring System (DMS) for global alarm information.




Figure 3 — West End local panel: WE O₂ sensors, WE Laser Beams diagram (Source Green, SWEB, tube toward CB), WE vacuum monitoring and the WE clean-room particle counters.




Figure 4 — North End local panel: NE O₂ sensors, NE Laser Beams diagram (Source Green, SNEB, tube toward CB), NE vacuum monitoring and the NE clean-room particle counters.

4. 1500W clean-room local panel

Location: one panel installed in the **1500W clean-room facility**, the auxiliary cleanroom hosting the Payload, Fiber, SAS and SQZ-laboratory preparation areas.

Scope: the information reported on this panel covers two complementary aspects:

- **Particle counting in the 1500W clean rooms** — a dedicated Particle Monitoring pane shows the four fixed counters of the 1500W facility (*Payload L.*, *Fiber L.*, *Clean R.*, *SAS*, *SQZ Lab.*), alongside the three Mobile counters shared with the other panels.
- **WE tower laser beams** — the WE-side O₂ sensors, WE laser-beam diagram and WE vacuum tube are reproduced exactly as on the WE end-building panel (see Section 3), so that personnel working in the 1500W cleanroom has the same situational awareness as the

operator entering the WE building.



Figure 5 — 1500W clean-room panel: WE O_2 sensors and WE Laser Beams diagram (same as the WE panel), WE vacuum monitoring, plus the dedicated 1500W Particle Monitoring pane (Payload L., Fiber L., Clean R. SAS, SQZ Lab.) and the shared Mobile particle counters.

5. Oxygen sensors

Each building is equipped with a network of O_2 sensors that continuously monitor the local oxygen concentration. The panels display, in real time, the % O_2 reading of every sensor together with its health status, so that an expert can spot a faulty channel at a glance and plan a replacement.

Naming conventions

- In the **Central Building** the sensors are grouped by **zones** (Zone A , Zone B , ..., Zone G , plus the Clean Room) and an additional height suffix (60 , 120 , 170 for the elevation in cm above the floor). Each zone label is also drawn on the Laser Beams – CB diagram, so an operator can immediately associate a reading with the physical area. The interferometer is divided exactly along these zones (ZONE A – ZONE G in CB, plus the ZONE A (EXT. TANK) label inside the laser room), and each zone is associated with the corresponding set of O_2 sensors.
- In the **end buildings (NE and WE)** the sensors are referenced by their **functional location** (Tower DX , Tower SX , Base Room , Tunnel , Tunnel Door , Clean Room , each in two height variants).

Alarm levels and sensor health (common to all panels)

The following status icons are used for O_2 sensors. Three alarm levels are reported in the legend as colour-coded discs: “Sensor O_2 Alarm 1” (yellow), “Sensor O_2 Alarm 2” (orange) and “Sensor O_2 Alarm 3” (red). Two additional states cover the sensor health: “Sensor O_2 Off” (grey) for a sensor that is not powered, and “Sensor O_2 Reset” (light pink) for a sensor that has just been acknowledged.

Building-level alert

A **general alert per building** (CB, NE, WE) is computed by combining all the local sensors with thresholds set by the safety experts. These alarms are reported in various locations (CB, NE, WE, Control Room). They are also used for the Detector Monitoring System (DMS).

Sensor health and lifetime

Industrial O₂ sensing cells have a finite lifetime of about **18 months**. When a cell drifts out of specification or stops responding, the panel shows the corresponding sensor in the **Sensor O₂ Off** (grey) or **Sensor O₂ Reset** (light pink) state. This is the cue the experts use to schedule a replacement before the affected zone loses coverage.

6. Laser-beam information

The Laser Beams diagram is the new central information and operations widget. It is a schematic of the optical path going through each vacuum element drawn as a labelled tile (cryotrap, towers, minitowers, sector valves). Around each tile, small status icons report the live state of the equipment driving the beam through that section. Colour codes are uniform across the three buildings.

Per-element indicators

- **Source location:** every laser source is drawn on the diagram as a **coloured rectangle** that hosts the source's status glyphs inside it — a coloured disc (Yag / Green / CO₂) and/or a shutter icon. The position of the rectangle itself identifies *where* the source is physically located on the layout, while the disc and shutter inside report the live status of that source (typically **ON** and/or **SHUTTERED**, plus the off / unknown variants described below). This makes the source tile a single self-contained widget combining identity, position and state.
- **Sector valve:** orange/brown arrow pair – pointing outward = *Valve Open*, pointing inward (green) = *Valve Close*.
- **Yag laser:** filled red disc = *Yag On*, grey disc = *Yag Off* (main Yag, SQZ Yag, and per-tower variants share the same colour key).
- **Yag shutter:** red shutter glyph open / grey closed.
- **Green laser:** green disc on / grey off. The Source Green disc reports **lasing only** (photodiode above threshold), independently of the shutter.
- **Green shutter:** green shutter glyph open / grey closed (release flag **1** = open, **0** = closed). Source disc and shutter glyph are independent; the beam reaches the towers only when **both** are green (see Section 6.1).
- **PCAL laser** (1047 Hz, NE / WE only): orange disc = *PCAL On*, grey disc with orange outline = *PCAL Off*. The disc is orange when the laser is **on or enabled** (a cross-check of two channels), grey only when both are zero. Drawn twice per end diagram — a Source PCAL disc and a tower PCAL disc; the tower disc mirrors the source state (see Section 6.1).
- **CO₂ heating** (used at NI, WI): yellow disc on / grey off; the corresponding shutter has its own open/closed glyph. As for the Green lasers, the Source CO₂ disc and the shutter glyph are independent, and the tower CO₂ disc lights only when the source is **ON and** the viewport shutter is open.
- **F0+F7 current:** red square = energised, grey square = off.

6.1 Channels and thresholds

The source / shutter indicators are not driven by simple booleans; each one aggregates one or more raw channels and applies a fixed threshold. Per-tower Yag / Green tiles inside each diagram are **propagated** through the optical topology (across the valves) from the **injected beam** — the source must be lasing **and** its shutter open — so a tile turns off as soon as its source stops, its shutter closes, or any valve on its path closes. Source discs and shutter glyphs remain independent indicators: a lasing but shuttered source shows a green disc with a closed (grey) shutter, and no tower lights up.

After discussion with the Injection, Squeezing, Payload and TCS teams, the laser beams that shall be **switched off and/or shuttered** to ensure complete safety for the operators during interventions were identified. Laser-beam power is given by fast-acquisition photodiodes at the source level: the **MAX** value of the photodiode signal is computed and compared to a limit threshold indicating that the laser is considered **OFF** by the sub-system experts.

Yag main source (CB)

Channel	Role
INJ_EIB_POUT_PD_MAX	Injector output PD
BsX_QF_DC_MAX	BS quad-far DC
BsX_QN_DC_MAX	BS quad-near DC

Rule: $S = \text{sum of the three values}$; $S \geq 0.1 \text{ V} \rightarrow \text{ON}$, $S < 0.1 \text{ V} \rightarrow \text{OFF}$.

Green main sources (WE / NE)

Source	Photodiode channel	Shutter channel
WE	ALS_WEB_PD_GREEN_MONI_CALI_MEAN	ALS_WEB_REL1
NE	ALS_NEB_PD_GREEN_MONI_CALI_MEAN	ALS_NEB_REL1

Rule: the Source Green disc is **ON** if $\text{PD} \geq 1.0$ (lasing, regardless of the shutter). The shutter glyph reads the release flag: $\text{REL} = 1 \rightarrow \text{OPEN}$, $\text{REL} = 0 \rightarrow \text{CLOSED}$. The beam injected into the vacuum — which seeds the tower propagation — is present only when $\text{PD} \geq 1.0$ AND $\text{REL} = 1$.

PCAL sources (NE / WE) — photon-calibrator laser (1047 Hz)

Source	Channels (laser on / laser enabled)
NE	PCAL_NE_laser_on_20kHz_50Hz_MAX / PCAL_NE_laser_enbl_20kHz_MAX
WE	PCAL_WE_laser_on_20kHz_50Hz_MAX / PCAL_WE_laser_enbl_20kHz_MAX

Rule: each end carries two 0/1 flags — laser on and laser enabled — combined as a cross-check: if *either* flag is non-zero the disc is **ON** (orange), and only when *both* are zero is it **OFF** (grey). The **_MAX** aggregate of each flag is used — the hazard-conservative choice for an on/off flag. The tower PCAL disc reads the same channels as the Source PCAL disc, so both light together — no valve propagation is applied to the PCAL beam.

CO₂ sources (WI / NI)

Source	Channels
WI	TCS_WI_CO2_CH_PWRLAS_MEAN , TCS_WI_CO2_PWRLAS_MEAN
NI	TCS_NI_CO2_CH_PWRLAS_MEAN , TCS_NI_CO2_PWRLAS_MEAN

Rule: ON if any channel reads $> 20 \text{ V}$ (test-bench threshold; the original Virgo specification was $0.1 \text{ V} / \sim 10 \text{ mW}$).

CO₂ shutters

Shutter	Shutter relay channels
WI	TCS_CO2_REL1 , TCS_CO2_REL2 , TCS_CO2_REL3
NI	TCS_CO2_REL5 , TCS_CO2_REL6 , TCS_CO2_REL7

Rule: all relays 0 → CLOSED; any relay non-zero → OPEN.

The WI / NI **tower** CO₂ discs combine the two tables above: they light only when the CO₂ source is ON **and** its viewport shutter is OPEN (the CO₂ lasers are installed at the towers themselves, so no valve propagation is involved). The Source CO₂ disc and the shutter glyph stay independent.

SQZ Green source (CB)

Channel	Threshold
SQZ_SHG_Lock_Status_MAX	$< 5.0 \rightarrow$ ON (SHG locked); otherwise OFF

Note: Yag propagation through the ITF is **not** considered for the SQZ chain because the residual Yag power leaking from the squeezer toward the interferometer is negligible (order of microwatts).

SQZ Yag fast shutter (CB) – also gates the SQZ Yag propagation

Channel	Threshold
EQB1_FAST_SHUTTER_MONI_MAX	$> 1.0 \rightarrow$ CLOSED (Yag OFF); $\leq 1.0 \rightarrow$ OPEN (Yag ON)

Local-control F0+F7 (per tower)

Tower	F0 enable	F7 on
NI / WI / BS / PR / SR	SAT_<T>_F0_DC_ENBL	SAT_<T>_F7_DC_ON
IB / MC	SAT_<T>_F0_DC_ENBL	(no F7 wired)
DET	SAT_0B_F0_DC_ENBL	(no F7 wired)

Rule: any channel reading 1 → ON (red square); all known channels 0 → OFF (grey square); unknown otherwise.

Note: these signals are exposed on the panel to inform the operator that the suspension is in a safe condition (F0 enabled and / or F7 active), so that local interventions on the tower can be carried out without risk of moving the payload.

Sector / cryo valves (drive both the diagram glyphs and the Yag / Green propagation)

Group	Channels
SQZ chain	VAC_SQZ300N_VPST , VAC_SQZ0N_VPST , VAC_SQZDET2_VPST , VAC_SQZDET1_VPST
Big sector	VAC_VALVEBIGNI_ST , VAC_VALVEBIGWI_ST
Central manifold	VAC_VALVECENTRAL_VLIST , VAC_VALVECENTRAL_VNSST , VAC_VALVECENTRAL_VWSST , VAC_VALVECENTRAL_VPSST , VAC_VALVECENTRAL_VSSST
Cryotrap	VAC_CRY0NI_VCRY0ST , VAC_CRY0WI_VCRY0ST
Cryo-link	VAC_CRYOLINKIB_Vs1 , VAC_CRYOLINKIB_Vs2 , VAC_CRYOLINKDET_Vs1 , VAC_CRYOLINKDET_Vs2
End valves (propagation only, not rendered on CB)	VAC_VALVEBIGWE_ST , VAC_CRY0WE_VCRY0ST , VAC_VALVEBIGNE_ST , VAC_CRYONE_VCRY0ST

Each valve channel uses the standard VPST / ST convention from the vacuum SCADA: 1 → OPEN (orange “valve open” glyph), 0 → CLOSED (green “valve close” glyph), any other code → unknown grey.

Note: both the **Cryo-link** valves and the **SQZ chain** valves are optically **transparent to the beams** even when CLOSED — they are fitted with a viewport, so they isolate the vacuum sectors without interrupting the Yag or Green propagation. They are reported on the diagram for vacuum-state awareness only and are skipped by the laser-propagation logic.

7. Particle counting

The Virgo clean rooms are continuously sampled by stationary particle counters that report six size buckets (0.3 / 0.5 / 1 / 2.5 / 5 / 10 µm). On the panels the readings are displayed as **absolute values** per size. A **threshold for each size class** can be set on the rack display and is managed by the clean-team experts. The bar associated with each value is green when the reading is below threshold, yellow / red when the limit for that size class is exceeded. An alarm associated with each threshold is transmitted to the DMS.




Figure 6 — Detailed view: five CB fixed counters with per-size absolute readings, alarms colour-coded green / red, and rack-level navigation buttons (NEXT, STATUS, TEMP, EXIT).

7.1 Operator presence in the tower

When operators have to intervene inside a tower, the dust budget of the corresponding clean room temporarily grows (door cycles, garment changes, tooling). The fixed counter may tend to oscillate and trigger alarms if the threshold acceptance is overpassed. The accepted procedure is therefore:

1. **Adjust the acquisition settings** of the affected fixed counters before entering the tower. The “CENTRAL BUILDING NEXT” view exposes the *Acquisition Time*, *Time Interval* and *Run Time* parameters, plus a *Start / Stop* couple. During an intervention the counters are set with a **longer counting (acquisition) time** and a **shorter holding time**, so that the actual dust generated by the activity is sampled more frequently and is not masked by long idle intervals between counts.
2. **Deploy a Mobile particle counter** next to the intervention point. The three Mobile counters (Mobile 1 / Mobile 2 / Mobile 3) are displayed in their own pane, in parallel with the fixed ones, and provide the short-term value the operator can use to decide whether to continue or pause.
3. **Revert the fixed counter settings** at the end of the intervention.



Figure 7 — Rack touchscreen “Central Building Next” view used to tune the counters before a tower intervention: per-counter Start / Stop and the Acquisition Programming panel (Acquisition Time, Time Interval, Run Time).

7.2 Rack-mounted and remote display touchscreens (Particle counters information and settings)

Unlike the wall-mounted information panels, which are read-only, each particle-counting rack is fitted with a **small touchscreen display** mounted at the rack itself. These touchscreens are meant to adjust particle counter settings in the field:

- they limit the scope to the counters served by that rack,
- they expose the start / stop controls and the acquisition parameters (*Acquisition Time*, *Time Interval*, *Run Time*),
- they provide the navigation buttons visible on the bottom row of the “CENTRAL BUILDING PARTICLE COUNTERS” and “CEB DUST CONTROL PANEL” views (MAIN, NEXT, STATUS, TEMP, EXIT, SETTINGS, MOBILE).

They are the direct way to reach a single counter when the operator is in the corresponding area; the wall-mounted displays in the CB, the ends and the Control Room only show the resulting values.

Two other small touchscreen displays are placed in the Clean Room SAS, and the Detection SAS. They allow remote access to Central Building rack interface.




Figure 8 — CEB Dust Control Panel: site-wide summary of every CB clean room (Injection Lab, Baseroom, Main Hall, Mirror, Payload, SAS, Detection Lab, SAS Detection Lab), with per-size value tiles and Status / Running / Com health LEDs.

8. Summary of deployment

Panel	Physical location(s)	Buildings covered
Global Control Room panel	Control Room (single instance)	CB + NE + WE
Central Building local panels	CB entrance, Clean SAS, Baseroom (below tower entrance level)	CB
WE local panel	WE entrance SAS	WE
NE local panel	NE entrance SAS	NE
1500W clean-room panel	1500W clean-room facility	1500W clean rooms (Payload L., Fiber L., Clean R. SAS, SQZ Lab.) + WE-side O ₂ & laser overview
Rack-mounted and remote display touchscreens (Particle counters information and settings)	One rack per building: CB in the pure water production room, NE in the main hall, WE in the main hall; remote touchscreens in CB Main Clean Room SAS and DET SAS	Only the counters served by the rack

9. Conclusion

The panels report, as a first priority, **real-time information** aimed at helping operators to work in a safe environment when entering the experimental areas. They cover several complementary aspects of the detector environment — **vacuum**, **laser beams**, **oxygen sensors** and **particle-counting states** — so that the user has a single, coherent view of what is happening locally before stepping into a clean room or opening a chamber.

The various thresholds shown on the panels (pressure, laser power, oxygen levels, particle counts) may **evolve over time** according to the expertise of the sub-system teams; the panels are therefore intended as a living reference of the current operating conditions, kept in sync with the up-to-date thresholds defined by the responsible experts.