

ELECTRICAL SCHEDULE OF LOADS

Supply: 400V 3-phase 4-wire 50Hz

Board	Circuit	Description	Connected_VA	Demand_Factor	Demand_VA	Poles	Breaker_AT	Cable_mm2	Phase
DB-1	1	Lighting	1200	1.00	1200.0	1P	16	2.5	A
DB-1	2	Power	2000	0.85	1700.0	1P	20	4.0	B
DB-1	3	HVAC	4000	0.78	3120.0	3P	25	6.0	C
DB-1	4	Spare	0	0.00	0.0	3P	20	2.5	A
DB-2	1	Lighting	1400	1.00	1400.0	1P	16	2.5	A
DB-2	2	Power	2200	0.85	1870.0	1P	20	4.0	B
DB-2	3	HVAC	4300	0.78	3354.0	3P	25	6.0	C
DB-2	4	Small Power	1800	0.80	1440.0	1P	32	6.0	A
MSB	1	Lighting	1600	1.00	1600.0	1P	16	2.5	A
MSB	2	Power	2400	0.85	2040.0	1P	20	4.0	B
MSB	3	HVAC	4600	0.78	3588.0	3P	25	6.0	C
MSB	4	Pumps	900	1.00	900.0	3P	40	16	B

BOARD SUMMARY

Board	Connected_VA	Demand_VA	Main_Breaker_AT	Feeder_mm2
DB-1	7200	6020.00	250	120
DB-2	9700	8064.00	250	120
MSB	9500	8128.00	400	185