Contents lists available at ScienceDirect


Extreme Mechanics Letters

journal homepage: www.elsevier.com/locate/eml



Electric field concentration in hydrogel-elastomer devices

Justina Vaicekauskaite a,b, Canhui Yang b,c, Anne Ladegaard Skov a, Zhigang Suo b,*



^c Department of Mechanics and Aerospace Engineering, Southern University of Science and Technology, Shenzhen, Guangdong 518055, PR China



ARTICLE INFO

Article history:
Received 19 June 2019
Received in revised form 29 October 2019
Accepted 29 October 2019
Available online 31 October 2019

Keywords:
Hydrogel-elastomer devices
Dielectric elastomers
Hydrogels
Electric field concentration
Localized heating
Salting out

ABSTRACT

Hydrogels and elastomers are being integrated to make stretchable, transparent, electromechanical devices. In such a device, a dielectric elastomer functions as an electric insulator, and a salt-containing hydrogel functions as an electric conductor. Here we report several experimental observations associated with electric field concentration along the edges of the hydrogels. We apply cyclic voltage to a large number of samples, and record the numbers of cycles when the elastomer suffers electric breakdown. In most samples, the elastomer breaks down at the edges of the hydrogels. Before the elastomer breaks down, we observe salting out, localized heating, and plasma along the edges of the hydrogels. These observations are consistent with the hypothesis that the concentrated electric field at the edges of the hydrogels breaks down the air when the elastomer is intact. Remarkably, the breakdown of air makes the electric field less concentrated, and protects the elastomer. When the sample is coated with an elastomer, air no longer breaks down, but the elastomer breaks down at a reduced applied voltage. We discuss the significance of these observations in applications.

© 2019 Elsevier Ltd. All rights reserved.

1. Introduction

When a membrane of a dielectric elastomer sandwiched between two compliant electrodes is subject to a voltage, charges of opposite polarities accumulate on two sides of the elastomer, resulting in the reduction of thickness and expansion of area [1]. This electromechanical transduction has a unique combination of attributes, such as large deformation, fast response, high efficiency, low cost, and light weight [2], and has enabled many devices [3–5]. Examples include prosthetic devices [3,6], haptic devices [7,8], soft robots [1,6,9], tunable optics [10,11], sensors [12], and energy harvesters [1,13].

Hydrogels have recently been used as the compliant electrodes [10]. A hydrogel is an aggregate of water molecules and a sparse polymer network. Water molecules make the hydrogel liquid-like and optically transparent, while the polymer network makes the hydrogel solid-like and elastically stretchable. Furthermore, the water molecules in the hydrogel can host ions to achieve conductivity up to 10 S/m [14]. The integration of hydrogels and elastomers has enabled many devices called hydrogel ionotronics [15] or stretchable ionics [16]. Examples include transparent loudspeaker [10], ionic skin [12], artificial axon [17], stretchable electroluminescence [18,19], stretchable touchpad [20], and

* Corresponding author. E-mail addresses: al@kt.dtu.dk (A.L. Skov), suo@seas.harvard.edu (Z. Suo). transparent membrane for active noise cancellation [21]. In these devices, hydrogels function as stretchable, transparent, ionic conductors, while elastomers function as stretchable, transparent dielectrics.

These promising demonstrations raise an immediate question: what is the reliability of hydrogel-elastomer devices under high voltage over many cycles? Here we report several observations associated with electric field concentration along the edges of the hydrogels. We make each sample by sandwiching a membrane of dielectric elastomer between two membranes of salt-containing hydrogels. When the two hydrogels are subject to a high voltage, the edges of the hydrogels concentrate electric field. We apply cyclic voltage of prescribed amplitude and frequency to a large number of samples, and record the numbers of cycles when the elastomer suffers electric breakdown. In most samples, the elastomer breaks down at the edges of the hydrogels (i.e. the regions outside of the area covered with electrode). Before the elastomer breaks down, we observe salting out, localized heating, and plasma along the edges of the hydrogels. These observations support the hypothesis that air breaks down when the elastomer is intact. When the device is coated with an elastomer, air no longer breaks down, but the elastomer breaks down at a reduced applied voltage. We discuss the significance of these observations for hydrogel-elastomer devices.




Fig. 1. Experimental set up. (a) Schematic top view of a hydrogel–elastomer device. A membrane of a dielectric elastomer is prestretched and fastened onto a rigid frame. Two circular membranes of hydrogels are attached on both sides of the elastomer and are connected, via two lines of hydrogels, to top and bottom metallic electrodes fixed on the rigid frame. (b) Schematic side view of the device. When a voltage is applied between the two metallic electrodes, electric field concentrates at the edges of the hydrogels. (c) A photo of a hydrogel–elastomer device.

2. Results and discussion

We fabricate a device by sandwiching a layer of elastomer between two layers of hydrogels (Fig. 1a). The elastomer is prestretched and fastened on a rigid frame. The two hydrogels are connected to top and bottom metallic electrodes fixed on the rigid frame. The hydrogels containing ions are electric conductors, and the elastomer is an electric insulator. When a voltage is applied between the two metallic electrodes, electric field vanishes in the hydrogels, but builds up in the elastomer and air (Fig. 1b). Within the area covered by the hydrogels, the electric field lines are straight and uniform in the elastomer, and are negligible in the air. At the edges of the hydrogels, the electric field lines are curved and concentrated, both in the elastomer and in the air. The electric field lines are perpendicular to the surface of the conductors, i.e., the hydrogels.

We use a polydimethylsiloxane (PDMS) elastomer as the stretchable transparent dielectric, and a polyacrylamide (PAAm) hydrogel containing lithium chloride (LiCl) as the stretchable transparent conductor. LiCl is the most hydroscopic salt used in hydrogel–elastomer devices [14]. Hydrogels are connected to voltage source through top and bottom electrodes, which are aluminum foils. The rigid frame is made of acrylic sheet. Because both the PDMS elastomer and the PAAm hydrogel are transparent, the device is also transparent (Fig. 1c). The diameter of the stretched elastomer film is 5 cm and the diameter of PAAm hydrogel is 2 cm. Unless otherwise specified, the thickness of the unstretched elastomer is 250 μm . After an equal biaxial stretch of 1.2, the thickness reduces to $\sim 173~\mu m$. The thickness of PAAm hydrogel is 500 μm .

We first study the effect of electric field concentration on the lifetime of the device. We use the PAAm hydrogels containing various concentrations of LiCl. To minimize the effects of ambient humidity, we conduct the experiments inside a chamber and control the interior humidity by placing a tank of LiCl solution

of the same concentration as that in the hydrogel (Fig. S1). The interior humidity is controlled by placing a tank of LiCl solution of the same concentration as that in the hydrogel. If carbon grease electrode is used, the concentration of LiCl is fixed at 8 mol/L. The humidity is approximately 88% for 1 mol/L, 80% for 4 mol/L, 52% for 8 mol/L and 32% for 12 mol/L LiCl solution. We apply a sinusoidal voltage of frequency 1 kHz. This frequency is chosen to optimize overall measurement time. The areal strain is less than 5% and the change of electric field due to areal strain is neglected. We measure the breakdown voltage by ramping up the amplitude of the sinusoidal voltage at a rate of 300 V/s speed. Then we apply voltage of the same frequency and a prescribed amplitude to many samples. When breakdown occurs, a small pinhole is observed on the elastomer. Dielectric elastomer is prestretched thus sample can tear, but this is not observed in all of the experiments. If the elastomer of a sample breaks down within 10 min, we plot the data point in the diagram with the axis of the amplitude of voltage and the number of cycles to breakdown (Fig. 2). If the elastomer of a sample does not break down in 10 minutes, the experiment is then terminated and the result is represented as an arrow in the diagram. Also included in the diagram are data of breakdown measured by applying voltage with ramping amplitude.

Both the breakdown voltage measured using ramping voltage and the number of cycles to breakdown measured using cyclic voltage of prescribed amplitude have large statistical scatter for all concentrations of LiCl. For most samples, the elastomer breaks down at the edges of the hydrogels (94% for PAAm samples with 1 mol/L LiCl, 100% for PAAm samples with 4 mol/L LiCl, 67% for PAAm samples with 8 mol/L LiCl and 81% for PAAm samples with 12 mol/L LiCl). Longer lifetime is obtained at lower voltage. Samples with lower LiCl concentration tends to have shorter lifetime. The relative humidity is higher when the concentration LiCl solution is lower (Fig. S1). For comparison, the diagram also includes the data for samples using carbon grease as the compliant electrodes. The lifetime of carbon grease driven devices is also




Fig. 2. Endurance of hydrogel-elastomer devices. Each data point represents a sample subject to cyclic voltage of prescribed amplitude and frequency, when the elastomer breaks down after some number of cycles. An arrow on a data point means that the sample has not broken down when the measurement is terminated. Unfilled symbols represent the breakdown of the elastomer at the edges of the compliant electrodes, and filled symbols represent the breakdown of the elastomer in the middle of the compliant electrodes. Also included along the vertical axis are the breakdown voltages measured under ramping voltage. This diagram contains the data for a total of 160 samples.

noisy and 97% devices break down on the edges. These results confirm that the edges of the electrodes (both the hydrogel and the carbon grease) concentrate the electric field, and cause the elastomer to breakdown at the edges of the electrodes.

We next study the effect of field concentration before electric breakdown. We observe that the LiCl in the hydrogels precipitates out during the experiment (Fig. 3a). We call this phenomenon salting out. Before the cyclic voltage is applied, LiCl fully dissolves in the hydrogels and the hydrogels are transparent. After we apply a sinusoidal voltage of frequency 1 kHz and amplitude 10680 V for 5 min, certain areas of the hydrogels, especially at the edges, turn white due to the precipitation of LiCl. The elastomer around the electrodes after experiment also gets opaque because of appearing cracks on the elastomers. The surrounding cracks might be caused by corona discharge due to the roughness of the hydrogels [22]. After 10 minutes of experiment, more pronounced salting out is observed with the precipitation area approaching more toward the interior. After the voltage is switched off for 1 h, the hygroscopic LiCl absorbs water from the ambient and dissolves in the hydrogels again, so that the hydrogels regain transparency.

We use a thermal camera (FLIR TG165) to monitor the device (Fig. 3b). Before experiment, temperature of the device is similar to that of ambient environment. The highest temperature measured is 21.9 °C, approximately the room temperature. After the voltage is applied for 5 min, the areas along the edges of the hydrogels show higher temperature than the rest of areas. At this stage, the highest temperature is measured to be 50.1 °C. After 10 minutes, the local temperature further increases with the highest temperature reaching 66.6 °C. Subsequently, we switch off the voltage. After 1 h, the temperature of the device recovers to room temperature. We conclude that it is the local heating that

causes the hydrogels to lose water, which then results in salting out. We verify that the hydrogels containing 8 mol/L LiCl dry out at 65 °C (Fig. S2). We confirm that local heating also occurs for samples driven by carbon grease (Fig. S3). The oil of carbon grease does not have noticeable drying out. However, for other types of carbon grease, increase in temperature causes the electrodes to flow (Fig. S4 a).

We further study the effects of frequency and amplitude of applied voltage on salting out and localized heating. When the amplitude of applied voltage is fixed at 10680 V and the experimental time is set to be 10 min, salting out becomes more and more pronounced as the frequency increases from 0.5 kHz to 1 kHz (Fig. S5). Similarly, higher amplitude of applied voltage leads to higher local temperature thus more pronounced salting out (Fig. S6).

What causes salting out and localized heating? The electric breakdown strength of the air is much smaller than that of the elastomer. We hypothesize that the electric field concentrated at the edges of the hydrogels cause the air breakdown when the elastomer is still intact (Fig. 4a). We test this hypothesis by applying cyclic voltage to samples placed in a dark room. We see purple light along the edges of the hydrogels (Fig. 4b). We surmise that the plasma is caused by air breakdown, which causes salting out and localized heating. We also observe plasma when carbon grease is used as electrodes (Fig. S4b).

To further test the hypothesis of air breakdown, we coat the hydrogel–elastomer device with a thin layer of PDMS elastomer (Fig. 4c). No plasma is observed prior to elastomer breakdown. The elastomer in coated samples breaks down at a voltage lower than the elastomer in uncoated samples (Fig. 4d). We interpret this experimental finding as follows. It is reasonable to approximate the plasma as an electric conductor, so that the electric




Fig. 3. Salting out and localized heating. (a) Images showing the evolution of the salting out process of a PDMS driven by PAAm hydrogels containing 8 mol/L LiCl under applied voltage of amplitude 10680 V and frequency 1 kHz. (b) Corresponding thermal images. The highest local temperature reaches 66.6 °C after 10 min of experiment.

field inside the plasma vanishes, and the electric field outside the plasma approaches the plasma perpendicularly. The size scale of the plasma is larger than the thickness of the hydrogel. Once air breaks down, the electric field nearby is limited by the breakdown electric field of the air, which is much below the breakdown field of the elastomer. Consequently, the air breakdown alleviates field concentration, and increases the voltage to breakdown the elastomer. We further vary the thickness of hydrogels between 250 μm and 1.5 mm, but the breakdown voltage does not show obvious dependence on the thickness (Fig. 4e). In all cases, when the devices are coated with elastomer, the breakdown voltage of the devices drops significantly. Similar behavior is observed when carbon grease is used. These results further support that the breakdown of air protects the devices.

We note that discrepant observation that encapsulation leads to the decrease of breakdown voltage in dielectric elastomer actuator has been reported in previous study [23]. We attribute the discrepancy to two differences. Firstly, salt-containing hydrogel which is ionically conductive and contains a lot of water is used in this work, while electronic conductors (e.g. graphite power) is used in previous work. Secondly, the thickness of hydrogel electrode (500 μm) is much larger than that of graphite electrode (less then $\sim\!10~\mu m$ [24]), so that the influence of electric field concentration can be more pronounced.

3. Concluding remarks

In summary, we have studied the electric field concentration in hydrogel-elastomer devices. We show that the lifetime has large statistical scatter. The field concentration causes the elastomer in the devices to break down mostly at the edges of the hydrogels. Prior to elastomer breakdown, air breaks down along the edges of hydrogels, causing salting out, localized heating, and plasma. Given that LiCl is among the best hygroscopic salt used for hydrogels, one should take into account of salting out and localized heating when the amplitude of applied voltage is large,

frequency of applied voltage is high, or the work time is long. Compared to hydrogels, ionogels containing ionic liquid can operate stably at high temperature (>100 °C) or even under vacuum [25,26], providing an alternative to achieve soft, stretchable and transparent actuators without the concerns of drying out. Electric field concentration is generic for all electrical devices and has numerous well-established applications, including lightening rod, ozone production, and sanitization of water. Recently, electric field concentration has enabled a new concept of airplane with no moving parts and solid-state propulsion [27]. The field concentration in hydrogel-elastomer devices opens doors for new applications. For example, compared to conventional electrical devices, hydrogel-elastomer devices are soft and biocompatible. The field concentration of these devices can be used for tissue engineering such as non-invasive cell manipulation and on-demand reconstruction of artificial tissues [28]. In addition, the amplification of electric field reduces the working voltage in voltage-driven devices, e.g. electroluminescent displays and liquid-crystal displays [29]. Furthermore, localized heating and the salting out are built-in indicators for the safe operation of the devices.

Declaration of competing interest

The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

Acknowledgments

The work at Harvard was supported by NSF MRSEC (DMR-14-20570). J. Vaicekauskaite was supported by Otto Mønsteds Fond and Idella Foundation as a visiting student at Harvard for




Fig. 4. Hydrogel plasma. (a) Schematic of an uncoated device. Air breaks down at the edges of hydrogels, creating plasma. (b) Subject to cyclic voltage, a plasma of purple light is produced along the edges of the hydrogels. (c) Schematic of an elastomer-coated device. Air no longer breaks down, but the electric field concentrates in the elastomer. (d) Photo of the device after the elastomer breaks down. All coated samples break down at the edge. (e) Comparison of breakdown voltage in coated and uncoated samples using various electrodes. At least 4 samples of one composition are used for each experiment.

6 months. The Independent Research Fund Denmark is acknowledged for funding the project. C. Yang acknowledge the start-up funding from Shenzhen and SUSTech (Y01326119 & Y01326219).

Experimental section

Synthesis of PAAm hydrogels

2 mol/L acrylamide (AAm, Sigma-Aldrich, A8887) solution is prepared. For every 1 ml of the solution, we add 4 μ L 0.1 mol/L crosslinking agent, N,N' methylenebisacrylamide (MBAA, Sigma-Aldrich, 146072), and 20 μ L 0.1 mol/L photoinitiator, α -ketoglutamate acid (α -keto, Sigma-Aldrich, 75890). Lithium chloride (LiCl, Sigma-Aldrich, 746460) is added to yield precursors with different LiCl concentrations: 1 mol/L, 4 mol/L, 8 mol/L

and 12 mol/L. The precursor is cast in $160 \times 160 \times 0.5 \text{ mm}^3$ glass mold and cured for 1 h under a 15 W bench UV Lamp (XX-15, UVP) at a dose rate of 30 mW/cm² at 365 nm in room temperature. Circular shaped electrodes with thin lines are cut out from the cured hydrogel film, using a laser cutter (Helix 75 W laser cutter, LZR-010).

Preparation of elastomer

Two parts of silicone rubber (Sylgard 184, Dow Corning), base and curing agent, are mixed in recommended ratio of 10:1. The mixture is cast into a $100 \times 100 \times 0.250 \text{ mm}^3$ mold and cured for 4 hours, at 65 degree Celsius. After curing, the elastomer film

is removed from the mold, stretched by 20% strain biaxially, and fixed on a rigid acrylic frame (Fig. 1).

Humidity control

We make a humidity chamber to control the relative humidity during the experiments. We cut acrylic sheets using laser cutter and glue them to form a chamber of dimensions $30 \times 16 \times 15 \text{ cm}^3$. Humidity equilibrium in the chamber is tested by placing a tank of 100 mL LiCl solution inside of the chamber (Fig. S1d) and monitoring humidity change in 24 h using a humidometer. The lifetime measurements are carried out when the humidity inside the chamber reaches equilibrium.

Fabrication of devices

A device is made by placing a layer of elastomer between two layers of electrodes. Two types of electrodes are used: carbon grease (CG, MG Chemicals, #846-80G), which is stenciled on both sides of elastomer, and polyacrylamide (PAAm) hydrogel containing LiCl. Electrodes are linked through thin electrode lines to two aluminum foils placed on top and bottom of the acrylic frame. For the coated samples, we dip coat the electrodes with the precursor of silicone elastomer (Sylgard 184, Dow Corning), base and curing agent are mixed in recommended ratio of 10:1, and cure at room temperature overnight. During testing, the two aluminum foils are connected to a high voltage amplifier (Trek, 30/20A), which amplifies the input voltage generated by a waveform generator (KEYSIGHT, 33500B) with an amplification factor of 3000.

Thermal and optical images

Thermal images are taken using Flir TG165 imaging IR thermometer with 80×60 resolution and accuracy of $\pm 1.5\%$. When a sample is subject to cyclic voltage, the thermal camera is pointed at the hottest spot of the sample. The number at the left top indicates the hottest temperature in that thermal image. Optical images are taken using a digital camera (Canon Ds126321).

Appendix A. Supplementary data

Supplementary material related to this article can be found online at https://doi.org/10.1016/j.eml.2019.100597.

References

- R.E. Pelrine, R.D. Kornbluh, J.P. Joseph, Electrostriction of polymer dielectrics with compliant electrodes as a means of actuation, Sensors Actuators, A 64 (1998) 77–85.
- [2] F. Carpi, D.De. Rossi, R. Kornbluh, R. Pelrine, P. Sommer-Larsen, Dielectric elastomers as electromechanical transducers: Fundamentals, materials, devices, models and applications of an emerging electroactive polymer technology, 2011, p. 51–68.
- [3] R.E. Pelrine, R.D. Kornbluh, Q. Pei, J. Joseph, High-speed electrically actuated elastomers with strain greater than 100%, Science 287 (2000) 836–840.
- [4] I.A. Anderson, T.A. Gisby, T.G. Mckay, B.M.O. Brien, E.P. Calius, Multifunctional dielectric elastomer artificial muscles for soft and smart machines, J. Appl. Phys. 112 (041101) (2012) 1–20.

- [5] P. Brochu, Q. Pei, Advances in dielectric elastomers for actuators and artificial muscles, Macromol Rapid Commun. 31 (2010) 10–36.
- [6] E. Acome, S.K. Mitchell, T.G. Morrissey, M.B. Emmett, C. Benjamin, M. King, et al., Hydraulically amplified self-healing electrostatic actuators with muscle-like performance, Science 359 (2018) 61–65.
- [7] D. Pyo, S. Ryu, K. Kyung, S. Yun, D. Kwon, High-pressure endurable flexible tactile actuator based on microstructured dielectric elastomer, Appl. Phys. Lett. 112 (061902) (2018) 1–5.
- [8] N. Tiwari, M. Rajput, N. Chien, N. Mathews, Highly transparent and integrable surface texture change device for localized tactile feedback, Small J. 14 (1702312) (2018) 1–9.
- [9] C. Jordi, S. Michel, E. Fink, Fish-like propulsion of an airship with planar membrane dielectric elastomeractuators, Bioinspir. Biomim. 5 (026007) (2010) 1–9.
- [10] C. Keplinger, J. Sun, C. Foo, P. Rothemund, G.M. Whitesides, Z. Suo, Stretchable, transparent, ionic conductors, Science 341 (6149) (2013) 984–987.
- [11] B. Jin, H. Ren, Position-movable lens driven by dielectric elastomer actuator, Opt. Eng. 55 (7) (2016) 1–7.
- [12] J. Sun, C. Keplinger, G.M. Whitesides, Z. Suo, Ionic skin, Adv. Mater. 26 (2014) 7608–7614.
- [13] G. Moretti, G.P.R. Papini, M. Righi, D. Foreh, D. Ingram, R. Vertechy, et al., Resonant wave energy harvester based on dielectric elastomer generator, Smart Mater. Struct. 27 (035015) (2018) 1–14.
- [14] Y. Bai, B. Chen, F. Xiang, J. Zhou, H. Wang, Z. Suo, Transparent hydrogel with enhanced water retention capacity by introducing highly hydratable salt, Appl. Phys. Lett. 105 (151903) (2014) 1–5.
- [15] C. Yang, Z. Suo, Hydrogel ionotronics, Nat. Rev. Mater. (2018).
- [16] H.R. Lee, C.C. Kim, J.Y. Sun, Stretchable ionics A promising candidate for upcoming wearable devices, Adv. Mater. 30 (42) (2018) 1–15.
- [17] C. Yang, B. Chen, J. Jing, J. Hai, J. Zhou, Y. Mei, et al., Ionic Cable, Extrem. Mech. Lett. 3 (2015) 59–65.
- [18] R. Shepherd, C. Larson, B. Peele, S. Li, S. Robinson, M. Totaro, et al., Highly stretchable electroluminescent skin for optical signaling and tactile sensing, Science 351 (6277) (2016) 1071–1074.
- [19] C.H. Yang, B. Chen, J. Zhou, Y.M. Chen, Z. Suo, Electroluminescence of giant stretchability, Adv. Mater. 3 (00) (2015) 1–4.
- [20] C.C. Kim, H.H. Lee, K.H. Oh, Sun J.Y. Highly stretchable, Transparent ionic touch panel, Science 353 (6300) (2016) 682–687.
- [21] P. Rothemund, X.P. Morelle, K. Jia, G.M. Whitesides, Z. Suo, A transparent membrane for active noise Cancelation, Adv. Funct. Mater. 1800653 (28) (2018) 1–8.
- [22] H. Hillborg, U.W. Gedde, Hydrophobicity recovery of polydimethylsiloxane after repeated exposure to corona discharges. Influence of crosslink density, Conf Electr. Insul. Dielectr. Phenom. (1999) 751–755.
- [23] T.G. La, G.K. Lau, Very high dielectric strength for dielectric elastomer actuators in liquid dielectric immersion, Appl. Phys. Lett. 102 (19) (2013).
- [24] Thanh-Giang La, Gih-Keong Lau, Li-Lynn Shiau, A.W.-Y.T, Muscle-like highstress dielectric elastomer actuators with oil capsules, Smart Mater. Struct. 23 (10) (2014) 1–10.
- [25] J. Le Bideau, L. Viau, A. Vioux, Ionogels, ionic liquid based hybrid materials, Chem. Soc. Rev. 40 (2) (2011) 907–925.
- [26] B. Chen, J.J. Lu, C.H. Yang, J.H. Yang, J. Zhou, Y.M. Chen, et al., Highly stretchable and transparent ionogels as nonvolatile conductors for dielectric elastomer transducers, ACS Appl. Mater. Interfaces 6 (10) (2014) 7840-7845.
- [27] H. Xu, Y. He, K.L. Strobel, C.K. Gilmore, S.P. Kelley, C.C. Hennick, et al., Flight of an aeroplane with solid-state propulsion, Nature 563 (7732) (2018) 532–535.
- [28] G.H. Markx, The use of electric fields in tissue engineering: A review, Organogenesis 4 (1) (2008) 11–17.
- [29] C.H. Yang, S. Zhou, S. Shian, D.R. Clarke, Z. Suo, Organic liquidcrystal devices based on ionic conductors, Mater. Horizons 4 (6) (2017) 1102–1109.