

Domain Lighting

code	service	1						
L-1a	Occupancy control for indoor lighting	Service group: Artificial lighting control						
Functionality levels		IMPACTS						
		Energy efficiency	Energy flexibility and storage	Comfort	Convenience	Health, well-being and accessibility	Maintenance and fault prediction	Information to occupants
level 0	Manual on/off switch	0	0	0	0	0	0	0
level 1	Manual on/off switch + additional sweeping extinction signal	1	0	1	1	0	0	0
level 2	Automatic detection (auto on / dimmed or auto off)	2	0	2	2	0	0	0
level 3	Automatic detection (manual on / dimmed or auto off)	3	0	2	2	0	0	0
level 4	0							
Information sources								
		Standard?	EN 15232					

code	service	0						
L-2	Control artificial lighting power based on daylight levels	Service group: Artificial lighting power based on daylight						
Functionality levels		IMPACTS						
		Energy efficiency	Energy flexibility and storage	Comfort	Convenience	Health, well-being and accessibility	Maintenance and fault prediction	Information to occupants
level 0	Manual (central)	0	0	0	0	0	0	0
level 1	Manual (per room / zone)	1	0	1	1	0	0	0
level 2	Automatic switching	2	0	1	1	1	0	0
level 3	Automatic dimming	3	0	2	2	2	0	0
level 4	Automatic dimming including scene-based light control (during time intervals, dynamic and adapted lighting scenes are set, for example, in terms of illuminance level, different correlated colour temperature (CCT) and the possibility to change the light distribution within the space according to e. g. design, human needs, visual tasks)	3	0	3	3	3	0	0
Information sources								
		Standard?	EN 15193-1 and CEN-TR 16791	CEN-TR 16791	EN 12464-1	CEN-TR 16791	CEN-TR 16791	CEN-TR 16791