

Non-Residential Impact Weighting Factors

North Europe	Energy efficiency	Energy flexibility and storage	Comfort	Convenience	Health, well-being and accessibility	Maintenance and fault prediction	Information to occupants
Heating	0.31	0.49	0.16	0.10	0.16	0.35	0.11
Domestic hot water	0.05	0.08	0.00	0.10	0.00	0.06	0.11
Cooling	0.09	0.15	0.16	0.10	0.16	0.10	0.11
Ventilation	0.20	0.00	0.16	0.10	0.16	0.22	0.11
Lighting	0.08	0.00	0.16	0.10	0.16	0.00	0.00
Electricity	0.02	0.02	0.00	0.10	0.00	0.02	0.11
Dynamic building envelope	0.05	0.00	0.16	0.10	0.16	0.05	0.11
Electric vehicle charging	0.00	0.05	0.00	0.10	0.00	0.00	0.11
Monitoring and control	0.20	0.20	0.20	0.20	0.20	0.20	0.20
	1.00	1.00	1.00	1.00	1.00	1.00	1.00

IMPACT WEIGHTINGS	Energy efficiency	Energy flexibility and storage	Comfort	Convenience	Health, well-being and accessibility	Maintenance and fault prediction	Information to occupants
	0.16667	0.33333	0.08333	0.08333	0.08333	0.16667	0.08333

1.00

West Europe	Energy efficiency	Energy flexibility and storage	Comfort	Convenience	Health, well-being and accessibility	Maintenance and fault prediction	Information to occupants
Heating	0.27	0.41	0.16	0.10	0.16	0.32	0.11
Domestic hot water	0.08	0.12	0.00	0.10	0.00	0.10	0.11
Cooling	0.13	0.19	0.16	0.10	0.16	0.15	0.11
Ventilation	0.14	0.00	0.16	0.10	0.16	0.17	0.11
Lighting	0.10	0.00	0.16	0.10	0.16	0.00	0.00
Electricity	0.02	0.03	0.00	0.10	0.00	0.02	0.11
Dynamic building envelope	0.05	0.00	0.16	0.10	0.16	0.05	0.11
Electric vehicle charging	0.00	0.05	0.00	0.10	0.00	0.00	0.11
Monitoring and control	0.20	0.20	0.20	0.20	0.20	0.20	0.20
	1.00	1.00	1.00	1.00	1.00	1.00	1.00

IMPACT WEIGHTINGS

IMPACT WEIGHTINGS

Energy efficiency	Energy flexibility and storage	Comfort	Convenience	Health, well-being and accessibility	Maintenance and fault prediction	Information to occupants
0.16667	0.33333	0.08333	0.08333	0.08333	0.16667	0.08333

1.00

South-East Europe	Energy efficiency	Energy flexibility and storage	Comfort	Convenience	Health, well-being and accessibility	Maintenance and fault prediction	Information to occupants
Heating	0.29	0.42	0.16	0.10	0.16	0.33	0.11
Domestic hot water	0.12	0.17	0.00	0.10	0.00	0.13	0.11
Cooling	0.07	0.11	0.16	0.10	0.16	0.08	0.11
Ventilation	0.15	0.00	0.16	0.10	0.16	0.17	0.11
Lighting	0.09	0.00	0.16	0.10	0.16	0.00	0.00
Electricity	0.03	0.05	0.00	0.10	0.00	0.04	0.11
Dynamic building envelope	0.05	0.00	0.16	0.10	0.16	0.05	0.11
Electric vehicle charging	0.00	0.05	0.00	0.10	0.00	0.00	0.11
Monitoring and control	0.20	0.20	0.20	0.20	0.20	0.20	0.20
	1.00	1.00	1.00	1.00	1.00	1.00	1.00

IMPACT WEIGHTINGS

Energy efficiency	Energy flexibility and storage	Comfort	Convenience	Health, well-being and accessibility	Maintenance and fault prediction	Information to occupants
0.16667	0.33333	0.08333	0.08333	0.08333	0.16667	0.08333

1.00