

EMERGENCY LIGHTING COMPLETION CERTIFICATE

For small new installations up to 25 self-contained luminaires

Issued in accordance with BS 5266-1, by an Approved Contractor or Conforming Body enrolled with NICEIC,
Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX.

Contractor's Reference Number

CRN/ N/A

DETAILS OF THE CLIENT

Client/
Address Mike Burgess
Demmings Road, Demmings Industrial Estate, Cheadle,
Cheshire

Postcode SK8 2PE

DETAILS OF THE EMERGENCY LIGHTING INSTALLATION

Address Demmings Road, Demmings Industrial Estate, Cheadle,
Cheshire

Postcode SK8 2PE

Extent of the
installation
covered by
this certificate
Emergency lighting system only

PURPOSE OF CERTIFICATE

The installed work is:

New ☒

An addition ☐

An alteration ☐

DETAILS OF THE ORGANISATION RESPONSIBLE FOR CERTIFICATION

Trading title Integration Electrical Ltd

Address 41 Coniston Ave, Whitefield, Manchester,

Postcode M45 6DE

NICEIC Enrolment No
(Essential information)

6 1 1 7 1 6

Branch number
(if applicable)

0 0 0

DECLARATION OF CONFORMITY

In consequence of acceptance of the outcomes declared in this certificate, I/we hereby declare that the emergency lighting system installation, or part thereof, described in this certificate conforms, to the best of my/our knowledge and belief, to the appropriate recommendations and requirements given in BS 5266-1: 2016, *Emergency lighting – Part 1: Code of practice for emergency lighting of premises*, BS EN 1838: 2013 *Lighting applications – Emergency lighting* and BS EN 50172: 2004, *Emergency escape lighting systems*, as set out in the outcomes declared, except for the deviations recorded.

To be signed by either: a) The **Responsible Person / Competent Person** (England and Wales); b) The **Employer or Other Persons** (Scotland)
or c) The **Employer or Nominated Employee** (Northern Ireland)

Signature



Date 25/07/2019

Name
(CAPITALS)

DANIEL ALLPORT

VALIDITY REVIEW AND ESSENTIAL RELATED DOCUMENTS

This certificate is valid only when accompanied by current versions of all the following:

- i) Signed compliance checklist ii) Photometric design data (see note 1) iii) Test log book

The contractor issuing this certificate MUST sign to verify that i), ii) and iii) above have been supplied with this certificate and that all essential related reference documents have been recorded below.

Related documents Insert the relevant certificate and design schedule numbers. (Insert N/A if not applicable).

Electrical Installation Certificate No.
(see Note 2)

N/A

Design Schedule No(s)

N/A

Minor Electrical Installation Works
Certificate No.

N/A

Emergency Lighting Periodic Inspection
and Test Certificate No. (see Note 3)

N/A

Other documents

In addition to the above, details of other related documents (if any), should be recorded below.

N/A

Signed by the NICEIC Approved Contractor

Signature



Date 25/07/2019

Name
(CAPITALS)

DANIEL ALLPORT

Reviewed by the Qualified Supervisor

Signature



Date 25/07/2019

Name
(CAPITALS)

DANIEL ALLPORT

NEXT INSPECTION

We, the signatories RECOMMEND that this installation is further inspected and tested after an interval of not more than

1 year

- Notes: 1. This can be in any of the following formats (in all cases appropriate de-rating factors must be used), and identified to meet worst case requirements:
a) Authenticated spacing data such as ICEL 1001 registered tables; b) Calculations as detailed in BS 5266-1: 2016, Annex D, and CIBSE / SLL Guide LG12;
c) Appropriate electronic format of results.
2. The electrical safety aspects of the emergency lighting installation must also be certified in accordance with BS 7671 – Requirements for Electrical Installations by issuing an 'Electrical Installation Certificate' or, where appropriate, a 'Minor Electrical Installation Works Certificate'.
3. Where this certificate relates to an alteration or addition that necessitated the carrying out of a periodic inspection on the existing emergency lighting installation, the 'Emergency Lighting Periodic Inspection and Testing Certificate' should accompany this certificate.

NOTES FOR RECIPIENT
THIS CERTIFICATE IS AN IMPORTANT AND VALUABLE DOCUMENT
AND SHOULD BE RETAINED FOR FUTURE REFERENCE

Only the NICEIC Approved Contractor or Conforming Body responsible for the small emergency lighting installation work, is authorised to issue this NICEIC Emergency Lighting Completion Certificate. This certificate has a printed seven digit serial number which is traceable to the Approved Contractor to which it was supplied by NICEIC.

You should have received the certificate, consisting of 3 pages in total, marked 'Original', and the NICEIC Approved Contractor responsible for carrying out the work should have retained the certificate marked 'Duplicate'.

Certification of emergency lighting installation works

This certificate should have been issued on completion of new emergency lighting installation work that includes no more than 25 new self-contained emergency lighting luminaires, where the NICEIC Approved Contractor issuing the certificate is solely responsible for the design, construction and the inspection and testing of the work. The work may be either a new emergency lighting installation or an addition or alteration to an existing emergency lighting installation.

The completed certificate is intended to confirm that the emergency lighting installation, detailed in this certificate has been fully inspected and tested and, except for the deviations (if any) recorded in the certificate, complies with the requirements of BS 7671 – *Requirements for Electrical Installations*, (IET *Wiring Regulations*, as amended) and the relevant recommendations and requirements of the emergency lighting standards listed below:

- BS 5266-1: 2016 – *Emergency lighting Part 1: Code of practice for the emergency lighting of premises*
- BS EN 1838: 2013 – *Lighting applications – Emergency lighting*
- BS EN 50172: 2004 (BS 5266-8: 2004) – *Emergency escape lighting systems*

The certificate should not have been issued for the periodic inspection and testing of an existing emergency lighting installation, for which an Emergency Lighting Periodic Inspection and Testing Certificate should be used.

The completed certificate should have been issued to the occupier/owner of the premises or alternatively their nominated representative for the premises (as identified in the *Declaration of Conformity*) and must be accompanied by all the following documents:

- i) a completed and signed compliance checklist
- ii) photometric design data
- iii) an appropriate test log book

The absence of any of these documents (i, ii or iii) above renders this certificate invalid.

If you were the person ordering the work, but not the user of the installation, you should pass this certificate, or a full copy of it, including these notes and any related reference documents, to the user immediately. This certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the emergency lighting installation in the future. If you later vacate the premises, the certificate will demonstrate to the new user that the emergency lighting installation covered by this certificate complied with the standards listed above and the requirements of BS 7671 (as amended), at the time the certificate was issued.

For safety reasons, the emergency lighting installation will need to be inspected and tested at appropriate intervals by a competent person. The recommended interval before the next inspection and test, on the work covered by this certificate, should have been agreed between the NICEIC Approved Contractor and the person signing the *Declaration of Conformity*, and recorded in the relevant section of the certificate.

* NICEIC, is operated by Certsure LLP, a partnership between the Electrical Contractors' Association and the charity, Electrical Safety First. NICEIC maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).

**For further information about electrical safety and how NICEIC can
help you, visit www.niceic.com**

EMERGENCY LIGHTING COMPLETION CERTIFICATE

For small new installations up to 25 self-contained luminaires

Original (To the person ordering the work)

COMPLIANCE CHECKLIST

Where a declared outcome is identified by an 'X', the details of the deviation must be accurately recorded. The deviation must be agreed between the Approved Contractor and the person signing the Declaration of Conformity.

Clause No.	Items assessed for compliance	Declared outcome
SYSTEM DESIGN AND DOCUMENTS		
4.2	1 Accurate plans are available showing the location of all emergency escape routes, the emergency exits, test facilities, fire indicating and fire fighting equipment and the like	✓
4.1; 5.2.8	2 Design provides coverage for all areas identified by the fire safety risk assessment	✓
5.2.8	3 Design provides coverage for all hazards identified by the fire safety risk assessment	✓
6.7	4 System has the correct mode of operation	✓
6.7	5 System is designed for the correct emergency duration period	✓
11	6 Photometric design data accompanies this certificate	✓
11	7 A test log book accompanies this certificate and is up-to-date	✓
EMERGENCY LUMINAIRES		
5.2.2	8 Luminaires* are suitably spaced in accordance with authenticated spacing or design data	✓
5.2.8.5; 5.2.8.6	9 Luminaires are installed where necessary to cover toilets, lifts, plant rooms and the like	✓
5.2.8	10 Luminaires are sited at or near (within 2 m) all relevant 'points of emphasis' in accordance with BS 5266-1: 2016 and in positions/locations identified from the fire safety risk assessment	✓
6.1	11 Non-maintained luminaires operate on failure of supply to local lighting circuit	✓
6.3	12 Illumination from at least two luminaires provided in each section of the escape route and open areas	✓
6.4	13 Luminaires are mounted at least 2 m above the floor and at a suitable height/position to avoid areas of smoke accumulation and/or obstructions	✓
6.7	14 Luminaires are suitably protected for their location (IP rating)	✓
7.4	15 All luminaires and converted luminaires conform to BS EN 60598-2-22	✓
12	16 Luminaires and lamps are in good condition	✓
12	17 Luminaires have been tested and found to operate for their full rated duration	✓
12	18 After the system has been tested, each luminaire charging indicator operates correctly	✓
SAFETY SIGNS		
5.2.9.1	19 Escape route signs comply with BS EN ISO 7010 and are located and operated in accordance with BS 5499- 4	✓
5.2.9.2	20 Other safety signs are located and operated in accordance with BS 5499-10	✓
TEST FACILITIES		
8.3.3	21 A sufficient number of suitably located test facilities are provided with their function clearly identified	✓
8.3.3	22 All test facilities are suitable to apply a test for the relevant duration	✓
8.3.3	23 The test facilities act upon the intended luminaires only	✓
8.3.3	24 Test facilities are protected from unauthorised operation	✓
8.3.3	25 Automatic test facilities conform to BS EN 62034	N/A
10.7	26 Training on the use of the test facilities and recording the results of tests has been given to the responsible person	✓
WIRING/EQUIPMENT		
8.1	27 Fixed wiring of the emergency lighting installation has been installed in accordance with BS 7671 (as amended)	✓
8.3.2	28 Isolators, switches and protective devices of the emergency system protected/located and appropriately labelled so as to prevent unauthorised use	✓
FINAL DECLARATION TO BE CONDUCTED AT COMPLETION		
10.7	29 User has been provided with accurate system documentation (drawings layout plans)	✓
10.7	30 User has been made aware of the action they need to take in the event of a test failure	✓
10.7	31 The user has been made aware of the need to maintain an up-to-date test log book	✓
11	32 The emergency lighting system operates correctly when tested	✓
11	33 Deviations (if any) have been recorded accurately	N/A

Assessment carried out by:

Name (CAPITALS)	DANIEL ALLPORT	Signature		Date	25/07/2019
-----------------	----------------	-----------	--	------	------------

Notes: '✓' Indicates that an item was assessed and the declared outcome was **satisfactory**.
'X' Indicates an agreed deviation.
'N/A' Indicates that the assessment of an item was not applicable to the particular installation.

* Illumination is normally checked by visual inspection and from the design spacings. Where measurements are taken the results and details of the instrument used (including serial number) must be appended with this certificate.

NICEIC Approved Contractors have been assessed as having the technical capability to carry out electrical work in compliance with the national electrical safety standard, BS 7671. The scope of that standard includes electrical safety aspects of emergency lighting systems but does not extend to the operational performance of such systems. Consequently, NICEIC is unable to investigate complaints about the operational performance of emergency lighting systems.

Where the client/person ordering the work has reason to believe that the newly installed work does not comply with the requirements of the national electrical safety standard, BS 7671 (as amended), or the particular electrical safety aspects embodied in the other standards included on the certificate, the client should, in the first instance, raise their specific concerns in writing with the Approved Contractor. If those concerns remain unresolved, the client may make a formal complaint to NICEIC.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available on the NICEIC website.

EMERGENCY LIGHTING COMPLETION CERTIFICATE

For small new installations up to 25 self-contained luminaires

DEVIATIONS

Record the details of any agreed deviations.

[illegible]

COMMENTS ON EXISTING INSTALLATION

(Any defects identified on the existing emergency lighting installation, not covered by this certificate, should be recorded below)

None