



Fire Alarm Specification

	Element	Requirement
Fire Alarm Panel	General	Panel must be open protocol, therefore maintenance is not restricted to any one company or small group of companies.. SEE APPENDIX A FOR ALL STATUTORY STANDARDS TO APPLY
Cabling & Devices	Capacity	• An allowance of 20% spare space as a minimum should be allowed for in all zones. • Each zone to have 20% spare device capacity on final installation.
	Devices	• All detection devices to be accessible for maintenance ie. Not installed above ducts or pipework. • Multi functions devices to be used must be justified and approved by CU. • All devices must be permanently and clearly labelled with a unique identity number corresponding to the system address.
	Design and Install	• Fire alarm system to be designed to L1 classification. • Any works to fire alarm systems must include the updating of the central graphics displays. • Fire Alarm systems and all interfaces to be demonstrated for cause and effect prior to handover. • Final connections of new or adapted fire alarm systems to the building system require full Method Statements and Risk Assessments and Permit to Work (PTW) to be issued and term contractor in charge of Fire Alarm system must be in attendance. • All works must include complete details of the device location, device identification in a spreadsheet format
	Cabling	• Cabling should be red as standard. • Fit for purpose • Manufactured to BASEC standards
	Doors	• Door hold backs shall be of a proprietary industry type preferably mounted at high level, where this can not be achieved and approved by CU, they can be floor or wall mounted. FOR FURTHER DETAILS ON DOOR FINISHES SEE THE DOOR FINISHES SPECIFICATION

STATUTORY REGULATIONS

In addition to government legislation, byelaws and local policy documents exist, created by local authorities at both district and county level, demanding the installation of fire alarm systems. These vary from area to area and advice must be sought from the appropriate local authority on any regulations in force.

Standard Number	Title	Status
BS 5839: Part 1: 2008 + A2 2008	Fire detection and alarm systems for buildings. Code of practice for system design, installation, commissioning and maintenance	Current,
BS 5839: Part 3: 1988	Fire detection and alarm systems for buildings. Specification for automatic release mechanisms for certain fire protection equipment	Current
BS 5839: Part 4: 1988	Fire detection and alarm systems for buildings. Specification for control and indicating equipment	Current,
BS 5839: Part 5: 1988	Fire detection and alarm systems for buildings. Specification for optical beam smoke detectors	Current
BS 5839 - 6: 2004	Fire detection and alarm systems for buildings. Code of practice for the design, installation and maintenance of fire detection and fire alarm systems in dwellings	Current
BS 5839: Part 8: 2008	Fire detection and alarm systems for buildings. Code of practice for the design, installation and servicing of voice alarm systems	Current
BS 5839 - 9: 2003	Fire detection and alarm systems for buildings. Code of practice for the design, installation, commissioning and maintenance of emergency voice communication systems	Current
PD 6531: 1997	Queries and interpretations on BS 5839:Parts 1 and 4 (as amended)	Current
BS 5446: Part 1: 2000	Fire detection and fire alarm devices for dwellings. Specification for smoke alarms	Current
BS 4422: Part 3: 1990, ISO 8421: Part 3: 1989	Glossary of terms associated with fire. Fire detection and alarm	Current
BS 5979: 2000	Code of practice for remote centres receiving signals from security systems	Current
BS 7807: 1995	Code of practice for design, installation and servicing of integrated systems incorporating fire detection and alarm systems and/or other security systems for buildings other than dwellings	Current
BS 7671	IEE Wiring Regulations	Current