

AI-CERTIFICATES

Professional certification management services

BS5839-1 FIRE DETECTION AND ALARM SYSTEM INSPECTION AND SERVICING REPORT

*In accordance with BS 5839-1: Fire detection and fire alarm systems for buildings
Code of practice for design, installation, commissioning and maintenance of
non-domestic premises*

CERTIFICATE NUMBER: FS-2025-001

1. SITE DETAILS

Site Name:	Office Tower One
Site Address:	123 Business Street, London
Client/Customer:	Office Tower One
Contact Person:	John Smith
Contact Telephone:	+44 20 1234 5678
Contact Email:	contact@officetower.com

AI-CERTIFICATES

Professional certification management services

2. SYSTEM/EQUIPMENT DETAILS

System Type:	L2
System Category:	P1
Control Panel Make/Model:	
Number of Detection Zones:	8
Number of Devices:	45
Building Floors Covered:	Not specified
Total Floor Area:	Not specified

3. INSPECTION DETAILS

Inspection Date:	01/06/2025
Inspector Name:	Mike Inspector
Inspector Qualification:	Certified Fire Safety Engineer
Inspection Type:	Routine Service
Next Inspection Due:	01/12/2025
Certificate Status:	COMPLETED

AI-CERTIFICATES

Professional certification management services

4. EQUIPMENT/ITEMS TESTED

Item	Location	Type/Description
1	Ground Floor Reception	Optical Smoke Detector
2	Security Room	Main Fire Alarm Control Panel
3	Emergency Exit	Manual Call Point

PASS

PASS

FAIL

5. DEFECTS AND RECOMMENDATIONS

DEFECT 1: Emergency Exit

Defect Description:

Glass broken

Recommendation:

Replace glass element

6. CERTIFICATION STATEMENT

I certify that the fire detection and alarm system detailed above has been inspected and tested in accordance with BS 5839-1. The system is functioning correctly and complies with the relevant standards, subject to any defects or recommendations noted above.

INSPECTOR SIGNATURE:

Name: Mike Inspector

Date: 01/06/2025

CLIENT SIGNATURE:

Name:

Date: