

OSHA 1910 Subpart D — Walking-Working Surfaces

Field Inspection & Compliance Checklist

Project / Building: _____
 Address: _____
 Owner / Mgr: _____

Date: _____
 Inspector: _____
 Weather/Temp: _____

Mark each item: OK = compliant | DEF = deficient (log in Corrective Action summary) | N/A = not present

1. GENERAL SURFACE CONDITIONS — §1910.22

Inspection Item	OK	DEF	N/A	Location/Note
Walking-working surfaces clean, orderly, sanitary; floors dry where feasible (drainage/mats for wet processes)				
Surfaces free of hazards: sharp/protruding objects, loose boards, corrosion, leaks, spills, snow, ice				
Each surface supports its maximum intended load (people + equipment + materials)				
Safe means of access and egress provided and used at every surface				
Surfaces inspected regularly; hazards corrected/repared before reuse, or guarded until repaired				
Structural repairs performed or supervised by a qualified person				

2. PORTABLE LADDERS — §1910.23(b),(c)

Inspection Item	OK	DEF	N/A	Location/Note
Inspected before each shift; defective ladders tagged "Dangerous: Do Not Use" and removed				
Rungs/steps level, uniformly spaced 10–14 in; slip-resistant; free of puncture/laceration hazards				
Used on stable, level surfaces; secured on slippery surfaces / passageways / doorways				
Side rails extend ≥ 3 ft (0.9 m) above the upper landing surface				
Not loaded beyond max intended load; not moved/extended while occupied				
No single-rail ladders; not placed on boxes/barrels for added height; top cap/top step not used as steps				

3. FIXED LADDERS — §1910.23(d) & §1910.28(b)(9)

Inspection Item	OK	DEF	N/A	Location/Note
Capable of supporting max intended load; corrosion-protected; surfaces free of hazards				
≥ 7 in (18 cm) clearance behind rungs; ≥ 15 in (38 cm) each side of centerline (no cage/well)				
Through/side-step rails extend ≥ 42 in (1.1 m) above landing; grab bars where required				
Ladders > 24 ft (7.3 m): equipped with personal fall arrest or ladder safety system (cage/well alone NOT compliant for new installs)				
Replacement sections trigger PFAS/ladder safety system; rest platforms ≤ 150 ft intervals				
NOTE: all fixed ladders must have PFAS or ladder safety system by Nov 18, 2036				

4. STEP BOLTS & MANHOLE STEPS — §1910.24

Inspection Item	OK	DEF	N/A	Location/Note
Inspected at start of shift; corrosion- and slip-resistant				
Step bolts spaced 12–18 in; ≥ 4.5 in clear width; ≥ 7 in behind centerline				
No step bolt bent > 15° from perpendicular (remove & replace if so)				
Post-1/17/2017 step bolts support ≥ 4× max intended load				

5. STAIRWAYS — §1910.25 & §1910.28(b)(11)

Inspection Item	OK	DEF	N/A	Location/Note
Standard stairs at 30–50°; max riser 9.5 in; min tread depth 9.5 in; min width 22 in				
Uniform riser heights & tread depths between landings; ≥ 6 ft 8 in vertical clearance				
Landings/platforms ≥ stair width and ≥ 30 in deep; door swing leaves ≥ 22 in usable platform				
Each stair supports ≥ 5× live load, never < 1,000 lb point load				
Flights with ≥ 3 treads & ≥ 4 risers have stair rail systems + handrails (per Table D-2)				
Landings ≥ 4 ft above lower level protected by guardrail/stair rail; ship/alt-tread stairs have handrails both sides				

6. DOCKBOARDS — §1910.26 & §1910.28(b)(4)

Inspection Item	OK	DEF	N/A	Location/Note
Support max intended load; designed/maintained to prevent transfer vehicles running off edge				
Portable dockboards secured/anchored against displacement; equipped with handholds				
Wheel chocks / sand shoes prevent transport vehicle movement while occupied				
Guardrails or handrails where fall $\geq$ 4 ft (exceptions: motorized materials handling, < 10 ft, trained)				

7. ROPE DESCENT SYSTEMS & ANCHORAGES — §1910.27

Inspection Item	OK	DEF	N/A	Location/Note
Written owner certification on file: each anchorage tested/certified $\geq$ 5,000 lb any direction per worker				
Annual inspection by qualified person current; re-test $\leq$ every 10 years (verify next-due dates)				
RDS inspected at start of each shift; damaged/defective equipment removed immediately				
Proper rigging, anchorages & tiebacks (esp. counterweights, cornice hooks, parapet clamps)				
Each worker on independent PFAS; anchorages for lifelines & suspension lines kept independent				
Not used > 300 ft above grade; stabilization provided for descents > 130 ft; ropes padded at edges				
Tools secured by lanyard; not used in storms / gusty / excessive wind				

8. FALL PROTECTION — DUTY & CRITERIA — §1910.28 / §1910.29

Inspection Item	OK	DEF	N/A	Location/Note
Every unprotected side/edge $\geq$ 4 ft protected (guardrail, safety net, or personal fall protection)				
Holes/skylights $\geq$ 4 ft: covers, guardrails, travel restraint, or PFAS; covers secured + rated $\geq$ 2 $\times$ load				
Low-slope roof: < 6 ft from edge $\rightarrow$ full protection; 6–15 ft $\rightarrow$ protection (designated area if infrequent/temporary); $\geq$ 15 ft $\rightarrow$ protection or enforced 15-ft work rule				
Guardrails: top rail 42 in ($\pm$ 3 in); withstands 200 lb top / 150 lb mid; openings $\leq$ 19 in				
Runways/ramps guarded each unprotected side; dangerous equipment guarded				
Toeboards $\geq$ 3.5 in where falling-object exposure; head protection provided				

9. TRAINING — §1910.30

Inspection Item	OK	DEF	N/A	Location/Note
Each exposed employee trained by a qualified person in fall-hazard recognition & procedures				
Trained in install/inspect/operate/maintain/disassemble of fall protection systems used				
RDS users trained in rigging & use; dockboard users trained in placement/securing				

Inspection Item	OK	DEF	N/A	Location/Note
Retraining performed when workplace, equipment, or employee knowledge changes; training understandable				

CORRECTIVE ACTION SUMMARY

#	§ / Item Deficient	Location	Corrective Action / Scope	Priority
1				
2				
3				
4				
5				
6				

Inspector signature: _____

Date: _____

Owner/Mgr acknowledgment: _____

Date: _____

Field compliance checklist only. Anchorage load-test capacity certification (§1910.27 / §1910.140) and any structural repair affecting integrity must be performed/certified by a qualified person / licensed P.E. Thresholds per 29 CFR 1910 Subpart D, current as of 12/23/2025. © La Gala Construction / Tilt Patchers, Inc. — CGC059211.