

MRPL ENGINEERING STANDARD: STD-MNT-007

Valve Packing Integrity & Flange Degradation Limits

SECTION 6.1: VALVE GLAND PACKING INTEGRITY

Any hydrocarbon valve exhibiting gland weeping during on-stream inspection must be categorized as:

- Category A (>10 drops/min): Immediate online gland tightening or box injection.
- Category B (<10 drops/min): Gland repack scheduled for next unit maintenance turnaround.

SECTION 6.2: FLANGE INTEGRITY LIMITS

Atmospheric surface rust with pit depth under 0.5 mm is classified as Normal Oxidation. Application of anti-corrosive primer recommended during turnaround.