DASHBOARD AMERICAN / BAAJA

Who pays for the grid?

A 30-year estimate of data-center transmission payments under AND pricing

A / ADDITIONAL PAYMENTS

New money caused by AND pricing

$63bn

Above the existing higher-of baseline; matched by lower bills for other customers.

B / ABOVE COST OF SERVICE

Total inherited-grid contribution

$125bn

Above incremental transmission cost; includes payments already made under the baseline.

2027-2056, constant 2026 dollars, undiscounted. A is part of B; do not add them. Cost of service here means incremental *transmission* cost caused by new loads.

Three assumptions, with an 80% load factor

DC growth after 2030 — **2.0% / year**

600 TWh in 2030 becomes 1,004 TWh in 2056.

Incremental network capital — **$0.65m / MW**

A selected cost scenario; test $0.3m-$1.0m/MW.

NITS-equivalent rate — **$95.1 / kW-year**

National cost-to-peak proxy, not an observed tariff average.

A comparable policy scale

About 2.0 times the ITC illustration. JCT officially scored BBB's transmission ITC at **$11.279bn over FY2022-2031**. For a common 30-year comparison, we normalize its annual cash flows to 2026 dollars at an assumed 2.5% inflation rate and repeat that real ten-year profile three times: **$31.7bn**. This is our repeated-program illustration, not an official 30-year score or the 30-year benefit of a single ten-year credit. BAAJA transfers private bills; the ITC costs the federal budget and does not guarantee equivalent bill savings.

Mechanism and limits. AND collects the full annual cost of attributable upgrades plus a contribution to the inherited grid. Incremental receipts are credited out of the shared revenue requirement. Fixed: 75% effective coverage; an 829 GW planning-peak proxy for the incumbent pool; charges from 2030, including prospective charges on 2027-2029 entrants; 40-year assets, 5% real financing and 1.5% O&M. No existing-AND deduction. Growth, cost, coverage and national pooling are assumptions. PUDL v2026.10.0 was reviewed; it does not establish a matched national NITS rate or DC-attributable capital per MW.

Sources: BAAJA draft s.2107(a), pp.229-230; JCT JCX-46-21 p.2; EIA AEO2026 Table54; Grid Strategies Nov2025 p.33. Full calculations, PUDL review and linked sources accompany the dashboard.