


| | | | | | | | | | | | | |
|--|--|-------|----------------------------------|--------------|------------------------------------|----------------------------------|--|---|--|-------------------------------------|-----------------|-----------|
| | REPUBLIC OF THE PHILIPPINES MUNICIPALITY OF MANOLO FORTICH MUNICIPAL ENGINEER'S OFFICE | SEAL: | | | PREPARED BY: | REVIEWED BY: | CHECKED BY: | PROJECT TITLE: | RECOMMENDING APPROVAL BY: | APPROVED BY: | SHEET CONTENTS: | SHEET NO. |
| | | | PROFESSIONAL ELECTRICAL ENGINEER | | HARRY D. RELOSA ENG'G ASSISTANT | CEDRICK A. SESTOSO ENGINEER-I | BERNABE C. AUXTERO JR. MUNICIPAL ENGINEER | ELECTRICAL PLAN MANOLO FORTICH SLAUGHTER HOUSE | JOIE CAESAR M. GAID MUNICIPAL ADMINISTRATOR | ROGELIO N. QUIÑO MUNICIPAL MAYOR | FLOOR PLAN | 1 4 |
| | | | PRC REG. NO. | PTR NO. | | | | | | | | |
| | | | TIN: | DATE ISSUED: | | | | LOCATION: TANKULAN, MANOLO FORTICH BUKIDNON | | | | |



LIGHTING LAYOUT PLAN

SCALE
1:100m



REPUBLIC OF THE PHILIPPINES
MUNICIPALITY OF MANOLO FORTICH
MUNICIPAL ENGINEER'S OFFICE

SEAL:

PROFESSIONAL ELECTRICAL ENGINEER

PRC REG. NO:

TIME:

| | |
|---------|--|
| PTR NO: | |
|---------|--|

DATE ISSUED:

PREPARED BY:

| | |
|--|-----------------|
| | HARRY D. RELOSA |
| | ENG'G ASSISTANT |

REVIEWED BY:

CEDRICK A. SESTOSO
ENGINEER-I

CHECKED BY:

BERNABE C. AUXTERO JR.
MUNICIPAL ENGINEER

PROJECT TITLE:

ELECTRICAL PLAN
MANOLO FORTICH SLAUGHTER HOUSE

LOCATION: TANKULAN, MANOLO FORTICH BUKIDNON

RECOMMENDING APPROVAL BY:

| |
|-------------------------|
| JOIE CAESAR M. GAID |
| MUNICIPAL ADMINISTRATOR |

APPROVED BY:


ROGELIO N. QUIÑO
MUNICIPAL MAYOR

SHEET CONTENTS:

LIGHTING LAYOUT
PLAN

SHEET NO.

4



POWER LAYOUT PLAN

SCALE
1:100m

| | | | | | | | | | | | | |
|--|--|--|-----------------|--------------------|------------------------|---|---|-------------------------|---------------------------|--------------|-----------------|-----------|
| | REPUBLIC OF THE PHILIPPINES MUNICIPALITY OF MANOLO FORTICH MUNICIPAL ENGINEER'S OFFICE | SEAL: | | | PREPARED BY: | REVIEWED BY: | CHECKED BY: | PROJECT TITLE: | RECOMMENDING APPROVAL BY: | APPROVED BY: | SHEET CONTENTS: | SHEET NO. |
| | | <div>PROFESSIONAL ELECTRICAL ENGINEER</div> <div>PTR REG. NO. PTR NO.</div> <div>TIN: DATE ISSUED:</div> | HARRY D. RELOSA | CEDRICK A. SESTOSO | BERNABE C. AUXTERO JR. | ELECTRICAL PLAN MANOLO FORTICH SLAUGHTER HOUSE | JOIE CAESAR M. GAID | ROGELIO N. QUIÑO | POWER LAYOUT PLAN | 3 4 | | |
| | | | ENG'G ASSISTANT | ENGINEER-I | MUNICIPAL ENGINEER | | LOCATION: TANKULAN, MANOLO FORTICH BUKIDNON | MUNICIPAL ADMINISTRATOR | | | MUNICIPAL MAYOR | |
| | | | | | | | | | | | | |

SCHEDULE OF LOADS

| DP | CKT. NO. | DESCRIPTION | NO. OF OUTLETS | VOLTS | VA | AMPERES | PROTECTION PER CIRCUIT | SIZE OF WIRE | SIZE OF CONDUIT Ø |
|-------|----------|--------------------|----------------|-----------|------|------------|------------------------|-------------------------------|-------------------|
| MDP | 1 | LIGHTING OUTLET | 11 | 230 | 1100 | 4.78 | 15 | 2 - 3.5 MM^2 THHN COPPER WIRE | 20 MM |
| | 2 | LIGHTING OUTLET | 10 | 230 | 1000 | 4.35 | 15 | 2 - 3.5 MM^2 THHN COPPER WIRE | 20 MM |
| | 3 | LIGHTING OUTLET | 9 | 230 | 900 | 3.91 | 15 | 2 - 3.5 MM^2 THHN COPPER WIRE | 20 MM |
| | 4 | LIGHTING OUTLET | 5 | 230 | 500 | 2.17 | 15 | 2 - 3.5 MM^2 THHN COPPER WIRE | 20 MM |
| | 5 | CONVENIENCE OUTLET | 7 | 230 | 1260 | 5.48 | 20 | 2 - 3.5 MM^2 THHN COPPER WIRE | 20 MM |
| | 6 | CONVENIENCE OUTLET | 6 | 230 | 1080 | 4.70 | 20 | 2 - 3.5 MM^2 THHN COPPER WIRE | 20 MM |
| | 7 | MOTOR (1HP) | 1 | 230 | 1840 | 8 | 30 | 2 - 5.5 MM^2 THHN COPPER WIRE | 20 MM |
| | 8 | MOTOR (2HP) | 1 | 230 | 2760 | 12 | 30 | 2 - 5.5 MM^2 THHN COPPER WIRE | 20 MM |
| | 9 | MOTOR (1HP) | 1 | 230 | 1840 | 8 | 30 | 2 - 5.5 MM^2 THHN COPPER WIRE | 20 MM |
| | 10 | MOTOR (1.5HP) | 1 | 230 | 2300 | 10 | 30 | 2 - 5.5 MM^2 THHN COPPER WIRE | 20 MM |
| | 11 | MOTOR (1HP) | 1 | 230 | 1840 | 8 | 30 | 2 - 5.5 MM^2 THHN COPPER WIRE | 20 MM |
| | 12 | MOTOR (3HP) | 1 | 230 | 3910 | 17 | 30 | 2 - 5.5 MM^2 THHN COPPER WIRE | 20 MM |
| | 13 | SPARE | | | | | 30 | 2 - 5.5 MM^2 THHN COPPER WIRE | 20 MM |
| | 14 | SPARE | | | | | 30 | 2 - 5.5 MM^2 THHN COPPER WIRE | 20 MM |
| TOTAL | | | | 20,330 VA | | 88.39 AMP. | | | |

TOTAL CURRENT @ 125% S.F. = 88.39 AMPERE X 1.25= 110.49 AMPERE

THEREFORE USE:

150 AMP MAIN CIRCUIT BREAKER 220V, 60Hz, BOLT-ON TYPE
2-38mm^2 THHN/THW COPPER WIRE ON 38mmØ RSC. FOR MAIN FEEDER
1-14mm^2 THHN/THW COPPER WIRE FOR GROUNDING

SIZE OF DISTRIBUTION TRANSFORMER:


TOTAL FULL LOAD CURRENT = 88.39A

KVA RATING = $\frac{88.39 \times 230}{1000}$ = 20.329KVA

USED:

1-25KVA TRANSFORMER SINGLE PHASE, 60HZ, 230V
POLE MOUNTED, OIL IMMERSSED TYPE

SINGLE LINE DIAGRAM
SERVICE ENTRANCE



VOLTAGE DROP CALCULATION

UTILITY PROVIDER TO MCB <2%
MCB TO BRANCH CIRCUIT <3%

$$VD = \frac{K \times L \times I_t \times z}{305m}$$

$$\%VD = \frac{Vd}{Vs} \times 100$$

WHERE:

K : constant 2 for single phase
L : lenght of wires (m)
I_t : line current
Z : cable impedance

Assuming a distance of service entrance of 30m

$$Vd = \frac{2 \times 30m \times 88.89 \times 0.16}{305m} = 2.798$$

$$\%Vd = \frac{2.798}{230} \times 100 = 1.2\%$$

Farthest load of circuit branches =25m

$$Vd = \frac{2 \times 25m \times 17 \times 1.1}{305m} = 3.07$$

$$\%Vd = \frac{3.07}{230} \times 100 = 1.33\%$$

$$\text{Total \%Vd} = 1.2\% + 1.33\% = 2.53\%$$

The computed voltage drop of the building with the total 2.53 percentage (%) of voltage drop meet the required allowable VD of the Philippine Electrical Code.

SHORT CIRCUIT CALCULATION

$$I_{sc} = \frac{P \times .8}{Z} \times \frac{305 \times K}{L}$$

$$I_{sc} = \frac{20,330VA \times .8}{0.16} \times \frac{305 \times 2}{30} = 6,481.82 \text{ AIC}$$

$$I_{sc} = 6.48 \text{ KAIC}$$

USED CIRCUIT BREAKER W/ ATLEAST 10 KAIC RATING


SYMBOLS:

- PANEL BOARD
- CIRCUIT BREAKER
- KILO WATT HOUR METER
- SERVICE ENTRANCE
- GROUND LINE
- S₁ SINGLE GANG SWITCH
- S₂ TWO - GANG SWITCH
- S₃ THREE - GANG SWITCH
- S_{3W} THREE WAY SWITCHH
- LIGHTING OUTLET
- PANEL LIGHT
- CONVENIENCE OUTLET
- MOTOR S.P.O.

SPECIFICATIONS

- ALL INSTALLIONS SHALL BE DONE IN ACCORDANCE WITH THE LATEST EDITION OF THE PHILIPPINE ELECTRICAL CODE AND PERTINENT REQUIREMENT OF THE LOCAL POWER AUTHORITY.
- ALL WIRE INSTALLIONS SHALL BE DONE IN RIGID PVC CONDUIT.
- ALL NONE-CURRENT CARRYING PARTS OF ELECTRICAL APPLIANCES DEVICES SHALL BE PROVIDED WITH PERMANENT PLUGS.
- ALL ELECTRICAL MATERIALS AND FIXTURES SHALL BE FREE FROM DEFECTS.
- NECESSARY BOXES, FITTINGS, ETC. SHALL BE PROVIDED AS REQUIRED ,EVEN IF NOT SHOWN IN THE DRAWINGS.
- ALL ELECTRICAL INSTALLATIONS SHALL BE DONE BY EXPERIENCE ELECTRICIAN WITH THE DIRECT SUPERVISION OF A DULY LICENSED MASTER ELECTRICIAN OR ELECTRICAL ENGINEER.

LOCATION PLAN



| | | | | | | | | | | | |
|--|--|-------|--|--|--|---|--|---|---|---|---------------------|
| | REPUBLIC OF THE PHILIPPINES MUNICIPALITY OF MANOLO FORTICH MUNICIPAL ENGINEER'S OFFICE | SEAL: | PROFESSIONAL ELECTRICAL ENGINEER PTR REG. NO: PTR NO: TIN: DATE ISSUED: | PREPARED BY: HARRY D. RELOSA ENG'G ASSISTANT | REVIEWED BY: CEDRICK A. SESTOSO ENGINEER-I | CHECKED BY: BERNABE C. AUXTERO JR. MUNICIPAL ENGINEER | PROJECT TITLE: ELECTRICAL PLAN MANOLO FORTICH SLAUGHTER HOUSE LOCATION: TANKULAN, MANOLO FORTICH BUKIDNON | RECOMMENDING APPROVAL BY: JOIE CAESAR M. GAID MUNICIPAL ADMINISTRATOR | APPROVED BY: ROGELIO N. QUIÑO MUNICIPAL MAYOR | SHEET CONTENTS: SCHEDULE OF LOADS SINGLE LINE DIAGRAM VOLTAGE DROP & SHORT CIRCUIT COMPUTATION LEGEND SPECIFICATIONS LOCATION PLAN | SHEET NO. 4 4 |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |