



Inspection Report

Morehouse School Of Medicine
720 Westview Drive Sw
Atlanta, GA 30310

Customer ID: **883**

Certificate: **57-R-0124**

Site: 001

MOREHOUSE SCHOOL OF MEDICINE

Type: ROUTINE INSPECTION

Date: 09-FEB-2017

3.25(c)

FACILITIES, GENERAL.

***There is a very large standing puddle of water in the storage rm B-55. Supplies of bedding, caging, etc. are stored in the room. The water is said to be originating from the outside of the building and entering through the wall during inclement weather. Exposure of supplies for the hamsters to this drainage may cause contamination and possibly lead to illness. The leakage shall be repaired and/or items shall not be stored at this location to protect them from contamination. Correct by February 28, 2017.

This inspection and exit interview were conducted with the Director of Operations.

Prepared By: WILLIAMS MICHELLE, D V M USDA, APHIS, Animal Care

Date:
09-FEB-2017

Title: VETERINARY MEDICAL OFFICER 2028

Received by Title: DIRECTOR OF OPERATIONS

Date:
09-FEB-2017



Species Inspected

| Cust No | Cert No | Site | Site Name | Inspection |
|---------|-----------|------|------------------------------|------------|
| 883 | 57-R-0124 | 001 | MOREHOUSE SCHOOL OF MEDICINE | 09-FEB-17 |

| Count | Scientific Name | Common Name |
|---------------|-----------------------------|----------------|
| 000025 | <i>Mesocricetus brandti</i> | GOLDEN HAMSTER |
| 000025 | Total | |