



Inspection Report

Elm Hill Labs Inc
7 Kidder Road
Chelmsford, MA 01824

Customer ID: **9059**
Certificate: **14-A-0017**
Site: 002
ELM HILL LABS INC

Type: ROUTINE INSPECTION
Date: 02-DEC-2014

3.26(d)

FACILITIES, INDOOR.

The concrete floor of a guinea pig housing room has a crack with a gap between the edges that is located in the center of the room and spans approximately the width of the room. Debris could accumulate in the crack and that area is not impervious to moisture. The facility must be maintained to be substantially impervious to moisture and that can be readily sanitized for the well-being of the animals.

Correct by January 16, 2015.

An exit briefing was conducted with the licensee at the time of inspection.

Prepared By: TONYA HADJIS, D V M USDA, APHIS, Animal Care

Date:
02-DEC-2014

Title: SUPERVISORY ANIMAL CARE SPECIALIST 1081

Received by Title: REPORT DELIVERED VIA EMAIL

Date:
02-DEC-2014



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
9059	14-A-0017	002	ELM HILL LABS INC	02-DEC-14

Count	Scientific Name	Common Name
002000	<i>Cavia porcellus</i>	DOMESTIC GUINEA PIG
002000	Total	