



Inspection Report

Novus Biologicals
10730 E Briarwood Ave
Centennial, CO 80112

Customer ID: **331569**
Certificate: **84-R-0089**
Site: 001
NOVUS BIOLOGICALS

Type: ROUTINE INSPECTION
Date: 15-JUL-2015

3.51(d)

FACILITIES, INDOOR.

At least 20 rabbit enclosures are moderately covered in rust. The presence of rust may prevent the required cleaning and sanitizing of the enclosures, which may adversely affect the health and well-being of the animals.

The facility is currently replacing rabbit primary enclosures, food receptacles, wood beams, and other structures. It was noted that one barn has been completed and a second barn had one row of enclosures replaced.

The interior building surfaces of indoor housing facilities shall be constructed and maintained so that they are substantially impervious to moisture and may be readily sanitized.

To be corrected by January 1, 2016

An exit briefing was conducted with the facility representative.

This was a focused inspection of the rabbit facility.

Accompanied on inspection by Dr. Tyler Fields, Veterinary Medical Officer.

Additional Inspectors

Fields Tyler, Veterinary Medical Officer

Prepared By: ALEXANDRA ANDRICOS, D V M USDA, APHIS, Animal Care

Date:
11-AUG-2015

Title: VETERINARY MEDICAL OFFICER 5038

Received by Title: FACILITY REPRESENTATIVE

Date:
11-AUG-2015



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
331569	84-R-0089	001	NOVUS BIOLOGICALS	15-JUL-15

Count	Scientific Name	Common Name
000240	<i>Oryctolagus cuniculus</i>	EUROPEAN RABBIT
000240	Total	