



## Inspection Report

---

EMBRYOTECH LABORATORIES INC  
140 HALE STREET  
HAVERHILL, MA 01830

Customer ID: **502015**

Certificate: **14-R-0213**

Site: 001

EMBRYOTECH LABORATORIES  
INC

Type: ROUTINE INSPECTION

Date: 15-JUN-2021

---

### 3.26(a)

#### Facilities, indoor.

On June 10th, 2021, the ambient temperature in the hamster room reached 30°C (86° F). Ambient temperatures in hamster facilities shall not be allowed to exceed 85° F to provide for their health and comfort.

Corrective measures had been instituted by the facility at the time of this inspection. To remain corrected from this date forward.

This inspection and exit interview were conducted on June 15th with the IACUC Chair.

---

**Prepared By:** EILIS KARR

USDA, APHIS, Animal Care

**Date:**

17-JUN-2021

**Title:** VETERINARY MEDICAL  
OFFICER

**Received by Title:** Facility Representative

**Date:**

17-JUN-2021



### Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
502015	14-R-0213	001	EMBRYOTECH LABORATORIES INC	15-JUN-2021

Count	Scientific Name	Common Name
000050	<i>Mesocricetus auratus</i>	SYRIAN / GOLDEN HAMSTER (COMMON PET/RESEARCH TYPE)
000050	<b>Total</b>	