



Inspection Report

Morehouse School Of Medicine
720 Westview Drive Sw
Atlanta, GA 30310

Customer ID: **883**

Certificate: **57-R-0124**

Site: 001

MOREHOUSE SCHOOL OF MEDICINE

Type: ROUTINE INSPECTION

Date: 13-FEB-2018

3.25(c) REPEAT

FACILITIES, GENERAL.

***There is an ongoing occurrence of standing water in the storage rm B-55. Supplies of caging, enrichment materials, water bottles, etc. are kept in the room. The water is coming in from the outside of the building and entering through the wall during inclement weather. Most of the supplies have been placed on racks or platforms to minimize exposure to contamination but without knowing where the water is coming in there is still potential for contamination. The leakage shall be repaired and/or items shall not be stored at this location to protect them from contamination.

This inspection and exit interview were conducted with the Director of Operations.

Prepared By: WILLIAMS MICHELLE, D V M USDA, APHIS, Animal Care

Date:
13-FEB-2018

Title: VETERINARY MEDICAL OFFICER 2028

Received by Title: DIRECTOR OF OPERATIONS

Date:
13-FEB-2018



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
883	57-R-0124	001	MOREHOUSE SCHOOL OF MEDICINE	13-FEB-18

Count	Scientific Name	Common Name
000012	<i>Mesocricetus auratus</i>	SYRIAN / GOLDEN HAMSTER (COMMON PET/RESEARCH TYPE)
000012	Total	