



## Inspection Report

Molecular Matrix Inc.  
3410 Industrial Blvd Suite 103  
West Sacramento, CA 95691

Customer ID: **331759**  
Certificate: **93-R-0564**  
Site: 002  
Molecular Matrix Inc.

Type: ROUTINE INSPECTION  
Date: 05-MAR-2019

### 3.51(d)

#### FACILITIES, INDOOR.

In the rabbit barn, there were two areas that were no longer substantially impervious to moisture or readily sanitized. On the floor of the aisle between the male rabbits the surface of the floor had flaked off, exposing porous concrete. This area of floor was approximately two feet by two feet in size, spanning more than half the aisle that can no longer be readily sanitized. Above the rabbit enclosures, the vent for the swamp cooler had rusted edges and fur caked on the edges. The rusted areas can no longer be readily sanitized. A system must be in place to maintain all interior surfaces in accordance with the regulations to ensure the health and well being of the animals.

Correction Date: 31 May 19

This inspection and exit interview were conducted with facility representatives.

Prepared By: FRANK KATHARINE, D V M USDA, APHIS, Animal Care

Date:  
07-MAR-2019

Title: VETERINARY MEDICAL OFFICER 6091

Received by Title: SENT BY EMAIL

Date:  
07-MAR-2019



## Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
331759	93-R-0564	002	Molecular Matrix Inc.	05-MAR-19

Count	Scientific Name	Common Name
000040	<i>Oryctolagus cuniculus</i>	DOMESTIC RABBIT / EUROPEAN RABBIT
<b>000040</b>	<b>Total</b>	