



Inspection Report

Biomedical Research Models Inc
57-3 Union Street
Worcester, MA 01608

Customer ID: **23918**

Certificate: **14-R-0192**

Site: 003

BIOMEDICAL RESEARCH MODELS INC

Type: ROUTINE INSPECTION

Date: 22-AUG-2016

3.75(a)

HOUSING FACILITIES, GENERAL.

1. There were several areas of the ceiling in one corner of the cage wash room where the paint was peeling or chips of paint had come off. Unpainted surfaces may not be substantially impervious to moisture.

Per this Section of the Regulations, housing facilities must be kept in good repair. Painted surfaces are impervious to moisture and may be readily sanitized.

The ceiling of the cage wash room needs to be re-painted to maintain the ceiling in good repair.

Correct by 9/2/16.

NOTE - Exit interview held 8/22/16 on-site with facility representatives. Report delivered by e-mail 8/22/16.

END OF REPORT

NOTE - The inspector completed this inspection report when Animal Care was transitioning to a new information management system. Because the inspector re-typed the inspection report into the new system when it was deployed, the "prepared by" date on this inspection report is different than the date the inspector prepared the original inspection report, which occurred on 8/22/16.

Prepared By: PAULA GLADUE, V M D USDA, APHIS, Animal Care

Date:
07-SEP-2016

Title: VETERINARY MEDICAL OFFICER 1054

Received by Title: REPORT DELIVERED BY E-MAIL 8/22/16

Date:
07-SEP-2016



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
23918	14-R-0192	003	BIOMEDICAL RESEARCH MODELS INC	22-AUG-16

Count	Scientific Name	Common Name
000026	<i>Callithrix jacchus</i>	COMMON MARMOSET
000114	<i>Macaca fascicularis</i>	CRAB-EATING MACAQUE / CYNOMOLGUS MONKEY
000012	<i>Macaca mulatta</i>	RHESUS MACAQUE *MALE
000015	<i>Oryctolagus cuniculus</i>	DOMESTIC RABBIT / EUROPEAN RABBIT
000167	Total	