



Inspection Report

Primate Products Inc
34200 Doctors Hammock Road
Immokalee, FL 34142

Customer ID: **1298**
Certificate: **58-B-0536**
Site: 002
PRIMATE PRODUCTS, INC.

Type: ROUTINE INSPECTION
Date: 10-JUN-2014

3.75(f)

HOUSING FACILITIES, GENERAL.

***Room # 6 had accumulation of water on the back corners of the floor and the floor was stained where the pvc pipe from the cages was draining where the water was accumulating. The water was not properly draining to the canal installed in the floor for that purpose.

****Bacteria may grow in the areas of waste water accumulation due to draining deficiency.

***Drainage systems must minimize odors and disease hazards. All drains must be properly constructed, installed, and maintained.

****To be corrected by 7-30-2014.

****An exit interview was conducted with the facility representative.

Prepared By: LUIS NAVARRO, D V M USDA, APHIS, Animal Care

Date:
10-JUN-2014

Title: VETERINARY MEDICAL OFFICER 6025

Received by Title: FACILITY REPRESENTATIVE

Date:
10-JUN-2014



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
1298	58-B-0536	002	PRIMATE PRODUCTS, INC.	10-JUN-14

Count	Scientific Name	Common Name
000360	<i>Macaca fascicularis</i>	CRAB-EATING MACAQUE / CYNOMOLGUS MONKEY
000100	<i>Macaca mulatta</i>	RHESUS MACAQUE *MALE
000460	Total	