



Inspection Report

Loyola University Chicago
2160 S. First Ave.
Building 115 Room 432-8
Maywood, IL 60153

Customer ID: **583**

Certificate: **33-R-0024**

Site: 001

STRITCH SCHOOL OF MEDICINE

Type: ROUTINE INSPECTION

Date: 13-AUG-2015

3.56(c)

SANITATION.

**The humidifier valve/pipe on the south wall of the rabbit room has a significant leak. There was a plastic container beneath the valve to collect the water. There was approximately 4-5 inches of water in the container.

**Several pipes in the room containing the bottle washer have significant leaks. Plastic containers were placed beneath the pipes to collect the dripping water. Plastic containers on the floor holding bottles to be used for the animals were in water from leaking pipes.

**These areas can not be readily cleaned and sanitized due to the leaking pipes which does not facilitate normal husbandry practices. The well-being of the animals could be compromised due to the inability to keep the areas clean and sanitized. The valve and pipes should be repaired. The premises should be kept in good repair in order to facilitate normal husbandry practices.

Correct by: September 3, 2015

Inspection and exit briefing conducted with facility representatives.

Prepared By: DAWN BARKSDALE, D V M USDA, APHIS, Animal Care

Date:
13-AUG-2015

Title: VETERINARY MEDICAL OFFICER 1062

Received by Title: SENT BY EMAIL

Date:
13-AUG-2015



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
583	33-R-0024	001	STRITCH SCHOOL OF MEDICINE	13-AUG-15

Count	Scientific Name	Common Name
000014	<i>Macaca mulatta</i>	RHESUS MACAQUE
000060	<i>Oryctolagus cuniculus</i>	DOMESTIC RABBIT / EUROPEAN RABBIT
000006	<i>Sus domestica</i>	DOMESTIC PIG
000080	Total	