



Inspection Report

Noble Life Sciences Inc
Po Box 242
Woodbine, MD 21797

Customer ID: **13428**

Certificate: **51-R-0092**

Site: 001

NOBLE LIFE SCIENCES INC

Type: ROUTINE INSPECTION

Date: 19-MAR-2014

3.131(c)

SANITATION.

***A 3 inch hole is located in the back wall of the rabbit room. Premises shall be kept in good repair to allow for proper cleaning and sanitation and to control pests. The hole in the wall must be sealed to facilitate prescribed husbandry practices, i.e. cleaning and pest control. Correct by April 4, 2014

The exit briefing was conducted with the facility representative.

Prepared By: GLORIA MCFADDEN, D V M USDA, APHIS, Animal Care

Date:
27-MAR-2014

Title: VETERINARY MEDICAL OFFICER 1048

Received by Title: E-MAIL SIGNATURE

Date:
27-MAR-2014



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
13428	51-R-0092	001	NOBLE LIFE SCIENCES INC	19-MAR-14

Count	Scientific Name	Common Name
000036	<i>Oryctolagus cuniculus</i>	EUROPEAN RABBIT
000036	Total	