



Inspection Report

Jubilant Hollister-Stier (J H S)
3525 N Regal Street
Spokane, WA 99207

Customer ID: 1021

Certificate: 91-R-0011

Site: 001

JUBILANT HOLLISTER-STIER (J H S)

Type: ROUTINE INSPECTION

Date: 16-OCT-2018

3.26(d)

FACILITIES, INDOOR.

Peeling paint is present on the walls in both rooms that house guinea pigs. The paint is peeling along the walls just above the fiberglass reinforced panels. These damaged surfaces are difficult to clean and sanitize. The interior surfaces of indoor housing facilities must be maintained so that they are substantially impervious to moisture and readily sanitized to protect the health and welfare of the animals.

Correct by: January 16, 2019

This inspection and exit briefing were conducted with the facility representatives.

Prepared By: FORBES DIANE, D V M USDA, APHIS, Animal Care

Date:
22-OCT-2018

Title: VETERINARY MEDICAL OFFICER 5053

Received by Title: QC - MICROBIOLOGY MANAGER

Date:
22-OCT-2018



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
1021	91-R-0011	001	JUBILANT HOLLISTER-STIER (J H S)	16-OCT-18

Count	Scientific Name	Common Name
000076	<i>Cavia porcellus</i>	DOMESTIC GUINEA PIG
000076	Total	