



Inspection Report

Gaston College/Vet Tech Program
201 Highway 321 South
Dallas, NC 28034

Customer ID: 988

Certificate: 55-R-0114

Site: 001

GASTON COLLEGE/VET TECH PROGRAM

Type: ROUTINE INSPECTION

Date: 26-FEB-2014

3.1(c)(2)

HOUSING FACILITIES, GENERAL.

The large teaching lab in the veterinary medical technology building has a solid concrete floor. In at least five places the concrete has disintegrated leaving patches of unfinished rough concrete measuring several inches wide. This surface is not being maintained as it needs to be to facilitate ready cleaning and sanitization. The floor needs to be repaired or replaced. To be corrected by 8-26-14.

Exit briefing conducted with facility representative.

Prepared By: LISA MACELDERRY, D V M USDA, APHIS, Animal Care

Date:
26-FEB-2014

Title: VETERINARY MEDICAL OFFICER 1055

Received by Title: DEPARTMENT CHAIR, VET MED TECH

Date:
26-FEB-2014



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
988	55-R-0114	001	GASTON COLLEGE/VET TECH PROGRAM	26-FEB-14

Count	Scientific Name	Common Name
000005	<i>Canis lupus familiaris</i>	DOG ADULT
000004	<i>Felis silvestris catus</i>	CAT ADULT
000009	Total	