



Inspection Report

Sharon Fox
872 Noigo Rd.
South West City, MO 64863

Customer ID: 6215
Certificate: 43-A-2581
Site: 002
SHARON FOX

Type: ROUTINE INSPECTION
Date: 22-JAN-2015

3.2(b)

INDOOR HOUSING FACILITIES.

Sec. 3.2 Indoor housing facilities(b)Ventilation.

The indoor whelping facility did not have sufficient ventilation and smelled of ammonia. The ammonia burned the inspector's eyes and throat. The facility has an auxiliary vent fan in the ceiling that was partially covered with a metal plate. The licensee struggled with the controls to get the fan to turn on. Breathing air with high ammonia levels can lead to health complications. The licensee shall provide sufficient ventilation to minimize odors, drafts, ammonia levels, and moisture condensation and to provide for the health and well-being of the animals.

TO BE CORRECTED BY: 1/23/2015

This inspection and exit briefing were conducted with the licensee.

Prepared By: KELLY ROBERTS, A C I USDA, APHIS, Animal Care

Date:
22-JAN-2015

Title: ANIMAL CARE INSPECTOR 6043

Received by Title: LICENSEE

Date:
22-JAN-2015



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
6215	43-A-2581	002	SHARON FOX	22-JAN-15

Count	Scientific Name	Common Name
000037	<i>Canis lupus familiaris</i>	DOG ADULT
000008	<i>Canis lupus familiaris</i>	DOG PUPPY
000045	Total	