



Inspection Report

Swarthmore College
Animal Care Manager
500 College Ave
Swarthmore, PA 19081

Customer ID: 549
Certificate: 23-R-0020
Site: 001
SWARTHMORE COLLEGE

Type: ROUTINE INSPECTION
Date: 15-JUN-2016

3.26(a)

FACILITIES, INDOOR.

Based on discussion with the facility manager and review of facility records, April 2, 2016, the ambient temperature of the cold chamber, which housed hamsters being acclimatized under Protocol # 02-16-2016, reached 100.4 degree Fahrenheit (38 degrees Celsius). According to facility records, thirty-five hamsters perished due to a malfunction in the cold chamber and alarm system. The alarm system failed to notify personnel when temperatures fell outside the appropriate temperature ranges.

The facility must ensure that the ambient temperature shall not exceed 85 degrees Fahrenheit for the health and/or well-being of these animals.

Based on the review of supportive documentation, the facility took effective corrective actions and implemented appropriate preventive measures to address this issue. There have not been any additional incidents since the corrective actions have been undertaken.

An on-site exit interview was conducted June 15, 2016 with Dr. Ashley McIntosh (VMO) and facility representative. A follow-up exit interview was conducted June 16, 2016 via telephone with facility representative.

Prepared By: ASHLEY MCINTOSH, D V M USDA, APHIS, Animal Care

Date:
17-JUN-2016

Title: VETERINARY MEDICAL OFFICER 6083

Received by Title: SENT VIA EMAIL

Date:
17-JUN-2016



Species Inspected

Cust No	Cert No	Site	Site Name	Inspection
549	23-R-0020	001	SWARTHMORE COLLEGE	15-JUN-16

Count	Scientific Name	Common Name
000117	<i>Phodopus sungorus</i>	DJUNGARIAN / RUSSIAN WINTER WHITE DWARF HAMSTER
000117	Total	