



## Inspection Report

---

Oklahoma State Univ.Ctr For Health Sciences  
1111 West 17th St.  
Tulsa, OK 74107

Customer ID: **335360**  
Certificate: **73-R-0119**  
Site: 001

Oklahoma State University Ctr for Health Sciences

Type: ROUTINE INSPECTION  
Date: 08-DEC-2016

---

### 3.131(c)

#### SANITATION.

In all three vole rooms, there was an accumulation of dirt/dust/debris on large centrally located ceiling ducts. Since the voles are housed with wire mesh top cages, they are potentially exposed to contamination from the dirt/dust/debris on the ceiling or in the air. Facility needs to clean and maintain the ceiling vents as needed to prevent dirt/dust/debris accumulation.

Correction Date: 12/10/2016 December 10, 2016

This inspection and exit interview were conducted with facility representative.

Additional inspector: Dr. Autumn Unck (VMO)

---

Prepared By: MICHAEL TYGART, D V M USDA, APHIS, Animal Care

Date:  
09-DEC-2016

Title: SUPERVISORY ANIMAL CARE SPECIALIST 6009

Received by Title: REPORT SENT VIA EMAIL

Date:  
09-DEC-2016



## Species Inspected

| Cust No | Cert No   | Site | Site Name   | Inspection |
|---------|-----------|------|---|------------|
| 335360  | 73-R-0119 | 001  | Oklahoma State University Ctr for Health Sciences | 08-DEC-16  |

| Count         | Scientific Name             | Common Name  |
|---------------|-----------------------------|--------------|
| 000101        | <i>Microtus ochrogaster</i> | PRAIRIE VOLE |
| <b>000101</b> | <b>Total</b>                |              |